

HEAT RATE MEASUREMENTS THERMAL POWER PLANT NORGENER

Results Heat Rate Measurements Norgener Unit 2

By order of AES Gener Chile

Report no.: 16-0246

Date: 2016-02-12



Project name: Heat Rate Measurements Thermal Power Plant Norgener DNV GL - Energy
Report title: Results Heat Rate Measurements Norgener Unit 2 Energy Advisory
Customer: By order of AES Gener Chile Utrechtseweg 310
Contact person: Juan Carlos Acevedo 6812 AR ARNHEM
Edinson Bascuñan Tel: +3126 356 9111
Gonzalo Ruiz Registered Arnhem 09080262
Cristian Cárdenas
Christian Andonie

Date of issue: 2016-02-12
Project No.: 74108301
Organisation unit: PTM
Report No.: 16-0246

Prepared by: Verified by: Approved by:

R. Tim



M.J.G. Snippert



L.B.M. van Kessel



-
- Unrestricted distribution (internal and external)
 - Unrestricted distribution within DNV GL
 - Limited distribution within DNV GL after 3 years
 - No distribution (confidential)
 - Secret

Reference to part of this report which may lead to misinterpretation is not permissible.

Rev. No.	Date	Reason for Issue	Prepared by	Verified by	Approved by
0	2016-02-12	First issue	R. Tim	M.J.G. Snippert	L.B.M. van Kessel

Table of contents

1	EXECUTIVE SUMMARY	1
2	INTRODUCTION.....	3
3	DESCRIPTION OF THE UNITS.....	3
4	STANDARDS	4
5	TEST PROGRAM HEAT RATE TESTS.....	4
6	REFERENCE CONDITIONS	4
7	MEASUREMENTS.....	4
8	CORRECTIONS TO REFERENCE CONDITIONS	5
9	RESULTS	5
10	UNCERTAINTY CALCULATION	10

Appendix A Test Measurement List & Point & Certificates

Appendix B Correction Curves

Appendix C Results Analysis Coal, Bottom Ash and Fly Ash

Appendix D Measurement Data, DNV GL, Algoritmos and AES

Appendix E Control Panel Screen Dumps

Appendix F Results DNV GL Calculation Program

Appendix G Results ASME PTC 4 Heat Balance Method

Appendix H Results Uncertainty Calculation

1 EXECUTIVE SUMMARY

Project

In close operation and by order of AES Gener, maximum power test and performance tests at Norgener Unit 2, as per CDEC-SING requirement, have been conducted by DNV GL in the period from the 15th of December 2015 until the 17th of December 2015.

Test procedure, with reference 15-1235, final version Rev.2 dated the 16th of September 2015, which has been agreed by parties involved, has been used as a guideline.

Deviating from the test procedure, on site, parties agreed to minimize the test duration of the heat rate tests from four hours to two hours. The needed time for the traverse measurements of the emissions could be decreased, due to the application of interconnection and combining the installed sample tubes in the ducts upstream and downstream of the air heater. The test duration of two hours still complies with the minimum requirement as per ASME PTC4. The duration of the maximum power test remained to five hours. The result of the maximum power test is reported in a separate document, with reference 74108301 CES/PTM 15-3256.

Also deviating from the test procedure is the introduction of an additional mass and heat balance measurement around the deaerator, to determine the final feed water flow of the boiler. It appeared that the feed water flow measurement down streams the feed water pumps, which was foreseen for the evaluation, is affected by swirl and systematically showing a too high value. For that reason we have used the determined boiler feed water flow, based on the main condensate flow (including additional heat balances of the deaerator and HP heaters I and II), as decisive value for the final evaluation.

Purpose

The purpose of the heat rate test is to determine the variable operating costs for Northern Interconnected Grid (CDEC-SING) as per specification "Procedimiento DO: Información de Consumos Específicos" version 3.

Report

In this report the final results are presented of the conducted heat rate tests of Norgener Unit 2. The results are based on the final coal analyse results (100% Signal Peak) and unburned analysis of the fly-ash and bottom-ash. The analysis has been performed by PCM Santiago. As per comment of CDEC-SING during the preparation phase, the fuel properties of the coal have not been applied for correction of the heat rate of the plant.

Final Results

In Table 1 the main final results of the performance test of Unit 2 are presented and a graphical presentation of the net heat rate is given in Figure 1.

For more detail information of the results, we refer to chapter 9 and Appendix F and G.

Table 1 Summary Final Result of Norgener Unit#2 (HHV)

Point Number DNVGL	Performance Test Date Time begin Time end	Unit	100% 15-12-15 09:00 11:00	95% 16-12-15 09:00 11:00	90% 16-12-15 12:45 14:45	80% 17-12-15 09:30 11:30	70% 17-12-15 13:00 15:00	47%/Min 17-12-15 17:00 19:00
	Net Power Plant Corr.							
@0560	Pe Net Power Unit (kWh)	kW	125479	118877	112468	99499	86803	57998
@0561	Pe Aux.Corr.CDEC-SING	kW	128	128	128	128	128	128
@0957	Pe Add.Corr.Power Factor	kW	-361	-327	-295	-238	-184	-90
@0958	Pe Add.Corr.CW Temp.	kW	-191	-197	-65	-246	-235	-295
@0965	Pe Net Power Plant Corr.	kW	125055	118480	112236	99143	86512	57740
	Net Heat Rate Plant Corr.							
@0960	Qc Fuel Consumption Corr.	kJ/s	359445	342946	326338	287887	253696	182883
@0965	Pe Net Power Plant Corr.	kW	125055	118480	112236	99143	86512	57740
@0970	HR Net Heat Rate Plant Corr	kJ/kWh	<u>10347</u>	<u>10420</u>	<u>10467</u>	<u>10454</u>	<u>10557</u>	<u>11402</u>
	Net HR Plant @Standard HHV of 6000 kCal/kg							
@0976	M Coal Corr. HHV (6000)	kg/s	14.31	13.65	12.99	11.46	10.10	7.28
@0965	Pe Net Power Plant Corr.	kW	125055	118480	112236	99143	86512	57740
@0980	HR Net HR Plant (at 6000)	g/kWh	411.9	414.8	416.7	416.1	420.2	453.9




Figure 1 Final Result Net Heat Rate of Norgener Unit#2 (HHV)

2 INTRODUCTION

In close operation and by order of AES Gener, maximum power test and performance tests at Norgener Unit 2, as per CDEC-SING requirement, have been conducted by DNV GL in the period from the 15th of December 2015 until the 17th of December 2015. In total six heat rate tests has been performed.

Test procedure, with reference 15-1235, final version Rev.2 dated the 16th of September 2015, which has been agreed by parties involved, has been used as a guideline.

Deviating from the test procedure, on site, parties agreed to minimize the test duration of the heat rate tests from four hours to two hours. The needed time for the traverse measurements of the emissions could be decreased, due to the application of interconnection and combining the installed sample tubes in the ducts upstream and downstream of the air heater. The test duration of two hours still complies with the minimum requirement as per ASME PTC4.

The duration of the maximum power test remained to five hours. The result of the maximum power test is reported in a separate document, with reference 74108301 CES/PTM 15-3255.

Also deviating from the test procedure is the introduction of an additional mass and heat balance measurement around the deaerator, to determine the final feed water flow of the boiler. It appeared that the feed water flow measurement down streams the feed water pumps, which was foreseen for the evaluation, is affected by swirl and systematically showing a too high value.

For that reason we have used the determined boiler feed water flow, based on the main condensate flow (including additional heat balances of the deaerator and HP heaters I and II), as decisive value for the final evaluation.

As per comment of CDEC-SING during the preparation phase, the fuel properties of the coal have not been applied for correction of the heat rate of the plant.

The following external representatives were present during the performance tests:

CDEC-SING : Mr. Sergio Pizarro

: Mr. José Flores (partly)

3 DESCRIPTION OF THE UNITS

The Norgener power plant (Unit 1 and Unit 2) is located at the coast in Tocopilla, Chile, in the Segunda Region about 175 km north to Antofagasta. Both units are type conventional coal-fired thermal units with a total installed gross power capacity of 264 MWe.

Each unit is foreseen with a conventional condenser, supplied by seawater from the pumping station. Recently both units are extended with a desulfurization plant.

The steam cycle is based on a conventional steam turbine with a nominal operating pressure of 160 bar(a) and a nominal HP and IP operating temperature equal to 537 °C, respectively 537.8°C.

Low pressure exhaust steam from the steam turbine is condensed in a condenser operating working under vacuum. The steam turbine system of unit 2 has no bypass system. Each steam turbine generator is connected to the local 220 kV system through a step-up transformer. The steam turbine generator is connected to the main transformer by means of an isolated phase bus. Each unit includes auxiliary transformers for service of all the plant's own loads and common station loads.

4 STANDARDS

The following standards have been used as a guideline for the maximum power test and heat rate tests:

- ASME PTC 46 Performance Test Code on overall Plant Performance, 1996
- ASME PTC 4 Fired Steam Generators, October 2008
- ASME PTC 6 Steam Turbines, December 2004
- ASME PTC 12.2 Steam Surface Condensers, January 2010
- ASME PTC 19.1 Test uncertainty, November 2005
- ASME PTC 19.5 Flow Measurement, March 2004
- ISO 5167 Measurement of fluid flows by means of differential pressure devices inserted in circular cross-section conduits running
- IAPWS-IFC97 Properties of Water and Steam, The Industrial Standard
- NEN-ISO 18283 Hard coal and coke – manual sampling, September 2006
- NEN-ISO 13909 Mechanical sampling moving streams

5 TEST PROGRAM HEAT RATE TESTS

Six tests, as presented in table 5.1, have been evaluated.

Table 5.1 Test program

Test	100%	95%	90%	80%	70%	47%/Min
Date	15-12-15	16-12-15	16-12-15	17-12-15	17-12-15	17-12-15
Time begin	09:00	09:00	12:45	09:30	13:00	17:00
Time end	11:00	11:00	14:45	11:30	15:00	19:00

6 REFERENCE CONDITIONS

The reference conditions at the system boundary of the plant are defined as follow:

Table 6.1 Reference conditions

Description	Unit	Reference Conditions	
		Unit 1	Unit 2
Ambient temperature	°C	18.8	18.8
Ambient relative humidity	%	75	75
Water content in ambient air	kg/kg	0.0101	0.0101
Cooling water inlet temperature	°C	18	18
Power factor generator steam turbine	-	0.85	0.85

7 MEASUREMENTS

In Appendix A2 an overview is presented of the essential measurements (measuring point list). An overview of these main measurements is also presented in the diagram of Appendix A1.

Essential measurements, which have a significant influence on the accuracy of the net heat rate, have been measured by means of calibrated test instruments or calibrated plant instrumentation.

Measurements which have a minor or even negligible influence or which will be used for information has been measured by means of plant instruments.

The most essential measurements for the net heat rate tests are:

- net power of the unit
- auxiliary power, excluded for power generation as per CDEC-SING requirement
- feed water flow inlet boiler and/or main condensate flow to the deaerator
- attemperator spray water flow to boiler and re-heater line
- main steam pressure and temperature at the outlet of the boiler
- main steam pressure and temperature at the inlet and outlet of the re-heater
- auxiliary steam flow, pressure and temperature at the header
- feed water temperature at the inlet of the boiler
- attemperator spray water temperature boiler and re-heater
- exhaust gas temperature after the air heater
- O₂ and CO content in the exhaust gasses after the air heater
- HHV, LHV, Ash, H₂O and volatile of the hard coal (and ultimate analysis C, H, N, S, O)
- unburned carbon content bottom ash and fly ash
- ambient conditions
- pre-heating of air (if applicable).

8 CORRECTIONS TO REFERENCE CONDITIONS

As per test procedure the following corrections have been applied:

- correction for air temperature at the boundary of the steam generator
- correction for fuel properties of the coal
- correction for cooling water inlet temperature of the condenser
- correction for power factor of the generator
- correction for auxiliary power, as per CDEC-SING requirement

The applicable correction curves are presented in Appendix B.

The correction for Unit 2 as per CDEC-SING definition consists of:

- correction for administration building and lightning
- correction for common auxiliaries, which may be divided equally to both units (air compressors, potable water pump, make up water pump, diesel pump).

9 RESULTS

In the following Annexes the main detail results are presented:

- | | |
|--------------|--|
| Appendix C: | Results analysis coal, bottom ash and fly ash |
| Appendix D: | Measurement data DNV GL, Algorithm and AES |
| Appendix E: | Control panel screen dumps |
| Appendix F: | Results DNV GL calculation program |
| Appendix F1: | Measurement input for DNV GL calculation program condensate balance |
| Appendix F2: | Results DNV GL calculation program condensate balance (long results) |
| Appendix F3: | Measurement input for DNV GL main calculation program |
| Appendix F4: | Results DNV GL main calculation program (long results) |
| Appendix G: | Results ASME PTC 4 Heat Balance Method |
| Appendix H: | Uncertainty calculation |

In the so-called long results output of Appendix F4, details of the calculations of the main program are presented step by step, so each calculated parameter can be easily checked. The numbers in the DNV GL main calculation program of Appendix F3 and F4 are:

- numbers @0001 till @0600: measured values, constants and flag setting
- numbers @0650 till @3054: calculated results.

In table 9.1 till table 9.3 the main results of the performance measurements are summarised.

Table 9.1 Ambient Conditions, Flow Measurements and HP Heater 6

Point Number DNVGL	Performance Test Date Time begin Time end	Unit	100% 15-12-15 09:00 11:00	95% 16-12-15 09:00 11:00	90% 16-12-15 12:45 14:45	80% 17-12-15 09:30 11:30	70% 17-12-15 13:00 15:00	47%/Min 17-12-15 17:00 19:00
Ambient Conditions								
@3001	P Ambient Pressure	mbar	1.0096	1.0095	1.0082	1.0082	1.0071	1.0051
@3002	T Ambient Temperature	°C	20.81	21.49	21.23	20.84	21.37	20.65
@0082	X Relative Humidity	%	64.82	68.98	63.98	61.61	64.47	74.84
@3004	X Absolute Humidity	kg/kg	0.00998	0.01109	0.01012	0.00951	0.0103	0.01149
@3005	X Wet Bulb Temperature	°C	16.50	17.65	16.75	16.09	16.94	17.64
HP Flow Measurement								
@0100	dP HP Feed Water Flow	mbar	440.88	401.04	357.92	277.85	206.07	98.96
@1751	P HP Feed Water	bar(a)	213.5	218.8	222.8	232.6	243	246.8
@1752	T HP Feed Water	°C	178.3	176.5	174.7	170.0	165.4	152.6
@1755	M HP Feed Water Flow	kg/s	118.02	112.68	106.55	94.11	81.23	56.59
@1756	M HP FW Cond.Method	kg/s	<u>114.88</u>	<u>109.69</u>	<u>103.79</u>	<u>91.53</u>	<u>79.18</u>	<u>55.53</u>
HP Spray Water Flow 1								
@0105	dP HP Spray Water Flow 1	mbar	0.00	0.00	0.00	0.00	0.00	0.00
@1761	P HP Spray Water 1	bar(a)	168.7	215.8	219.9	229.7	240.1	243.9
@1762	T HP Spray Water 1	°C	178.3	176.5	174.7	170	165.4	152.6
@1760	M HP Spray Water Flow 1	kg/s	0.00	0.00	0.00	0.00	0.00	0.00
HP Spray Water Flow 2								
@0115	dP HP Spray Water Flow 2	mbar	0.00	18.85	63.47	8.20	39.95	18.16
@1771	P HP Spray Water 2	bar(a)	168.7	215.7	219.7	229.6	240.0	243.8
@1772	T HP Spray Water 2	°C	178.3	176.5	174.7	170.0	165.4	152.6
@1770	M HP Spray Water Flow 2	kg/s	0.00	1.15	2.11	0.76	1.68	1.14
RH Spray Water Flow								
@0110	dP RH Spray Water Flow	mbar	78.06	30.91	19.83	0.00	0.00	3.90
@1801	P RH Spray Water	bar(a)	73.86	75.95	77.22	80.41	83.11	82.98
@1802	T RH Spray Water	°C	175.61	173.55	171.42	112.56	105.63	139.39
@1800	M RH Spray Water Flow	kg/s	2.33	1.47	1.17	0.00	0.00	0.53
Heat Balance HP Heater 6								
@1700	M HP Feed Water Inlet	kg/s	114.9	108.5	101.7	90.8	77.5	54.4
@1701	P HP Feed Water Inlet	bar(a)	184.7	179.8	176.6	170.9	165.3	160.1
@1702	T HP Feed Water Inlet	°C	215.6	213.3	210.9	204.5	198.3	182.2
@1703	H Enthalpy FW Inlet	kJ/kg	928.9	918.6	907.7	878.8	851.4	780.7
@1711	P HP Feed Water Outlet	bar(a)	184.7	179.8	176.6	170.9	165.3	160.1
@1712	T HP Feed Water Outlet	°C	249.1	246.4	243.7	236.3	229.0	210.2
@1713	H Enthalpy FW Outlet	kJ/kg	1082.4	1069.5	1056.7	1022.6	989.0	903.8
@1721	P Drain Outlet	bar(a)	39.15	37.21	35.25	30.83	26.81	18.65
@1722	T Drain Outlet	°C	221.1	218.6	215.9	209.1	202.0	184.3
@1723	H Drain Outlet	kJ/kg	949.1	937.5	925	893.9	861.9	782.5
@1020	M Extraction Flow HPH 6	kg/s	8.246	7.654	7.043	6.011	4.865	3.008

Table 9.2 Boiler Heat Production and Boiler Fuel Efficiency

Point Number DNVGL	Performance Test Date Time begin Time end	Unit	100% 15-12-15 09:00 11:00	95% 16-12-15 09:00 11:00	90% 16-12-15 12:45 14:45	80% 17-12-15 09:30 11:30	70% 17-12-15 13:00 15:00	47%/Min 17-12-15 17:00 19:00
HP Steam Production								
@1750	M HP Feed Water Flow	kg/s	114.88	109.69	103.79	91.53	79.18	55.53
@0901	M Boiler Leakage	kg/s	0.268	0.268	0.268	0.268	0.268	0.268
@0902	M Blow Down Boiler	kg/s	0.00	0.00	0.00	0.00	0.00	0.00
@1000	M HP Steam Outlet Boiler	kg/s	114.61	109.42	103.52	91.26	78.91	55.26
Cold RH Steam Production								
@1000	M HP Steam Outlet Boiler	kg/s	114.61	109.42	103.52	91.26	78.91	55.26
@1020	M Extraction Flow HPH 6	kg/s	8.246	7.654	7.043	6.011	4.865	3.008
@0900	M Leak HP Turb.&Gland St.	kg/s	2.534	2.436	2.323	2.088	1.851	1.393
@0490	M Ejector Steam Design	kg/s	0.18	0.18	0.18	0.18	0.18	0.18
@1035	M CRH Steam Inlet Boiler	kg/s	103.65	99.15	93.98	82.98	72.02	50.68
Hot RH Steam Production								
@1035	M CRH Steam Inlet Boiler	kg/s	103.65	99.15	93.98	82.98	72.02	50.68
@1800	M RH Spray Water Flow	kg/s	2.33	1.47	1.17	0.00	0.00	0.53
@1040	M HRH Steam Outlet Boiler	kg/s	105.99	100.62	95.15	82.98	72.02	51.21
Boiler Heat Production								
@1000	M HP Steam Outlet Boiler	kg/s	114.61	109.42	103.52	91.26	78.91	55.26
@1003	H HP Steam Outlet Boiler	kJ/kg	3406.9	3396.1	3398.2	3405.4	3406.7	3380.0
@1650	M Feed Water Inlet Boiler	kg/s	114.88	108.54	101.68	90.77	77.50	54.39
@1653	H Feed Water Inlet Boiler	kJ/kg	1117.7	1104.7	1091.5	1056.6	1022.1	932.4
@1040	M HRH Steam Outlet Boiler	kg/s	105.99	100.62	95.15	82.98	72.02	51.21
@1043	H HRH Steam Outlet Boiler	kJ/kg	3554.1	3554.3	3556.2	3555.6	3558.8	3497.5
@1035	M CRH Steam Inlet Boiler	kg/s	103.65	99.15	93.98	82.98	72.02	50.68
@1033	H CRH Steam Inlet Boiler	kJ/kg	3098.6	3089.2	3087.6	3077.3	3064.7	3021.3
@1760	M HP Spray Water Flow 1	kg/s	0.00	0.00	0.00	0.00	0.00	0.00
@1763	H HP Spray Water Flow 1	kJ/kg	764.0	758.8	751.3	731.6	712.7	658.2
@1770	M HP Spray Water Flow 2	kg/s	0.00	1.15	2.11	0.76	1.68	1.14
@1773	H HP Spray Water Flow 2	kJ/kg	764.0	758.8	751.3	731.6	712.7	658.2
@1800	M RH Spray Water Flow	kg/s	2.33	1.47	1.17	0.00	0.00	0.53
@1803	H RH Spray Water Flow	kJ/kg	747.2	738.4	729.2	477.9	448.9	591.8
@0830	Q Boiler Heat Production	kJ/s	315833	301067	286586	254021	223998	160985
Boiler Fuel Efficiency								
@0520	Ym Fuel Efficiency Measured	%	87.90	87.82	87.86	88.27	88.33	88.04
@0952	Xc Corr.for Ambient Temp.	%	-0.035	-0.048	-0.043	-0.036	-0.045	-0.032
@0953	Xc Corr.for Humidity	%	-0.002	0.009	-0.001	-0.007	0.001	0.014
@0954	Xc Corr.for Hydrogen Coal	%	0.000	0.000	0.000	0.000	0.000	0.000
@0955	Xc Corr.for Moisture Coal	%	0.000	0.000	0.000	0.000	0.000	0.000
@0956	Xc Corr.for Theor.Dry Air	%	0.000	0.000	0.000	0.000	0.000	0.000
@0950	Ym Fuel Efficiency Corrected	%	<u>87.87</u>	<u>87.79</u>	<u>87.82</u>	<u>88.24</u>	<u>88.29</u>	<u>88.03</u>

Table 9.3 Fuel Consumption, Net Heat Rate and Net Heat Rate at Standard HHV of 6000 kCal/kg

Point Number DNVGL	Performance Test Date Time begin Time end	Unit	100% 15-12-15 09:00 11:00	95% 16-12-15 09:00 11:00	90% 16-12-15 12:45 14:45	80% 17-12-15 09:30 11:30	70% 17-12-15 13:00 15:00	47%/Min 17-12-15 17:00 19:00
@0830	Fuel Consumption Corr. Q Boiler Heat Production	kJ/s	315833	301067	286586	254021	223998	160985
@0950	Yc Fuel Efficiency Corrected	%	87.87	87.79	87.82	88.24	88.29	88.03
@0960	Qc Fuel Consumption Corr.	kJ/s	359445	342946	326338	287887	253696	182883
	Net Power Plant Corr.							
@0560	Pe Net Power Unit (kWh)	kW	125479	118877	112468	99499	86803	57998
@0561	Pe Aux.Corr.CDEC-SING	kW	128	128	128	128	128	128
@0957	Pe Add.Corr.Power Factor	kW	-361	-327	-295	-238	-184	-90
@0958	Pe Add.Corr.CW Temp.	kW	-191	-197	-65	-246	-235	-295
@0965	Pe Net Power Plant Corr.	kW	125055	118480	112236	99143	86512	57740
	Net Heat Rate Plant Corr.							
@0960	Qc Fuel Consumption Corr.	kJ/s	359445	342946	326338	287887	253696	182883
@0965	Pe Net Power Plant Corr.	kW	125055	118480	112236	99143	86512	57740
@0970	HR Net Heat Rate Plant Corr	kJ/kWh	10347	10420	10467	10454	10557	11402
	Mass Coal HHV as Fired							
@0960	Qc Fuel Consumption Corr.	kJ/s	359445	342946	326338	287887	253696	182883
@0295	HHV Coal (as fired)	kJ/kg	23580	23614	23542	23777	23542	23505
@0975	M Coal Corr. HHV (fired)	kg/s	15.24	14.52	13.86	12.11	10.78	7.78
	Mass Coal @6000 kCal/kg							
@0975	M Coal Corr. HHV (fired)	kg/s	15.24	14.52	13.86	12.11	10.78	7.78
@0295	HHV Coal (as fired)	kJ/kg	23580	23614	23542	23777	23542	23505
@0511	HHV Coal (standard)	kCal/kg	6000	6000	6000	6000	6000	6000
@0976	M Coal Corr. HHV (6000)	kg/s	14.31	13.65	12.99	11.46	10.10	7.28
	Net HR Plant @Standard HHV of 6000 kCal/kg							
@0976	M Coal Corr. HHV (6000)	kg/s	14.31	13.65	12.99	11.46	10.10	7.28
@0965	Pe Net Power Plant Corr.	kW	125055	118480	112236	99143	86512	57740
@0980	HR Net HR Plant (at 6000)	g/kWh	411.9	414.8	416.7	416.1	420.2	453.9

10 UNCERTAINTY CALCULATION

Based on the uncertainties of the individual measurements, the total uncertainty of the net corrected heat rate of the plant has been calculated for the full load test (test 1). Detail results are presented in Appendix H.

The used systematically uncertainties (calibrated test equipment DNV GL and AES Gener Metering Systems, coal, fly-ash and bottom-ash analysis, etcetera) are presented in Table 10.1.

For the process variations during the tests, for each individual process value, the applicable fluctuation by means of the standard deviations (random error) has been used. The result of the 2k standard deviations (random errors at 95% confidence interval) is presented in the summary table of Appendix H.

Table 10.1 Used systematically uncertainties

Name	Unit	Uncertainty
Ambient Temperature	°C	± 0.2 K (abs.)
Ambient Pressure	mbar	± 1 mbar (abs.)
Ambient Humidity	%	± 2.5 %
Differential Transmitters	mbar	± 0.2 %
Water and Steam Pressures	bar(a)	± 0.1 %
Water and Steam Temperature (<50°C)	°C	± 0.2 K (abs.)
Water and Steam Temperature (50°C < T <400°C)	°C	± 0.5 K (abs.)
Water and Steam Temperature (> 400°C)	°C	± 1.2 K (abs.)
Net Power Metering	%	± 0.35 %
Gross Power Metering	%	± 0.35 %
Power Factor	%	± 0.35 %
HHV Analysis	kJ/kg	± 1.5 %
Water Content Analysis	%	± 1.0 %
Ash Content Analysis	%	± 1.0 %
C, H, O, N, S Analysis	%	± 1.0 %
Unburned Carbon	%	± 1.0 %
O2 in Exhaust Gas Inlet Air Heater (incl.grid)	%	± 5.0 %
O2 in Exhaust Gas Outlet Air Heater (incl.grid)	%	± 5.0 %
CO in Exhaust Gas Outlet Air Heater (incl.grid)	ppm	± 5.0 %
Temperature Exhaust Gas Inlet Air Heater (incl.grid)	°C	± 2.5 K (abs)
Temperature Exhaust Gas Outlet Air Heater (incl.grid)	°C	± 2.5 K (abs)
Temperature Primary Air Inlet Air Heater	°C	± 1.5 K (abs)
Temperature Secondary Air Inlet Air Heater	°C	± 1.5 K (abs)
Total Auxiliary Power within System Boundary	kW	± 5.0 %

The summary result of the uncertainty calculation (Appendix H) is presented in Table 10.2.

Table 10.2 Uncertainty Net Heat Rate of Norgener Unit 2

Uncertainty Process Value	Unit	Uncertainty Test 1
σ Net Heat Rate Plant Corrected	%	± 2.3 %




APPENDIX A

Test Measurement List & Point



APPENDIX A1

Location of the Test Measurement Points





APPENDIX A2

DNV GL Test Measuring Points List

AES GENER								Date	11-dec-15
Norgener								Revision	Rev 0
Unit 2									
<i>TEST POINT</i>									<i>REMARKS</i>
DNV/GL No.	Code	Description	Type	Test instr.	Unit	Reading	Ref. #	Supplier	
							Geod.H.		
Ambient Condition									
81	-	Ambient Temperature Dry	T	4701	°C	-	-	DNV-GL	
82	-	Ambient Relative Humidity	RH	0013	%	-	-	DNV-GL	R15130
80	-	Ambient Pressure	P	8123	mbar	-	-	DNV-GL	
Flow Measurements Water/Steam/Air									
100	1/2 F0001	Feedwater Differential Pressure	dP	2802	mbar	-	-	DNV-GL	
105	1/2 F0002	SH Spray Differential Pressure No.1	dP	2803	mbar	-	-	DNV-GL	
115	1/2 F0003	SH Spray Differential Pressure No.2	dP	2804	mbar	-	-	DNV-GL	
110	1/2 F0004	RH Spray Differential Pressure	dP	2805	mbar	-	-	DNV-GL	
13	1/2 F4003	Condensate Differential Pressure	dP	2806	mbar	-	-	DNV-GL	
Pressure Measurements Water/Steam									
20	1/2 F4003	Condensate to Deaerator Pressure	P	2360	bar(g)	-	-	3.90M	DNV-GL
50	1/2 P4831	Extraction Steam Pressure Deaerator	P	2358	bar(g)	-	-	-0.40M	DNV-GL
77	1/2 P4869	Extraction Steam to HP Heater 1	P	2361	bar(g)	-	0.00M	DNV-GL	
101	1/2 F0001	Feedwater Mass Flow : Pressure + side	P	2391	bar(g)	-	-3.35M	DNV-GL	
106	1/2 F0002	SH Spray Water: Pressure + side No.1	P	2392	bar(g)	-	-4.70M	DNV-GL	
116	1/2 F0003	SH Spray Water: Pressure + side No.2	P	2393	bar(g)	-	-2.50M	DNV-GL	
111	1/2 F0004	Reheater Spray Water: Pressure + side	P	2352	bar(g)	-	-4.70M	DNV-GL	
130	1/2 P0803	HP Steam Pressure	P	2394	bar(g)	-	-20.95M	DNV-GL	
133	1/2 P0804	Cold Reheat Pressure inlet before RH	P	2363	bar(g)	-	+0.70M	DNV-GL	
135	1/2 P0805	Reheater Outlet Steam Pressure	P	2366	bar(g)	-	-21.25M	DNV-GL	
124	1/2 P4865	Feed Water HP Heater 2 Outlet	P	2395	bar(g)	-	0.00M	DNV-GL	
140	1/2 P0801	Feed Water Boiler Inlet	P	2399	bar(g)	-	+1.00M	DNV-GL	
120	1/2 P4870	Steam Extraction to HP Heater 2	P	2357	bar(g)	-	-0.75M	DNV-GL	

AES GENER				Date 11-dec-15			
Norgener Unit 2				Revision Rev 0			
TEST POINT		INSTRUMENT		REMARKS			
DNV/GL No.	Code	Description	Type	Test instr.	Unit	Reading	Ref. # Geod.H.
Temperatures Measurements Water/Steam							
21	1/2 T4903	Condensate to Deaerator	T	4702	°C	-	DNV-GL R15131
51	1/2 T4820	Steam Extraction to Deaerator	T	4208	°C	-	DNV-GL R15141
60	1/2 T4825	Feedwater Temperature inlet pump 1	T	4213	°C	-	DNV-GL R15136
61	1/2 T4826	Feedwater Temperature inlet pump 2	T	-	°C	-	DNV-GL Pump was not running
62	1/2 T4827	Feedwater Temperature inlet pump 3	T	4207	°C	-	DNV-GL R15142
78	1/2 T4925	Steam Extraction to HP Heater 1	T	4201	°C	-	DNV-GL R15132
102	1/2 T4009	Feedwater Mass Flow : Temperature	T	4209	°C	-	DNV-GL R15135
141	1/2 T0001	Feedwater Temperature inlet Boiler	T	4212	°C	-	DNV-GL R15145
131	1/2 T0012	HP Steam Temperature	T	4202	°C	-	DNV-GL R15140
134	1/2 T0041	Cold Reheat Temperature inlet before RH	T	4210	°C	-	DNV-GL R15144
136	1/2 T0505	Reheater Outlet Steam Temp	T	4204	°C	-	DNV-GL R15137A
112	1/2 T4911	RH Spray water temperature FW pump 1	T	4211	°C	-	DNV-GL R15143
113	1/2 T4912	RH Spray water temperature FW pump 2	T	-	°C	-	DNV-GL Pump was not running
114	1/2 T4913	RH Spray water temperature FW pump 3	T	4214	°C	-	DNV-GL R15139
123	1/2 T4832	Feed Water HP Heater 2 inlet	T	3241	°C	-	DNV-GL R15169
125	1/2 T4833	Feed Water HP Heater 2 outlet	T	3301	°C	-	DNV-GL R15169
121	1/2 T4926	Steam Extraction to HP Heater 2	T	4206	°C	-	DNV-GL R15134
126	1/2 T4839	Drain Temp. HP Heater 2	T	3246	°C	-	DNV-GL R15169
127	1/2 T4838	Drain Temp. HP Heater 1	T	4205	°C	-	DNV-GL R15138
Air and Flue Gas Temperatures							
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5401	°C	-	DNV-GL Exhaust extraction probe 104, R15206-1
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5431	°C	-	DNV-GL Exhaust extraction probe 104, R15207-1
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5461	°C	-	DNV-GL Exhaust extraction probe 104, R15208-1
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5402	°C	-	DNV-GL Exhaust extraction probe 105, R15206-2
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5432	°C	-	DNV-GL Exhaust extraction probe 105, R15207-2
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5462	°C	-	DNV-GL Exhaust extraction probe 105, R15208-2
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5403	°C	-	DNV-GL Exhaust extraction probe 106, R15206-3
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5433	°C	-	DNV-GL Exhaust extraction probe 106, R15207-3
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5463	°C	-	DNV-GL Exhaust extraction probe 106, R15208-3

Client Location Unit			AES GENER Norgener Unit 2			Date Revision	11-dec-15 Rev 0	
TEST POINT	Code	Description	Type	Test instr.	Unit	Reading	Ref. #	Supplier
DNV/GL No.						Geod.H.		REMARKS
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5404	°C	-	DNV-GL	Exhaust extraction probe 107, R15206-4
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5434	°C	-	DNV-GL	Exhaust extraction probe 107, R15207-4
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5464	°C	-	DNV-GL	Exhaust extraction probe 107, R15208-4
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5405	°C	-	DNV-GL	Exhaust extraction probe 108, R15206-5
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5435	°C	-	DNV-GL	Exhaust extraction probe 108, R15207-5
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5465	°C	-	DNV-GL	Exhaust extraction probe 108, R15208-5
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5406	°C	-	DNV-GL	Exhaust extraction probe 109, R15206-6
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5436	°C	-	DNV-GL	Exhaust extraction probe 109, R15207-6
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5466	°C	-	DNV-GL	Exhaust extraction probe 109, R15208-6
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5407	°C	-	DNV-GL	Exhaust extraction probe 110, R15206-7
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5437	°C	-	DNV-GL	Exhaust extraction probe 110, R15207-7
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5467	°C	-	DNV-GL	Exhaust extraction probe 110, R15208-7
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5408	°C	-	DNV-GL	Exhaust extraction probe 113, R15206-8
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5438	°C	-	DNV-GL	Exhaust extraction probe 113, R15207-8
201	1/2 Test Nozzles	GAH Inlet Exhaust Gas Temp. A	T	5468	°C	-	DNV-GL	Exhaust extraction probe 113, R15208-8
203	1/2 Test Nozzles	GAH Outlet Exhaust Gas Temp. A	T	5501	°C	-	DNV-GL	Exhaust extraction probe 117, R15166-1
203	1/2 Test Nozzles	GAH Outlet Exhaust Gas Temp. A	T	5531	°C	-	DNV-GL	Exhaust extraction probe 117, R15167-2
203	1/2 Test Nozzles	GAH Outlet Exhaust Gas Temp. A	T	5561	°C	-	DNV-GL	Exhaust extraction probe 117, R15168-2
203	1/2 Test Nozzles	GAH Outlet Exhaust Gas Temp. A	T	5502	°C	-	DNV-GL	Exhaust extraction probe 118, R15166-2
203	1/2 Test Nozzles	GAH Outlet Exhaust Gas Temp. A	T	5532	°C	-	DNV-GL	Exhaust extraction probe 118, R15167-3
203	1/2 Test Nozzles	GAH Outlet Exhaust Gas Temp. A	T	5562	°C	-	DNV-GL	Exhaust extraction probe 118, R15168-3
203	1/2 Test Nozzles	GAH Outlet Exhaust Gas Temp. A	T	5503	°C	-	DNV-GL	Exhaust extraction probe 119, R15166-3
203	1/2 Test Nozzles	GAH Outlet Exhaust Gas Temp. A	T	5533	°C	-	DNV-GL	Exhaust extraction probe 119, R15167-5
203	1/2 Test Nozzles	GAH Outlet Exhaust Gas Temp. A	T	5563	°C	-	DNV-GL	Exhaust extraction probe 119, R15168-4
203	1/2 Test Nozzles	GAH Outlet Exhaust Gas Temp. A	T	5506	°C	-	DNV-GL	Exhaust extraction probe 122, R15166-6
203	1/2 Test Nozzles	GAH Outlet Exhaust Gas Temp. A	T	5536	°C	-	DNV-GL	Exhaust extraction probe 122, R15167-9
203	1/2 Test Nozzles	GAH Outlet Exhaust Gas Temp. A	T	5566	°C	-	DNV-GL	Exhaust extraction probe 122, R15168-8
203	1/2 Test Nozzles	GAH Outlet Exhaust Gas Temp. A	T	5505	°C	-	DNV-GL	Exhaust extraction probe 121, R15166-5
203	1/2 Test Nozzles	GAH Outlet Exhaust Gas Temp. A	T	5535	°C	-	DNV-GL	Exhaust extraction probe 121, R15167-8
203	1/2 Test Nozzles	GAH Outlet Exhaust Gas Temp. A	T	5565	°C	-	DNV-GL	Exhaust extraction probe 121, R15168-6

Internal Boundary Conditions for CT correction / ST correction



APPENDIX A3

DNV GL Calibration Certificates



T.C.L. Tradinco Calibration Laboratory

Page 1 of 2



CALIBRATION CERTIFICATE

Certificate number : 21500262R1

Applicant DNV GL
Utrechtseweg 310
6812 AR Arnhem

Instrument Pressure transmitter
Manufacturer ABB
Type 266MST
Serial number 3K65000006803
Service number 18065
Customer identification number DP 2802

Calibration method This calibration is carried out with :
Deadweight tester type : T1100/1 S/N : 4275/86 Cal. Due : 11 July 2018
Deadweight tester type : T2300/1 S/N : 6612/91 Cal. Due : 18 July 2018

During calibration a testpressure is put under a calibrated measuring piston which is loaded with calibrated weights

Environmental conditions Temperature: 20.0°C ± 2°C
Humidity: 55 %rh ± 25 %rh

Date / period of calibration 24 February 2015

Results See following page(s)
Uncertainty ± 0.011 % of reading with use of correction figures in the range of 20 - 100 % of full scale

The reported uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %.
The standard uncertainty has been determined in accordance with document EA-4/02.

Calculated by software revision: 2.7.6.6/2.35

Traceability The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.

Date 24 February 2015

Name A.G. v.d. Berghe
Deputy Head of TCL

Industrieweg 74
2651 BD Berkel en Rodenrijs
The Netherlands
Tel. : +31(0)105112911
Telefax : +31 (0)105115114

All our offers and agreements are governed by the FHI General Conditions of Delivery 2014 issued by FHI, Federation of Technology Branches, filed at the Chamber of Commerce of Gooi-, Eem- and Flevoland under the number 40507574. These general conditions are available for free at www.tradinco.com

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced after written permission by T.C.L.

This certificate is issued provided that neither T.C.L. nor the RvA assumes any liability



The Calibration Company

T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 2 of 2

Certificate number : 21500262R1

	Standard 1	Standard 2	Instrument
Service number			18065
Type	T1100/1	T2300/1	266MST
Manufacturer	Tradinco Instruments	Tradinco Instruments	ABB
Description	Deadweight tester	Deadweight tester	Pressure transmitter
Serial number	4275/86	6612/91	3K650000006803
Range	(30 ÷ 2000) mbar	(0.2 ÷ 35) bar	(0 ÷ 2500) mbar
Medium	Air	Air	Air
Accuracy	±0.01 % R	±0.01 % R	±0.1 % R
Temperature	21.0°C ± 0.5°C	21.0°C ± 0.5°C	

MP.	STANDARD		INSTRUMENT					
	INPUT UP mbar	INPUT DOWN mbar	READING UP mbar	READING DOWN mbar	ERROR UP % R	ERROR DOWN % R	LIMIT UP % R	LIMIT DOWN % R
1	0.0000	0.0000	0.01	0.01			± 0.10	± 0.10
2	29.9700	29.9700	29.97	29.98	0.00	0.03	± 0.10	± 0.10
3	49.9683	49.9683	49.98	49.98	0.02	0.02	± 0.10	± 0.10
4	99.9630	99.9630	99.97	99.97	0.01	0.01	± 0.10	± 0.10
5	199.960	199.960	199.96	199.96	0.00	0.00	± 0.10	± 0.10
6	299.957	299.957	299.96	299.95	0.00	0.00	± 0.10	± 0.10
7	449.955	449.955	449.96	449.94	0.00	0.00	± 0.10	± 0.10
8	599.947	599.947	599.95	599.94	0.00	0.00	± 0.10	± 0.10
9	799.937	799.937	799.94	799.93	0.00	0.00	± 0.10	± 0.10
10	999.933	999.933	999.92	999.93	0.00	0.00	± 0.10	± 0.10
11	1249.94	1249.94	1249.92	1249.92	0.00	0.00	± 0.10	± 0.10
12	1499.93	1499.93	1499.92	1499.90	0.00	0.00	± 0.10	± 0.10
13	1999.91	1999.91	1999.87	1999.88	0.00	0.00	± 0.10	± 0.10
14	2500.04		2500.09		0.00		± 0.10	

Before calibration the transmitter has been set to zero.

The transmitter is mounted in a frame and the whole is calibrated in the horizontal position.

The read-out of the transmitter was done using the software Studio302 / ThermoLyse on a laptop of the customer.

Customer ID. no. : DP 2802

Customer ref. : 1.099.74103420.400

Our ref. : 61402416

Customer : DNV GL

Calibrated by
TCL Technician

C. Martinus
Cal. date : 24 February 2015

Approved by
Deputy Head of TCL

A.G.v.d.Berghe
Date : 24 February 2015
Berkel en Rodenrijs



The Calibration Company

T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 1 of 2

Certificate number : 21500524

Applicant	DNV GL Utrechtseweg 310 6812 AR Amhem
Instrument	Pressure transmitter
Manufacturer	ABB
Type	266MST
Serial number	3K650000006804
Service number	18222
Customer identification number	DP 2803
Calibration method	This calibration is carried out with: Deadweight tester type : T1100/1 S/N : 4275/86 Cal. Due : 11 July 2018 Deadweight tester type : T2300/1 S/N : 6612/91 Cal. Due : 18 July 2018

During calibration a testpressure is put under a calibrated measuring piston which is loaded with calibrated weights

Environmental conditions	Temperature: 20.0°C ± 2°C Humidity: 55 %rh ± 25 %rh
Date / period of calibration	8 April 2015

Results	See following page(s)
Uncertainty	± 0.012 % of reading with use of correction figures in the range of 20 - 100 % of full scale

The reported uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %.
The standard uncertainty has been determined in accordance with document EA-4/02.

Calculated by software revision: 2.7.6.6/2.33

Traceability	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	8 April 2015

Name
S. Baidjnath-Misier
Head of TCL

Industrieweg 74
2651 BD Berkel en Rodenrijs
The Netherlands
Tel. : +31(0)105112911
Telefax : +31 (0)105115114

All quotations and deliveries are subject to the general delivery- and payment conditions of the "Coöperatieve Vereniging Het Instrument U.A." filed with the Registry of the District Court in Utrecht on 13-01-1993 and with the Chamber of Commerce and Industry in Amersfoort

Reproduction of the complete certificate is allowed.
Parts of the certificate may only be reproduced after written permission by T.C.L.

This certificate is issued provided that neither T.C.L. nor the RvA assumes any liability



The Calibration Company

T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 2 of 2

Certificate number : 21500524

	Standard 1	Standard 2	Instrument
Service number			18222
Type	T1100/1	T2300/1	266MST
Manufacturer	Tradinco Instruments	Tradinco Instruments	ABB
Description	Deadweight tester	Deadweight tester	Pressure transmitter
Serial number	4275/86	6612/91	3K65000006804
Range	(30 ± 2000) mbar	(0.2 ± 35) bar	(0 ± 2500) mbar
Medium	Air	Air	Air
Accuracy	±0.01 % R	±0.01 % R	±0.1 % R
Temperature	21.1°C ± 0.5°C	21.1°C ± 0.5°C	

MP.	STANDARD		INSTRUMENT					
	INPUT UP mbar	INPUT DOWN mbar	READING UP mbar	READING DOWN mbar	ERROR UP % R	ERROR DOWN % R	LIMIT UP % R	LIMIT DOWN % R
1	0.0000	0.0000	0.01	0.01			± 0.10	± 0.10
2	29.9699	29.9699	29.97	29.98	0.00	0.03	± 0.10	± 0.10
3	49.9682	49.9682	49.97	49.97	0.00	0.00	± 0.10	± 0.10
4	99.9627	99.9627	99.97	99.97	0.01	0.01	± 0.10	± 0.10
5	199.960	199.960	199.96	199.96	0.00	0.00	± 0.10	± 0.10
6	299.956	299.956	299.96	299.97	0.00	0.00	± 0.10	± 0.10
7	449.954	449.954	449.95	449.96	0.00	0.00	± 0.10	± 0.10
8	599.945	599.945	599.94	599.95	0.00	0.00	± 0.10	± 0.10
9	799.935	799.935	799.93	799.93	0.00	0.00	± 0.10	± 0.10
10	999.930	999.930	999.92	999.93	0.00	0.00	± 0.10	± 0.10
11	1249.94	1249.94	1249.92	1249.94	0.00	0.00	± 0.10	± 0.10
12	1499.92	1499.92	1499.91	1499.92	0.00	0.00	± 0.10	± 0.10
13	1999.90	1999.90	1999.90	1999.90	0.00	0.00	± 0.10	± 0.10
14	2500.04		2500.11		0.00		± 0.10	

Before calibration the transmitter has been set to zero.

The transmitter is mounted in a frame and the whole is calibrated in the horizontal position.

The read-out of the transmitter was done using the software Studio302 / ThermoLyse on a laptop of the customer.

Customer ID. no. : DP 2803

Customer ref. : 9.099.74103420.400

Our ref. : 61500533

Customer : DNV GL

Calibrated by

TCL Technician

C. Martinus

Cal. date : 8 April 2015

Approved by

Head of TCL

S. Bandjmath-Misier

Date : 8 April 2015

Berkel en Rodenrijs



The Calibration Company

T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 1 of 2

Certificate number : 21500527

Applicant	DNV GL Utrechtseweg 310 6812 AR Amhem
Instrument	Pressure transmitter
Manufacturer	ABB
Type	266MST
Serial number	3K650000006805
Service number	18223
Customer identification number	DP 2804
Calibration method	This calibration is carried out with: Deadweight tester type : T1100/1 S/N : 4275/86 Cal. Due : 11 July 2018 Deadweight tester type : T2300/1 S/N : 6612/91 Cal. Due : 18 July 2018

During calibration a testpressure is put under a calibrated measuring piston which is loaded with calibrated weights

Environmental conditions	Temperature: 20.0°C ± 2°C Humidity: 55 %rh ± 25 %rh
Date / period of calibration	9 April 2015

Results	See following page(s)
Uncertainty	± 0.012 % of reading with use of correction figures in the range of 20 - 100 % of full scale

The reported uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %.
The standard uncertainty has been determined in accordance with document EA-4/02.

Calculated by software revision: 2.7.6.6/2.33

Traceability	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	9 April 2015

Name
S. Baidjnath-Misier
Head of TCL

Industrieweg 74
2651 BD Berkel en Rodenrijs
The Netherlands
Tel. : +31(0)105112911
Telefax : +31 (0)105115114

All quotations and deliveries are subject to the general delivery- and payment conditions of the "Coöperatieve Vereniging Het Instrument U.A." filed with the Registry of the District Court in Utrecht on 13-01-1993 and with the Chamber of Commerce and Industry in Amersfoort

Reproduction of the complete certificate is allowed.
Parts of the certificate may only be reproduced after written permission by T.C.L.

This certificate is issued provided that neither T.C.L. nor the RvA assumes any liability



T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 2 of 2

Certificate number : 21500527

	Standard 1	Standard 2	Instrument
Service number			18223
Type	T1100/1	T2300/1	266MST
Manufacturer	Tradinco Instruments	Tradinco Instruments	ABB
Description	Deadweight tester	Deadweight tester	Pressure transmitter
Serial number	4275/86	6612/91	3K65000006805
Range	(30 ± 2000) mbar	(0.2 ± 35) bar	(0 ± 2500) mbar
Medium	Air	Air	Air
Accuracy	±0.01 % R	±0.01 % R	±0.1 % R
Temperature	20.3°C ± 0.5°C	20.3°C ± 0.5°C	

MP.	STANDARD		INSTRUMENT					
	INPUT UP mbar	INPUT DOWN mbar	READING UP mbar	READING DOWN mbar	ERROR UP % R	ERROR DOWN % R	LIMIT UP % R	LIMIT DOWN % R
1	0.0000	0.0000	0.00	-0.04	0.00		± 0.10	± 0.10
2	29.9705	29.9705	30.00	29.94	0.10	-0.10	± 0.10	± 0.10
3	49.9693	49.9693	50.00	49.95	0.06	-0.04	± 0.10	± 0.10
4	99.9649	99.9649	100.02	99.94	0.06	-0.02	± 0.10	± 0.10
5	199.964	199.964	200.07	199.98	0.05	0.01	± 0.10	± 0.10
6	299.963	299.963	300.08	300.00	0.04	0.01	± 0.10	± 0.10
7	449.964	449.964	450.13	450.04	0.04	0.02	± 0.10	± 0.10
8	599.958	599.958	600.15	600.07	0.03	0.02	± 0.10	± 0.10
9	799.952	799.952	800.26	800.14	0.04	0.02	± 0.10	± 0.10
10	999.952	999.952	1000.26	1000.26	0.03	0.03	± 0.10	± 0.10
11	1249.96	1249.96	1250.35	1250.34	0.03	0.03	± 0.10	± 0.10
12	1499.95	1499.95	1500.45	1500.49	0.03	0.04	± 0.10	± 0.10
13	1999.95	1999.95	2000.60	2000.58	0.03	0.03	± 0.10	± 0.10
14	2500.07		2501.01		0.04		± 0.10	

Before calibration the transmitter has been set to zero.

The transmitter is mounted in a frame and the whole is calibrated in the horizontal position.

The read-out of the transmitter was done using the software Studio302 / ThermoLyse on a laptop of the customer.

Customer ID. no. : DP 2804

Customer ref. : 9.099.74103420.400

Our ref. : 61500533

Customer : DNV GL

Calibrated by

TCL Technician

C. Martinus

Cal. date : 9 April 2015

Approved by

Head of TCL

S. Bandjmath-Misier

Date : 9 April 2015

Berkel en Rodenrijs



The Calibration Company

T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 1 of 2

Certificate number : 21500528

Applicant	DNV GL Utrechtseweg 310 6812 AR Amhem
Instrument	Pressure transmitter
Manufacturer	ABB
Type	266MST
Serial number	3K650000006806
Service number	18224
Customer identification number	DP 2805
Calibration method	This calibration is carried out with: Deadweight tester type : T1100/1 S/N : 4275/86 Cal. Due : 11 July 2018 Deadweight tester type : T2300/1 S/N : 6612/91 Cal. Due : 18 July 2018

During calibration a testpressure is put under a calibrated measuring piston which is loaded with calibrated weights

Environmental conditions	Temperature: 20.0°C ± 2°C Humidity: 55 %rh ± 25 %rh
Date / period of calibration	9 April 2015

Results	See following page(s)
Uncertainty	± 0.012 % of reading with use of correction figures in the range of 20 - 100 % of full scale

The reported uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %.
The standard uncertainty has been determined in accordance with document EA-4/02.

Calculated by software revision: 2.7.6.6/2.33

Traceability	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	9 April 2015

Name
S. Baidjnath-Misier
Head of TCL

Industrieweg 74
2651 BD Berkel en Rodenrijs
The Netherlands
Tel. : +31(0)105112911
Telefax : +31 (0)105115114

All quotations and deliveries are subject to the general delivery- and payment conditions of the "Coöperatieve Vereniging Het Instrument U.A." filed with the Registry of the District Court in Utrecht on 13-01-1993 and with the Chamber of Commerce and Industry in Amersfoort

Reproduction of the complete certificate is allowed.
Parts of the certificate may only be reproduced after written permission by T.C.L.

This certificate is issued provided that neither T.C.L. nor the RvA assumes any liability



T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 2 of 2

Certificate number : 21500528

	Standard 1	Standard 2	Instrument
Service number			18224
Type	T1100/1	T2300/1	266MST
Manufacturer	Tradinco Instruments	Tradinco Instruments	ABB
Description	Deadweight tester	Deadweight tester	Pressure transmitter
Serial number	4275/86	6612/91	3K65000006806
Range	(30 ± 2000) mbar	(0.2 ± 35) bar	(0 ± 2500) mbar
Medium	Air	Air	Air
Accuracy	±0.01 % R	±0.01 % R	±0.1 % R
Temperature	20.9°C ± 0.5°C	20.9°C ± 0.5°C	

MP.	STANDARD		INSTRUMENT					
	INPUT UP mbar	INPUT DOWN mbar	READING UP mbar	READING DOWN mbar	ERROR UP % R	ERROR DOWN % R	LIMIT UP % R	LIMIT DOWN % R
1	0.0000	0.0000	0.00	0.01	0.00		± 0.10	± 0.10
2	29.9701	29.9701	29.99	29.99	0.07	0.07	± 0.10	± 0.10
3	49.9684	49.9684	50.01	50.02	0.08	0.10	± 0.10	± 0.10
4	99.9633	99.9633	99.98	99.98	0.02	0.02	± 0.10	± 0.10
5	199.961	199.961	199.97	199.98	0.00	0.01	± 0.10	± 0.10
6	299.958	299.958	299.97	299.97	0.00	0.00	± 0.10	± 0.10
7	449.957	449.957	449.96	449.97	0.00	0.00	± 0.10	± 0.10
8	599.949	599.949	599.95	599.94	0.00	0.00	± 0.10	± 0.10
9	799.939	799.939	799.93	799.93	0.00	0.00	± 0.10	± 0.10
10	999.936	999.936	999.92	999.92	0.00	0.00	± 0.10	± 0.10
11	1249.94	1249.94	1249.91	1249.94	0.00	0.00	± 0.10	± 0.10
12	1499.93	1499.93	1499.89	1499.89	0.00	0.00	± 0.10	± 0.10
13	1999.91	1999.91	1999.87	1999.87	0.00	0.00	± 0.10	± 0.10
14	2500.05		2500.09		0.00		± 0.10	

Before calibration the transmitter has been set to zero.

The transmitter is mounted in a frame and the whole is calibrated in the horizontal position.

The read-out of the transmitter was done using the software Studio302 / ThermoLyse on a laptop of the customer.

Customer ID. no. : DP 2805

Customer ref. : 9.099.74103420.400

Our ref. : 61500533

Customer : DNV GL

Calibrated by

TCL Technician

C. Martinus

Cal. date : 9 April 2015

Approved by

Head of TCL

S. Bandjmath-Misier

Date : 9 April 2015

Berkel en Rodenrijs



T.C.L. Tradinco Calibration Laboratory

Page 1 of 2



CALIBRATION CERTIFICATE

Certificate number : 21500528

Applicant	DNV GL Utrechtseweg 310 6812 AR Amhem
Instrument	Pressure transmitter
Manufacturer	ABB
Type	266MST
Serial number	3K650000006806
Service number	18224
Customer identification number	DP 2805
Calibration method	This calibration is carried out with: Deadweight tester type : T1100/1 S/N : 4275/86 Cal. Due : 11 July 2018 Deadweight tester type : T2300/1 S/N : 6612/91 Cal. Due : 18 July 2018

During calibration a testpressure is put under a calibrated measuring piston which is loaded with calibrated weights

Environmental conditions	Temperature: 20.0°C ± 2°C Humidity: 55 %rh ± 25 %rh
Date / period of calibration	9 April 2015
Results	See following page(s)
Uncertainty	± 0.012 % of reading with use of correction figures in the range of 20 - 100 % of full scale The reported uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %. The standard uncertainty has been determined in accordance with document EA-4/02.
Traceability	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	9 April 2015
Name	S. Baidjnath-Misier Head of TCL

Industrieweg 74
2651 BD Berkel en Rodenrijs
The Netherlands
Tel. : +31(0)105112911
Telefax : +31 (0)105115114

All quotations and deliveries are subject to the general delivery- and payment conditions of the "Coöperatieve Vereniging Het Instrument U.A." filed with the Registry of the District Court in Utrecht on 13-01-1993 and with the Chamber of Commerce and Industry in Amersfoort

Reproduction of the complete certificate is allowed.
Parts of the certificate may only be reproduced after written permission by T.C.L.

This certificate is issued provided that neither T.C.L. nor the RvA assumes any liability



T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 2 of 2

Certificate number : 21500528

	Standard 1	Standard 2	Instrument
Service number			18224
Type	T1100/1	T2300/1	266MST
Manufacturer	Tradinco Instruments	Tradinco Instruments	ABB
Description	Deadweight tester	Deadweight tester	Pressure transmitter
Serial number	4275/86	6612/91	3K65000006806
Range	(30 ÷ 2000) mbar	(0.2 ÷ 35) bar	(0 ÷ 2500) mbar
Medium	Air	Air	Air
Accuracy	±0.01 % R	±0.01 % R	±0.1 % R
Temperature	20.9°C ± 0.5°C	20.9°C ± 0.5°C	

MP.	STANDARD		INSTRUMENT					
	INPUT UP mbar	INPUT DOWN mbar	READING UP mbar	READING DOWN mbar	ERROR UP % R	ERROR DOWN % R	LIMIT UP % R	LIMIT DOWN % R
1	0.000	0.000	0.00	0.01	0.00		± 0.10	± 0.10
2	29.9701	29.9701	29.99	29.99	0.07	0.07	± 0.10	± 0.10
3	49.9684	49.9684	50.01	50.02	0.08	0.10	± 0.10	± 0.10
4	99.9633	99.9633	99.98	99.98	0.02	0.02	± 0.10	± 0.10
5	199.961	199.961	199.97	199.98	0.00	0.01	± 0.10	± 0.10
6	299.958	299.958	299.97	299.97	0.00	0.00	± 0.10	± 0.10
7	449.957	449.957	449.96	449.97	0.00	0.00	± 0.10	± 0.10
8	599.949	599.949	599.95	599.94	0.00	0.00	± 0.10	± 0.10
9	799.939	799.939	799.93	799.93	0.00	0.00	± 0.10	± 0.10
10	999.936	999.936	999.92	999.92	0.00	0.00	± 0.10	± 0.10
11	1249.94	1249.94	1249.91	1249.94	0.00	0.00	± 0.10	± 0.10
12	1499.93	1499.93	1499.89	1499.89	0.00	0.00	± 0.10	± 0.10
13	1999.91	1999.91	1999.87	1999.87	0.00	0.00	± 0.10	± 0.10
14	2500.05		2500.09		0.00		± 0.10	

Before calibration the transmitter has been set to zero.

The transmitter is mounted in a frame and the whole is calibrated in the horizontal position.

The read-out of the transmitter was done using the software Studio302 / ThermoLyse on a laptop of the customer.

Customer ID. no. : DP 2805

Customer ref. : 9.099.74103420.400

Our ref. : 61500533

Customer : DNV GL

Calibrated by
TCL Technician

C. Martinus
Cal. date : 9 April 2015

Approved by
Head of TCL
S. Badjina-Misier
Date : 9 April 2015
Berkel en Rodenrijs



T.C.L. Tradinco Calibration Laboratory

Page 1 of 2



CALIBRATION CERTIFICATE

Certificate number : 21500563

Applicant	DNV GL Utrechtseweg 310 6812 AR Amhem
Instrument	Pressure transmitter
Manufacturer	ABB
Type	266MST
Serial number	3K650000006807
Service number	18225
Customer identification number	DP 2806
Calibration method	This calibration is carried out with: Deadweight tester type : T1100/1 S/N : 4275/86 Cal. Due : 11 July 2018 Deadweight tester type : T2300/1 S/N : 6612/91 Cal. Due : 18 July 2018

During calibration a testpressure is put under a calibrated measuring piston which is loaded with calibrated weights

Environmental conditions	Temperature: 20.0°C ± 2°C
	Humidity: 55 %rh ± 25 %rh
Date / period of calibration	14 April 2015

Results	See following page(s)
Uncertainty	± 0.012 % of reading with use of correction figures in the range of 20 - 100 % of full scale

The reported uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %.
The standard uncertainty has been determined in accordance with document EA-4/02.

Calculated by software revision: 2.7.6.6/2.33

Traceability	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
--------------	--

Date	14 April 2015
------	---------------

Name	S. Baidjnath-Misier
	Head of TCL

Industrieweg 74
2651 BD Berkel en Rodenrijs
The Netherlands
Tel. : +31(0)105112911
Telefax : +31 (0)105115114

All quotations and deliveries are subject to the general delivery- and payment conditions of the "Coöperatieve Vereniging Het Instrument U.A." filed with the Registry of the District Court in Utrecht on 13-01-1993 and with the Chamber of Commerce and Industry in Amersfoort

Reproduction of the complete certificate is allowed.
Parts of the certificate may only be reproduced after written permission by T.C.L.

This certificate is issued provided that neither T.C.L. nor the RvA assumes any liability



T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 2 of 2

Certificate number : 21500563

	Standard 1	Standard 2	Instrument
Service number			18225
Type	T1100/1	T2300/1	266MST
Manufacturer	Tradinco Instruments	Tradinco Instruments	ABB
Description	Deadweight tester	Deadweight tester	Pressure transmitter
Serial number	4275/86	6612/91	3K65000006807
Range	(30 ± 2000) mbar	(0.2 ± 35) bar	(0 ± 2500) mbar
Medium	Air	Air	Air
Accuracy	±0.01 % R	±0.01 % R	±0.1 % R
Temperature	20.0°C ± 0.5°C	20.0°C ± 0.5°C	

MP.	STANDARD		INSTRUMENT					
	INPUT UP mbar	INPUT DOWN mbar	READING UP mbar	READING DOWN mbar	ERROR UP % R	ERROR DOWN % R	LIMIT UP % R	LIMIT DOWN % R
1	0.0000	0.0000	0.00	0.01			± 0.10	± 0.10
2	29.9708	29.9708	29.97	29.97	0.00	0.00	± 0.10	± 0.10
3	49.9697	49.9697	49.98	49.97	0.02	0.00	± 0.10	± 0.10
4	99.9657	99.9657	99.98	99.98	0.01	0.01	± 0.10	± 0.10
5	199.965	199.965	199.98	199.98	0.01	0.01	± 0.10	± 0.10
6	299.965	299.965	299.99	299.99	0.01	0.01	± 0.10	± 0.10
7	449.967	449.967	450.02	449.98	0.01	0.00	± 0.10	± 0.10
8	599.963	599.963	600.02	600.03	0.01	0.01	± 0.10	± 0.10
9	799.959	799.959	800.05	800.06	0.01	0.01	± 0.10	± 0.10
10	999.960	999.960	1000.09	1000.10	0.01	0.01	± 0.10	± 0.10
11	1249.97	1249.97	1250.12	1250.13	0.01	0.01	± 0.10	± 0.10
12	1499.97	1499.97	1500.14	1500.12	0.01	0.01	± 0.10	± 0.10
13	1999.96	1999.96	2000.20	2000.20	0.01	0.01	± 0.10	± 0.10
14	2500.09		2500.06		0.00		± 0.10	

Before calibration the transmitter has been set to zero.

The transmitter is mounted in a frame and the whole is calibrated in the horizontal position.

The read-out of the transmitter was done using the software Studio302 / ThermoLyse on a laptop of the customer.

Customer ID. no. : DP 2806

Customer ref. : 9.099.74103420.400

Our ref. : 61500533

Customer : DNV GL

Calibrated by

TCL Technician

C. Martinus

Cal. date : 14 April 2015

Approved by

Head of TCL

S. Badjina-Misier

Date : 14 April 2015

Berkel en Rodenrijs



T.C.L. Tradinco Calibration Laboratory

Page 1 of 2



CALIBRATION CERTIFICATE

Certificate number : 21500272R1

Applicant	DNV GL Utrechtseweg 310 6812 AR Arnhem
Instrument	Pressure transmitter
Manufacturer	ABB
Type	266GST
Serial number	3K650000006847
Service number	18053
Customer identification number	P 2352
Calibration method	This calibration is carried out with : Deadweight tester type : M2200/1 S/N : 4792/87 Cal. Due : 24 April 2019

During calibration a testpressure is put under a calibrated measuring piston which is loaded with calibrated weights

The instrument is calibrated in combination with oil/gas separator type 8335.

Environmental conditions	Temperature: 20.0°C ± 2°C Humidity: 55 %rh ± 25 %rh
Date / period of calibration	25 February 2015

Results	See following page(s)
Uncertainty	± 0.017 % of reading with use of correction figures in the range of 20 - 100 % of full scale

The reported uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %.
The standard uncertainty has been determined in accordance with document EA-4/02.

Calculated by software revision: 2.7.6.6/2.35

Traceability	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	25 February 2015

Name
S. Baidjnath-Misier
Head of TCL

Industrieweg 74
2651 BD Berkel en Rodenrijs
The Netherlands
Tel. : +31(0)105112911
Telefax : +31 (0)105115114

All our offers and agreements are governed by the FHI General Conditions of Delivery 2014 issued by FHI, Federation of Technology Branches, filed at the Chamber of Commerce of Gooi-, Eem- and Flevoland under the number 40507574. These general conditions are available for free at www.tradinco.com

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced after written permission by T.C.L.

This certificate is issued provided that neither T.C.L. nor the RvA assumes any liability



The Calibration Company

T.C.L. Tradinco Calibration Laboratory

Page 2 of 2



CALIBRATION CERTIFICATE

Certificate number : 21500272R1

	Standard	Instrument
Service number		18053
Type	M2200/1	266GST
Manufacturer	Tradinco Instruments	ABB
Description	Deadweight tester	Pressure transmitter
Serial number	4792/87	3K650000006847
Range	(2.7 ÷ 700) bar	(0 ÷ 100) bar
Medium	Oil	Air
Accuracy	±0.012 % R	±0.1 % R
Temperature	20.2°C ± 0.5°C	

MP.	STANDARD		INSTRUMENT					
	INPUT UP bar	INPUT DOWN bar	READING UP bar	READING DOWN bar	ERROR UP % R	ERROR DOWN % R	LIMIT UP % R	LIMIT DOWN % R
1	0.00000	0.00000	0.000	0.000	0.00	0.00	± 0.10	± 0.10
2	10.0001	10.0001	10.003	10.006	0.03	0.06	± 0.10	± 0.10
3	20.0049	20.0049	20.008	20.012	0.02	0.04	± 0.10	± 0.10
4	30.0083	30.0083	30.012	30.016	0.01	0.03	± 0.10	± 0.10
5	39.9853	39.9853	39.992	39.996	0.02	0.03	± 0.10	± 0.10
6	49.9800	49.9800	49.983	49.991	0.01	0.02	± 0.10	± 0.10
7	59.9865	59.9865	59.993	59.996	0.01	0.02	± 0.10	± 0.10
8	69.9814	69.9814	69.981	69.984	0.00	0.00	± 0.10	± 0.10
9	79.9779	79.9779	79.973	79.975	-0.01	0.00	± 0.10	± 0.10
10	89.9744	89.9744	89.977	89.978	0.00	0.00	± 0.10	± 0.10
11	99.9690		99.962		-0.01		± 0.10	

Before calibration the transmitter has been set to zero.

The transmitter is mounted in a frame and the whole is calibrated in the horizontal position.

The read-out of the transmitter was done using the software Studio302 / ThermoLyse on a laptop of the customer.

Customer ID. no. : P 2352

Customer ref. : 1.099.74103420.400

Our ref. : 61402416

Customer : DNV GL

Calibrated by
TCL Technician

C. Martinus
Cal. date : 25 February 2015

Approved by
Head of TCL
S. Bandjmath-Misier
Date : 25 February 2015
Berkel en Rodenrijs



The Calibration Company

T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 1 of 2

Certificate number : 21500548

Applicant	DNV GL Utrechtseweg 310 6812 AR Amhem
Instrument	Pressure transmitter
Manufacturer	ABB
Type	266GST
Serial number	3K650000006848
Service number	18209
Customer identification number	P 2353
Calibration method	This calibration is carried out with : Deadweight tester type : M2000/1 S/N : 7518/93 Cal. Due : 3 June 2019

During calibration a testpressure is put under a calibrated measuring piston which is loaded with calibrated weights

The instrument is calibrated in combination with oil/gas separator type 8335.

Environmental conditions	Temperature: 20.0°C ± 2°C Humidity: 55 %rh ± 25 %rh
Date / period of calibration	13 April 2015

Results	See following page(s)
Uncertainty	± 0.015 % of reading with use of correction figures in the range of 20 - 100 % of full scale

The reported uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %.
The standard uncertainty has been determined in accordance with document EA-4/02.

Calculated by software revision: 2.7.6.6/2.33

Traceability	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	13 April 2015

Name
S. Baidjnath-Misier
Head of TCL

Industrieweg 74
2651 BD Berkel en Rodenrijs
The Netherlands
Tel. : +31(0)105112911
Telefax : +31 (0)105115114

All quotations and deliveries are subject to the general delivery- and payment conditions of the "Coöperatieve Vereniging Het Instrument U.A." filed with the Registry of the District Court in Utrecht on 13-01-1993 and with the Chamber of Commerce and Industry in Amersfoort

Reproduction of the complete certificate is allowed.
Parts of the certificate may only be reproduced after written permission by T.C.L.

This certificate is issued provided that neither T.C.L. nor the RvA assumes any liability



The Calibration Company

T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 2 of 2

Certificate number : 21500548

	Standard	Instrument
Service number		18209
Type	M2000/1	266GST
Manufacturer	Tradinco Instruments	ABB
Description	Deadweight tester	Pressure transmitter
Serial number	7518/93	3K65000006848
Range	(2.6 ± 350) bar	(0 ± 100) bar
Medium	Oil	Air
Accuracy	±0.011 % R	±0.1 % R
Temperature	19.6°C ± 0.5°C	

MP.	STANDARD		INSTRUMENT					
	INPUT UP bar	INPUT DOWN bar	READING UP bar	READING DOWN bar	ERROR UP % R	ERROR DOWN % R	LIMIT UP % R	LIMIT DOWN % R
1	0.00000	0.00000	0.000	0.002	0.00		± 0.10	± 0.10
2	9.99608	9.99608	9.998	10.001	0.02	0.05	± 0.10	± 0.10
3	19.9969	19.9969	20.001	20.003	0.02	0.03	± 0.10	± 0.10
4	29.9975	29.9975	30.002	30.004	0.01	0.02	± 0.10	± 0.10
5	39.9899	39.9899	39.993	39.997	0.01	0.02	± 0.10	± 0.10
6	49.9881	49.9881	49.990	49.993	0.00	0.01	± 0.10	± 0.10
7	59.9865	59.9865	59.987	59.990	0.00	0.01	± 0.10	± 0.10
8	69.9845	69.9845	69.986	69.990	0.00	0.01	± 0.10	± 0.10
9	79.9828	79.9828	79.985	79.982	0.00	0.00	± 0.10	± 0.10
10	89.9807	89.9807	89.980	89.978	0.00	0.00	± 0.10	± 0.10
11	99.9784		99.978		0.00		± 0.10	

Before calibration the transmitter has been set to zero.

The transmitter is mounted in a frame and the whole is calibrated in the horizontal position.

The read-out of the transmitter was done using the software Studio302 / ThermoLyse on a laptop of the customer.

Customer ID. no. : P 2353

Customer ref. : 9.099.74103420.400

Our ref. : 61500533

Customer : DNV GL

Calibrated by

TCL Technician

C. Martinus

Cal. date : 13 April 2015

Approved by

Head of TCL

S. Bandjimat-Misier

Date : 13 April 2015

Berkel en Rodenrijs



The Calibration Company

T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 1 of 2

Certificate number : 21500560

Applicant	DNV GL Utrechtseweg 310 6812 AR Amhem
Instrument	Pressure transmitter
Manufacturer	ABB
Type	266GST
Serial number	3K650000006851
Service number	18207
Customer identification number	P 2356
Calibration method	This calibration is carried out with : Deadweight tester type : M2000/1 S/N : 7518/93 Cal. Due : 3 June 2019

During calibration a testpressure is put under a calibrated measuring piston which is loaded with calibrated weights

The instrument is calibrated in combination with oil/gas separator type 8335.

Environmental conditions	Temperature: 20.0°C ± 2°C Humidity: 55 %rh ± 25 %rh
Date / period of calibration	14 April 2015

Results	See following page(s)
Uncertainty	± 0.013 % of reading with use of correction figures in the range of 20 - 100 % of full scale

The reported uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %.
The standard uncertainty has been determined in accordance with document EA-4/02.

Calculated by software revision: 2.7.6.6/2.33

Traceability	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	14 April 2015

Name
S. Baidjnath-Misier
Head of TCL

Industrieweg 74
2651 BD Berkel en Rodenrijs
The Netherlands
Tel. : +31(0)105112911
Telefax : +31 (0)105115114

All quotations and deliveries are subject to the general delivery- and payment conditions of the "Coöperatieve Vereniging Het Instrument U.A." filed with the Registry of the District Court in Utrecht on 13-01-1993 and with the Chamber of Commerce and Industry in Amersfoort

Reproduction of the complete certificate is allowed.
Parts of the certificate may only be reproduced after written permission by T.C.L.

This certificate is issued provided that neither T.C.L. nor the RvA assumes any liability



T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 2 of 2

Certificate number : 21500560

	Standard	Instrument
Service number		18207
Type	M2000/1	266GST
Manufacturer	Tradinco Instruments	ABB
Description	Deadweight tester	Pressure transmitter
Serial number	7518/93	3K650000006851
Range	(2.6 ± 350) bar	(0 ± 100) bar
Medium	Oil	Air
Accuracy	±0.011 % R	±0.1 % R
Temperature	20.4°C ± 0.5°C	

MP.	STANDARD		INSTRUMENT					
	INPUT UP bar	INPUT DOWN bar	READING UP bar	READING DOWN bar	ERROR UP % R	ERROR DOWN % R	LIMIT UP % R	LIMIT DOWN % R
1	0.00000	0.00000	0.000	0.002	0.00		± 0.10	± 0.10
2	9.99595	9.99595	9.999	10.001	0.03	0.05	± 0.10	± 0.10
3	19.9966	19.9966	20.002	20.004	0.03	0.04	± 0.10	± 0.10
4	29.9971	29.9971	30.003	30.001	0.02	0.01	± 0.10	± 0.10
5	39.9894	39.9894	39.998	39.998	0.02	0.02	± 0.10	± 0.10
6	49.9875	49.9875	49.993	49.995	0.01	0.02	± 0.10	± 0.10
7	59.9857	59.9857	59.988	59.992	0.00	0.01	± 0.10	± 0.10
8	69.9836	69.9836	69.987	69.991	0.00	0.01	± 0.10	± 0.10
9	79.9817	79.9817	79.986	79.987	0.01	0.01	± 0.10	± 0.10
10	89.9795	89.9795	89.983	89.981	0.00	0.00	± 0.10	± 0.10
11	99.9771		99.978		0.00		± 0.10	

Before calibration the transmitter has been set to zero.

The transmitter is mounted in a frame and the whole is calibrated in the horizontal position.

The read-out of the transmitter was done using the software Studio302 / ThermoLyse on a laptop of the customer.

Customer ID. no. : P 2356

Customer ref. : 9.099.74103420.400

Our ref. : 61500533

Customer : DNV GL

Calibrated by
TCL Technician

C. Martinus
Cal. date : 14 April 2015

Approved by
Head of TCL
S. Bandjmath-Misier
Date : 14 April 2015
Berkel en Rodenrijs



The Calibration Company

T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 1 of 2

Certificate number : 21500459

Applicant	DNV GL Utrechtseweg 310 6812 AR Amhem
Instrument	Pressure transmitter
Manufacturer	ABB
Type	266GST
Serial number	3K650000006852
Service number	18052
Customer identification number	P 2357
Calibration method	This calibration is carried out with : Deadweight tester type : M2000/1 S/N : 7518/93 Cal. Due : 3 June 2019

During calibration a testpressure is put under a calibrated measuring piston which is loaded with calibrated weights

The instrument is calibrated in combination with oil/gas separator type 8335.

Environmental conditions	Temperature: 20.0°C ± 2°C Humidity: 55 %rh ± 25 %rh
Date / period of calibration	26 March 2015

Results	See following page(s)
Uncertainty	± 0.015 % of reading with use of correction figures in the range of 20 - 100 % of full scale

The reported uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %.
The standard uncertainty has been determined in accordance with document EA-4/02.

Calculated by software revision: 2.7.6.6/2.33

Traceability	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	26 March 2015

Name
S. Baidjnath-Misier
Head of TCL

Industrieweg 74
2651 BD Berkel en Rodenrijs
The Netherlands
Tel. : +31(0)105112911
Telefax : +31 (0)105115114

All quotations and deliveries are subject to the general delivery- and payment conditions of the "Coöperatieve Vereniging Het Instrument U.A." filed with the Registry of the District Court in Utrecht on 13-01-1993 and with the Chamber of Commerce and Industry in Amersfoort

Reproduction of the complete certificate is allowed.
Parts of the certificate may only be reproduced after written permission by T.C.L.

This certificate is issued provided that neither T.C.L. nor the RvA assumes any liability



T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 2 of 2

Certificate number : 21500459

	Standard	Instrument
Service number		18052
Type	M2000/1	266GST
Manufacturer	Tradinco Instruments	ABB
Description	Deadweight tester	Pressure transmitter
Serial number	7518/93	3K650000006852
Range	(2.6 ± 350) bar	(0 ± 100) bar
Medium	Oil	Air
Accuracy	±0.011 % R	±0.1 % R
Temperature	20.6°C ± 0.5°C	

MP.	STANDARD		INSTRUMENT					
	INPUT UP bar	INPUT DOWN bar	READING UP bar	READING DOWN bar	ERROR UP % R	ERROR DOWN % R	LIMIT UP % R	LIMIT DOWN % R
1	0.00000	0.00000	-0.011	-0.009			± 0.10	± 0.10
2	9.99591	9.99591	9.986	9.989	-0.10	-0.07	± 0.10	± 0.10
3	19.9965	19.9965	19.988	19.991	-0.04	-0.03	± 0.10	± 0.10
4	29.9970	29.9970	29.989	29.992	-0.03	-0.02	± 0.10	± 0.10
5	39.9893	39.9893	39.980	39.984	-0.02	-0.01	± 0.10	± 0.10
6	49.9873	49.9873	49.978	49.982	-0.02	-0.01	± 0.10	± 0.10
7	59.9855	59.9855	59.976	59.980	-0.02	-0.01	± 0.10	± 0.10
8	69.9834	69.9834	69.973	69.977	-0.01	-0.01	± 0.10	± 0.10
9	79.9815	79.9815	79.970	79.973	-0.01	-0.01	± 0.10	± 0.10
10	89.9792	89.9792	89.970	89.970	-0.01	-0.01	± 0.10	± 0.10
11	99.9767		99.964		-0.01		± 0.10	

Before calibration the transmitter has not been set to zero.

The transmitter is mounted in a frame and the whole is calibrated in the horizontal position.

The read-out of the transmitter was done using the software Studio302 / ThermoLyse on a laptop of the customer.

Customer ID. no. : P 2357

Customer ref. : -

Our ref. : 61500730

Customer : DNV GL

Calibrated by
TCL Technician

P. Verhoef

Cal. date : 26 March 2015

Approved by

Head of TCL

S. Bandjmath-Misier

Date : 26 March 2015

Berkel en Rodenrijs



The Calibration Company

T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 1 of 2

Certificate number : 21500532

Applicant	DNV GL Utrechtseweg 310 6812 AR Amhem
Instrument	Pressure transmitter
Manufacturer	ABB
Type	266GST
Serial number	3K650000006853
Service number	18201
Customer identification number	P 2358
Calibration method	This calibration is carried out with : Deadweight tester type : M2000/1 S/N : 7518/93 Cal. Due : 3 June 2019

During calibration a testpressure is put under a calibrated measuring piston which is loaded with calibrated weights

The instrument is calibrated in combination with oil/gas separator type 8335.

Environmental conditions	Temperature: 20.0°C ± 2°C Humidity: 55 %rh ± 25 %rh
Date / period of calibration	9 April 2015

Results	See following page(s)
Uncertainty	± 0.015 % of reading with use of correction figures in the range of 20 - 100 % of full scale

The reported uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %.
The standard uncertainty has been determined in accordance with document EA-4/02.

Calculated by software revision: 2.7.6.6/2.33

Traceability	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	9 April 2015

Name
S. Baidjnath-Misier
Head of TCL

Industrieweg 74
2651 BD Berkel en Rodenrijs
The Netherlands
Tel. : +31(0)105112911
Telefax : +31 (0)105115114

All quotations and deliveries are subject to the general delivery- and payment conditions of the "Coöperatieve Vereniging Het Instrument U.A." filed with the Registry of the District Court in Utrecht on 13-01-1993 and with the Chamber of Commerce and Industry in Amersfoort

Reproduction of the complete certificate is allowed.
Parts of the certificate may only be reproduced after written permission by T.C.L.

This certificate is issued provided that neither T.C.L. nor the RvA assumes any liability



T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 2 of 2

Certificate number : 21500532

	Standard	Instrument
Service number		18201
Type	M2000/1	266GST
Manufacturer	Tradinco Instruments	ABB
Description	Deadweight tester	Pressure transmitter
Serial number	7518/93	3K650000006853
Range	(2.6 ± 350) bar	(0 ± 100) bar
Medium	Oil	Air
Accuracy	±0.011 % R	±0.1 % R
Temperature	20.5°C ± 0.5°C	

MP.	STANDARD		INSTRUMENT					
	INPUT UP bar	INPUT DOWN bar	READING UP bar	READING DOWN bar	ERROR UP % R	ERROR DOWN % R	LIMIT UP % R	LIMIT DOWN % R
1	0.00000	0.00000	-0.005	0.004			± 0.10	± 0.10
2	9.99593	9.99593	9.992	9.994	-0.04	-0.02	± 0.10	± 0.10
3	19.9966	19.9966	19.995	19.996	-0.01	0.00	± 0.10	± 0.10
4	29.9971	29.9971	29.996	29.999	0.00	0.01	± 0.10	± 0.10
5	39.9894	39.9894	39.985	39.993	-0.01	0.01	± 0.10	± 0.10
6	49.9874	49.9874	49.990	49.989	0.01	0.00	± 0.10	± 0.10
7	59.9856	59.9856	59.984	59.985	0.00	0.00	± 0.10	± 0.10
8	69.9835	69.9835	69.981	69.990	0.00	0.01	± 0.10	± 0.10
9	79.9816	79.9816	79.985	79.982	0.00	0.00	± 0.10	± 0.10
10	89.9793	89.9793	89.986	89.987	0.01	0.01	± 0.10	± 0.10
11	99.9769		99.981		0.00		± 0.10	

Before calibration the transmitter has been set to zero.

The transmitter is mounted in a frame and the whole is calibrated in the horizontal position.

The read-out of the transmitter was done using the software Studio302 / ThermoLyse on a laptop of the customer.

Customer ID. no. : P 2358

Customer ref. : 9.099.74103420.400

Our ref. : 61500533

Customer : DNV GL

Calibrated by
TCL Technician

C. Martinus
Cal. date : 9 April 2015

Approved by
Head of TCL
S. Bandjmath-Misier
Date : 9 April 2015
Berkel en Rodenrijs



The Calibration Company

T.C.L. Tradinco Calibration Laboratory

Page 1 of 2



CALIBRATION CERTIFICATE

Certificate number : 21500547

Applicant	DNV GL Utrechtseweg 310 6812 AR Amhem
Instrument	Pressure transmitter
Manufacturer	ABB
Type	266GST
Serial number	3K650000006855
Service number	18210
Customer identification number	P 2360
Calibration method	This calibration is carried out with: Deadweight tester type : M2000/1 S/N : 7518/93 Cal. Due : 3 June 2019

During calibration a testpressure is put under a calibrated measuring piston which is loaded with calibrated weights

The instrument is calibrated in combination with oil/gas separator type 8335.

Environmental conditions	Temperature: 20.0°C ± 2°C Humidity: 55 %rh ± 25 %rh
Date / period of calibration	13 April 2015

Results	See following page(s)
Uncertainty	± 0.015 % of reading with use of correction figures in the range of 20 - 100 % of full scale

The reported uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %.
The standard uncertainty has been determined in accordance with document EA-4/02.

Calculated by software revision: 2.7.6.6/2.33

Traceability	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	13 April 2015
Name	S. Baidjnath-Misier Head of TCL

Industrieweg 74
2651 BD Berkel en Rodenrijs
The Netherlands
Tel. : +31(0)105112911
Telefax : +31 (0)105115114

All quotations and deliveries are subject to the general delivery- and payment conditions of the "Coöperatieve Vereniging Het Instrument U.A." filed with the Registry of the District Court in Utrecht on 13-01-1993 and with the Chamber of Commerce and Industry in Amersfoort

Reproduction of the complete certificate is allowed.
Parts of the certificate may only be reproduced after written permission by T.C.L.

This certificate is issued provided that neither T.C.L. nor the RvA assumes any liability



T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 2 of 2

Certificate number : 21500547

	Standard	Instrument
Service number		18210
Type	M2000/1	266GST
Manufacturer	Tradinco Instruments	ABB
Description	Deadweight tester	Pressure transmitter
Serial number	7518/93	3K65000006855
Range	(2,6 ÷ 350) bar	(0 ÷ 100) bar
Medium	Oil	Air
Accuracy	±0.011 % R	±0.1 % R
Temperature	19.6°C ± 0.5°C	

MP.	STANDARD		INSTRUMENT					
	INPUT UP bar	INPUT DOWN bar	READING UP bar	READING DOWN bar	ERROR UP % R	ERROR DOWN % R	LIMIT UP % R	LIMIT DOWN % R
1	0.00000	0.00000	0.000	0.002	0.00		± 0.10	± 0.10
2	9.99608	9.99608	9.997	10.000	0.01	0.04	± 0.10	± 0.10
3	19.9969	19.9969	20.002	20.004	0.03	0.04	± 0.10	± 0.10
4	29.9975	29.9975	30.003	30.006	0.02	0.03	± 0.10	± 0.10
5	39.9899	39.9899	39.993	39.998	0.01	0.02	± 0.10	± 0.10
6	49.9881	49.9881	49.989	49.995	0.00	0.01	± 0.10	± 0.10
7	59.9865	59.9865	59.987	59.990	0.00	0.01	± 0.10	± 0.10
8	69.9845	69.9845	69.984	69.989	0.00	0.01	± 0.10	± 0.10
9	79.9828	79.9828	79.982	79.981	0.00	0.00	± 0.10	± 0.10
10	89.9807	89.9807	89.981	89.979	0.00	0.00	± 0.10	± 0.10
11	99.9784		99.978		0.00		± 0.10	

Before calibration the transmitter has been set to zero.

The transmitter is mounted in a frame and the whole is calibrated in the horizontal position.

The read-out of the transmitter was done using the software Studio302 / ThermoLyse on a laptop of the customer.

Customer ID. no. : P 2360

Customer ref. : 9.099.74103420.400

Our ref. : 61500533

Customer : DNV GL

Calibrated by
TCL Technician

C. Martinus
Cal. date : 13 April 2015

Approved by

Head of TCL

S. Badjinaal-Misier

Date : 13 April 2015

Berkel en Rodenrijs



The Calibration Company

T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 1 of 2

Certificate number : 21500549

Applicant	DNV GL Utrechtseweg 310 6812 AR Amhem
Instrument	Pressure transmitter
Manufacturer	ABB
Type	266GST
Serial number	3K650000006856
Service number	18200
Customer identification number	P 2361
Calibration method	This calibration is carried out with : Deadweight tester type : M2000/1 S/N : 7518/93 Cal. Due : 3 June 2019

During calibration a testpressure is put under a calibrated measuring piston which is loaded with calibrated weights

The instrument is calibrated in combination with oil/gas separator type 8335.

Environmental conditions	Temperature: 20.0°C ± 2°C Humidity: 55 %rh ± 25 %rh
Date / period of calibration	13 April 2015

Results	See following page(s)
Uncertainty	± 0.020 % of reading with use of correction figures in the range of 20 - 100 % of full scale

The reported uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %.
The standard uncertainty has been determined in accordance with document EA-4/02.

Calculated by software revision: 2.7.6.6/2.33

Traceability	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	13 April 2015

Name
S. Baidjnath-Misier
Head of TCL

Industrieweg 74
2651 BD Berkel en Rodenrijs
The Netherlands
Tel. : +31(0)105112911
Telefax : +31 (0)105115114

All quotations and deliveries are subject to the general delivery- and payment conditions of the "Coöperatieve Vereniging Het Instrument U.A." filed with the Registry of the District Court in Utrecht on 13-01-1993 and with the Chamber of Commerce and Industry in Amersfoort

Reproduction of the complete certificate is allowed.
Parts of the certificate may only be reproduced after written permission by T.C.L.

This certificate is issued provided that neither T.C.L. nor the RvA assumes any liability



T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 2 of 2

Certificate number : 21500549

	Standard	Instrument
Service number		18200
Type	M2000/1	266GST
Manufacturer	Tradinco Instruments	ABB
Description	Deadweight tester	Pressure transmitter
Serial number	7518/93	3K650000006856
Range	(2.6 ÷ 350) bar	(0 ÷ 100) bar
Medium	Oil	Air
Accuracy	±0.011 % R	±0.1 % R
Temperature	20.3°C ± 0.5°C	

MP.	STANDARD		INSTRUMENT					
	INPUT UP bar	INPUT DOWN bar	READING UP bar	READING DOWN bar	ERROR UP % R	ERROR DOWN % R	LIMIT UP % R	LIMIT DOWN % R
1	0.00000	0.00000	0.000	0.001	0.00		± 0.10	± 0.10
2	9.99596	9.99596	9.998	10.002	0.02	0.06	± 0.10	± 0.10
3	19.9966	19.9966	20.001	20.004	0.02	0.04	± 0.10	± 0.10
4	29.9972	29.9972	30.003	30.005	0.02	0.03	± 0.10	± 0.10
5	39.9895	39.9895	39.994	39.997	0.01	0.02	± 0.10	± 0.10
6	49.9876	49.9876	49.993	49.996	0.01	0.02	± 0.10	± 0.10
7	59.9858	59.9858	59.989	59.994	0.01	0.01	± 0.10	± 0.10
8	69.9837	69.9837	69.989	69.992	0.01	0.01	± 0.10	± 0.10
9	79.9819	79.9819	79.987	79.994	0.01	0.02	± 0.10	± 0.10
10	89.9796	89.9796	89.982	89.990	0.00	0.01	± 0.10	± 0.10
11	99.9772		99.978		0.00		± 0.10	

Before calibration the transmitter has been set to zero.

The transmitter is mounted in a frame and the whole is calibrated in the horizontal position.

The read-out of the transmitter was done using the software Studio302 / ThermoLyse on a laptop of the customer.



Customer ID. no. : P 2361

Customer ref. : 9.099.74103420.400

Our ref. : 61500533

Customer : DNV GL

Calibrated by
TCL Technician

C. Martinus
Cal. date : 13 April 2015

Approved by

Head of TCL

S. Baidjadjah-Misier

Date : 13 April 2015

Berkel en Rodenrijs



The Calibration Company

T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 1 of 2

Certificate number : 21500461

Applicant	DNV GL Utrechtseweg 310 6812 AR Amhem
Instrument	Pressure transmitter
Manufacturer	ABB
Type	266GST
Serial number	3K650000006880
Service number	18060
Customer identification number	P 2391
Calibration method	This calibration is carried out with : Deadweight tester type : M2200/1 S/N : 4792/87 Cal. Due : 24 April 2019

During calibration a testpressure is put under a calibrated measuring piston which is loaded with calibrated weights

The instrument is calibrated in combination with oil/gas separator type 8335.

Environmental conditions	Temperature: 20.0°C ± 2°C Humidity: 55 %rh ± 25 %rh
Date / period of calibration	26 March 2015

Results	See following page(s)
Uncertainty	± 0.019 % of reading with use of correction figures in the range of 20 - 100 % of full scale

The reported uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %.
The standard uncertainty has been determined in accordance with document EA-4/02.

Calculated by software revision: 2.7.6.6/2.33

Traceability	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	26 March 2015

Name
S. Baidjnath-Misier
Head of TCL

Industrieweg 74
2651 BD Berkel en Rodenrijs
The Netherlands
Tel. : +31(0)105112911
Telefax : +31 (0)105115114

All quotations and deliveries are subject to the general delivery- and payment conditions of the "Coöperatieve Vereniging Het Instrument U.A." filed with the Registry of the District Court in Utrecht on 13-01-1993 and with the Chamber of Commerce and Industry in Amersfoort

Reproduction of the complete certificate is allowed.
Parts of the certificate may only be reproduced after written permission by T.C.L.

This certificate is issued provided that neither T.C.L. nor the RvA assumes any liability



The Calibration Company

T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 2 of 2

Certificate number : 21500461

	Standard	Instrument
Service number		18060
Type	M2200/1	266GST
Manufacturer	Tradinco Instruments	ABB
Description	Deadweight tester	Pressure transmitter
Serial number	4792/87	3K650000006880
Range	(2.7 ± 700) bar	(0 ± 400) bar
Medium	Oil	Air
Accuracy	±0.012 % R	±0.1 % R
Temperature	20.2°C ± 0.5°C	

MP.	STANDARD		INSTRUMENT					
	INPUT UP bar	INPUT DOWN bar	READING UP bar	READING DOWN bar	ERROR UP % R	ERROR DOWN % R	LIMIT UP % R	LIMIT DOWN % R
1	0.00000	0.00000	-0.012	-0.021			± 0.10	± 0.10
2	39.9853	39.9853	39.962	39.962	-0.06	-0.06	± 0.10	± 0.10
3	79.9779	79.9779	79.958	79.966	-0.02	-0.01	± 0.10	± 0.10
4	119.973	119.973	119.968	119.984	0.00	0.01	± 0.10	± 0.10
5	159.970	159.970	159.982	160.000	0.01	0.02	± 0.10	± 0.10
6	199.952	199.952	199.975	199.995	0.01	0.02	± 0.10	± 0.10
7	239.949	239.949	239.973	239.998	0.01	0.02	± 0.10	± 0.10
8	279.945	279.945	279.974	279.990	0.01	0.02	± 0.10	± 0.10
9	319.940	319.940	319.965	319.976	0.01	0.01	± 0.10	± 0.10
10	359.938	359.938	359.934	359.975	0.00	0.01	± 0.10	± 0.10
11	399.920		399.917		0.00		± 0.10	

Before calibration the transmitter has not been set to zero.

The transmitter is mounted in a frame and the whole is calibrated in the horizontal position.

The read-out of the transmitter was done using the software Studio302 / ThermoLyse on a laptop of the customer.

Customer ID. no. : P 2391

Customer ref. : -

Our ref. : 61500730

Customer : DNV GL

Calibrated by
TCL Technician

P. Verhoef

Cal. date : 26 March 2015

Approved by

Head of TCL

S. Bandjmath-Misier

Date : 26 March 2015

Berkel en Rodenrijs



T.C.L. Tradinco Calibration Laboratory

Page 1 of 2



CALIBRATION CERTIFICATE

Certificate number : 21500278R1

Applicant	DNV GL Utrechtseweg 310 6812 AR Arnhem
Instrument	Pressure transmitter
Manufacturer	ABB
Type	266GST
Serial number	3K650000006881
Service number	18061
Customer identification number	P 2392
Calibration method	This calibration is carried out with : Deadweight tester type : M2200/1 S/N : 4792/87 Cal. Due : 24 April 2019

During calibration a testpressure is put under a calibrated measuring piston which is loaded with calibrated weights

The instrument is calibrated in combination with oil/gas separator type 8335.

Environmental conditions	Temperature: 20.0°C ± 2°C Humidity: 55 %rh ± 25 %rh
Date / period of calibration	25 February 2015

Results	See following page(s)
Uncertainty	± 0.029 % of reading with use of correction figures in the range of 20 - 100 % of full scale

The reported uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %.
The standard uncertainty has been determined in accordance with document EA-4/02.

Calculated by software revision: 2.7.6.6/2.35

Traceability	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	25 February 2015

Name
S. Baidjnath-Misier
Head of TCL

Industrieweg 74
2651 BD Berkel en Rodenrijs
The Netherlands
Tel. : +31(0)105112911
Telefax : +31 (0)105115114

All our offers and agreements are governed by the FHI General Conditions of Delivery 2014 issued by FHI, Federation of Technology Branches, filed at the Chamber of Commerce of Gooi-, Eem- and Flevoland under the number 40507574. These general conditions are available for free at www.tradinco.com

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced after written permission by T.C.L.

This certificate is issued provided that neither T.C.L. nor the RvA assumes any liability



The Calibration Company

T.C.L. Tradinco Calibration Laboratory

Page 2 of 2



CALIBRATION CERTIFICATE

Certificate number : 21500278R1

	Standard	Instrument
Service number		18061
Type	M2200/1	266GST
Manufacturer	Tradinco Instruments	ABB
Description	Deadweight tester	Pressure transmitter
Serial number	4792/87	3K65000006881
Range	(2.7 ÷ 700) bar	(0 ÷ 400) bar
Medium	Oil	Air
Accuracy	±0.012 % R	±0.1 % R
Temperature	20.9°C ± 0.5°C	

MP.	STANDARD		INSTRUMENT					
	INPUT UP bar	INPUT DOWN bar	READING UP bar	READING DOWN bar	ERROR UP % R	ERROR DOWN % R	LIMIT UP % R	LIMIT DOWN % R
1	0.00000	0.00000	0.000	-0.002	0.00		± 0.10	± 0.10
2	39.9849	39.9849	39.985	39.988	0.00	0.01	± 0.10	± 0.10
3	79.9770	79.9770	79.982	79.992	0.01	0.02	± 0.10	± 0.10
4	119.972	119.972	119.974	119.981	0.00	0.01	± 0.10	± 0.10
5	159.968	159.968	159.964	159.982	0.00	0.01	± 0.10	± 0.10
6	199.950	199.950	199.970	199.943	0.01	0.00	± 0.10	± 0.10
7	239.946	239.946	239.916	239.948	-0.01	0.00	± 0.10	± 0.10
8	279.942	279.942	279.891	279.925	-0.02	-0.01	± 0.10	± 0.10
9	319.937	319.937	319.895	319.989	-0.01	0.02	± 0.10	± 0.10
10	359.934	359.934	359.922	359.989	0.00	0.02	± 0.10	± 0.10
11	399.916		399.861		-0.01		± 0.10	

Before calibration the transmitter has been set to zero.

The transmitter is mounted in a frame and the whole is calibrated in the horizontal position.

The read-out of the transmitter was done using the software Studio302 / ThermoLyse on a laptop of the customer.

Customer ID. no. : P 2392

Customer ref. : 1.099.74103420.400

Our ref. : 61402416

Customer : DNV GL

Calibrated by
TCL Technician

C. Martinus
Cal. date : 25 February 2015

Approved by
Head of TCL
S. Bandjmath-Misier
Date : 25 February 2015
Berkel en Rodenrijs



The Calibration Company

T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 1 of 2

Certificate number : 21500579

Applicant	DNV GL Utrechtseweg 310 6812 AR Amhem
Instrument	Pressure transmitter
Manufacturer	ABB
Type	266GST
Serial number	3K650000006882
Service number	18215
Customer identification number	P 2393
Calibration method	This calibration is carried out with : Deadweight tester type : M2200/1 S/N : 4792/87 Cal. Due : 24 April 2019

During calibration a testpressure is put under a calibrated measuring piston which is loaded with calibrated weights

The instrument is calibrated in combination with oil/gas separator type 8335.

Environmental conditions	Temperature: 20.0°C ± 2°C Humidity: 55 %rh ± 25 %rh
Date / period of calibration	16 April 2015

Results	See following page(s)
Uncertainty	± 0.015 % of reading with use of correction figures in the range of 20 - 100 % of full scale

The reported uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %.
The standard uncertainty has been determined in accordance with document EA-4/02.

Calculated by software revision: 2.7.6.6/2.33

Traceability	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	16 April 2015

Name
S. Baidjnath-Misier
Head of TCL

Industrieweg 74
2651 BD Berkel en Rodenrijs
The Netherlands
Tel. : +31(0)105112911
Telefax : +31 (0)105115114

All quotations and deliveries are subject to the general delivery- and payment conditions of the "Coöperatieve Vereniging Het Instrument U.A." filed with the Registry of the District Court in Utrecht on 13-01-1993 and with the Chamber of Commerce and Industry in Amersfoort

Reproduction of the complete certificate is allowed.
Parts of the certificate may only be reproduced after written permission by T.C.L.

This certificate is issued provided that neither T.C.L. nor the RvA assumes any liability



The Calibration Company

T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 2 of 2

Certificate number : 21500579

	Standard	Instrument
Service number		18215
Type	M2200/1	266GST
Manufacturer	Tradinco Instruments	ABB
Description	Deadweight tester	Pressure transmitter
Serial number	4792/87	3K65000006882
Range	(2.7 ± 700) bar	(0 ± 400) bar
Medium	Oil	Air
Accuracy	±0.012 % R	±0.1 % R
Temperature	20.4°C ± 0.5°C	

MP.	STANDARD		INSTRUMENT					
	INPUT UP bar	INPUT DOWN bar	READING UP bar	READING DOWN bar	ERROR UP % R	ERROR DOWN % R	LIMIT UP % R	LIMIT DOWN % R
1	0.00000	0.00000	0.000	0.000	0.00	0.00	± 0.10	± 0.10
2	39.9852	39.9852	39.999	39.997	0.03	0.03	± 0.10	± 0.10
3	79.9777	79.9777	79.987	79.993	0.01	0.02	± 0.10	± 0.10
4	119.973	119.973	119.975	119.961	0.00	-0.01	± 0.10	± 0.10
5	159.969	159.969	159.951	159.938	-0.01	-0.02	± 0.10	± 0.10
6	199.952	199.952	199.942	199.952	0.00	0.00	± 0.10	± 0.10
7	239.948	239.948	239.954	239.966	0.00	0.01	± 0.10	± 0.10
8	279.944	279.944	279.946	279.929	0.00	-0.01	± 0.10	± 0.10
9	319.939	319.939	319.940	319.938	0.00	0.00	± 0.10	± 0.10
10	359.937	359.937	359.932	359.921	0.00	0.00	± 0.10	± 0.10
11	399.919		399.912		0.00		± 0.10	

Before calibration the transmitter has been set to zero.

The transmitter is mounted in a frame and the whole is calibrated in the horizontal position.

The read-out of the transmitter was done using the software Studio302 / ThermoLyse on a laptop of the customer.

Customer ID. no. : P 2393

Customer ref. : 9.099.74103420.400

Our ref. : 61500533

Customer : DNV GL

Calibrated by
TCL Technician

C. Martinus
Cal. date : 16 April 2015

Approved by
Head of TCL
S. Bandjmath-Misier
Date : 16 April 2015
Berkel en Rodenrijs



T.C.L. Tradinco Calibration Laboratory

Page 1 of 2



CALIBRATION CERTIFICATE

Certificate number : 21500995

Applicant	DNV GL Utrechtseweg 310 6812 AR Amhem
Instrument	Pressure transmitter
Manufacturer	ABB
Type	266GST
Serial number	3K650000006883
Service number	18216
Customer identification number	P 2394
Calibration method	This calibration is carried out with: Deadweight tester type : M2200/1 S/N : 4792/87 Cal. Due : 24 April 2019

During calibration a testpressure is put under a calibrated measuring piston which is loaded with calibrated weights

The instrument is calibrated in combination with oil/gas separator type 8335.

Environmental conditions	Temperature: 20.0°C ± 2°C Humidity: 55 %rh ± 25 %rh
Date / period of calibration	23 July 2015

Results	See following page(s)
Uncertainty	± 0.014 % of reading with use of correction figures in the range of 20 - 100 % of full scale

The reported uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %.
The standard uncertainty has been determined in accordance with document EA-4/02.

Calculated by software revision: 2.7.6.6/2.35

Traceability	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
--------------	--

Date	23 July 2015
------	--------------

Name
S. Baidjnath-Misier
Head of TCL

Industrieweg 74
2651 BD Berkel en Rodenrijs
The Netherlands
Tel. : +31(0)105112911
Telefax : +31 (0)105115114

All our offers and agreements are governed by the FHI General Conditions of Delivery 2014 issued by FHI, Federation of Technology Branches, filed at the Chamber of Commerce of Goor-, Eem- and Flevoland under the number 40507574. These general conditions are available for free at www.tradinco.com

Reproduction of the complete certificate is allowed.
Parts of the certificate may only be reproduced after written permission by T.C.L.

This certificate is issued provided that neither T.C.L. nor the RvA assumes any liability



T.C.L. Tradinco Calibration Laboratory

Page 2 of 2



CALIBRATION CERTIFICATE

Certificate number : 21500995

	Standard	Instrument
Service number		18216
Type	M2200/1	266GST
Manufacturer	Tradinco Instruments	ABB
Description	Deadweight tester	Pressure transmitter
Serial number	4792/87	3K650000006883
Range	(2.7 ÷ 700) bar	(0 ÷ 400) bar
Medium	Oil	Air
Accuracy	±0.012 % R	±0.1 % R
Temperature	20.5°C ± 0.5°C	

MP.	STANDARD		INSTRUMENT					
	INPUT UP bar	INPUT DOWN bar	READING UP bar	READING DOWN bar	ERROR UP % R	ERROR DOWN % R	LIMIT UP % R	LIMIT DOWN % R
1	0.00000	0.00000	0.000	-0.006	0.00		± 0.10	± 0.10
2	39.9851	39.9851	39.978	39.979	-0.02	-0.02	± 0.10	± 0.10
3	79.9775	79.9775	79.973	79.967	-0.01	-0.01	± 0.10	± 0.10
4	119.972	119.972	119.952	119.955	-0.02	-0.01	± 0.10	± 0.10
5	159.969	159.969	159.948	159.963	-0.01	0.00	± 0.10	± 0.10
6	199.951	199.951	199.940	199.955	-0.01	0.00	± 0.10	± 0.10
7	239.948	239.948	239.933	239.943	-0.01	0.00	± 0.10	± 0.10
8	279.943	279.943	279.918	279.927	-0.01	-0.01	± 0.10	± 0.10
9	319.939	319.939	319.911	319.921	-0.01	-0.01	± 0.10	± 0.10
10	359.936	359.936	359.909	359.907	-0.01	-0.01	± 0.10	± 0.10
11	399.918		399.910		0.00		± 0.10	

Before calibration the transmitter has been set to zero.

The transmitter is mounted in a frame and the whole is calibrated in the horizontal position.

The read-out of the transmitter was done using the software Studio302 / ThermoLyse on a laptop of the customer.

Customer ID. no. : P 2394

Customer ref. : 17.099.74103420.400

Our ref. : 61501526

Customer : DNV GL

Calibrated by
TCL Technician

C. Martinus
Cal. date : 23 July 2015

Approved by
Head of TCL
S. Bandjmath-Misier
Date : 23 July 2015
Berkel en Rodenrijs



The Calibration Company

T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 1 of 2

Certificate number : 21500577

Applicant	DNV GL Utrechtseweg 310 6812 AR Amhem
Instrument	Pressure transmitter
Manufacturer	ABB
Type	266GST
Serial number	3K650000006884
Service number	18214
Customer identification number	P 2395
Calibration method	This calibration is carried out with : Deadweight tester type : M2200/1 S/N : 4792/87 Cal. Due : 24 April 2019

During calibration a testpressure is put under a calibrated measuring piston which is loaded with calibrated weights

The instrument is calibrated in combination with oil/gas separator type 8335.

Environmental conditions	Temperature: 20.0°C ± 2°C Humidity: 55 %rh ± 25 %rh
Date / period of calibration	16 April 2015

Results	See following page(s)
Uncertainty	± 0.019 % of reading with use of correction figures in the range of 20 - 100 % of full scale

The reported uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %.
The standard uncertainty has been determined in accordance with document EA-4/02.

Calculated by software revision: 2.7.6.6/2.33

Traceability	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	16 April 2015

Name
S. Baidjnath-Misier
Head of TCL

Industrieweg 74
2651 BD Berkel en Rodenrijs
The Netherlands
Tel. : +31(0)105112911
Telefax : +31 (0)105115114

All quotations and deliveries are subject to the general delivery- and payment conditions of the "Coöperatieve Vereniging Het Instrument U.A." filed with the Registry of the District Court in Utrecht on 13-01-1993 and with the Chamber of Commerce and Industry in Amersfoort

Reproduction of the complete certificate is allowed.
Parts of the certificate may only be reproduced after written permission by T.C.L.

This certificate is issued provided that neither T.C.L. nor the RvA assumes any liability



The Calibration Company

T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 2 of 2

Certificate number : 21500577

	Standard	Instrument
Service number		18214
Type	M2200/1	266GST
Manufacturer	Tradinco Instruments	ABB
Description	Deadweight tester	Pressure transmitter
Serial number	4792/87	3K65000006884
Range	(2.7 ± 700) bar	(0 ± 400) bar
Medium	Oil	Air
Accuracy	±0.012 % R	±0.1 % R
Temperature	20.2°C ± 0.5°C	

MP.	STANDARD		INSTRUMENT					
	INPUT UP bar	INPUT DOWN bar	READING UP bar	READING DOWN bar	ERROR UP % R	ERROR DOWN % R	LIMIT UP % R	LIMIT DOWN % R
1	0.00000	0.00000	0.000	-0.010	0.00		± 0.10	± 0.10
2	39.9853	39.9853	39.987	39.987	0.00	0.00	± 0.10	± 0.10
3	79.9779	79.9779	79.979	79.984	0.00	0.01	± 0.10	± 0.10
4	119.973	119.973	119.960	119.963	-0.01	-0.01	± 0.10	± 0.10
5	159.970	159.970	159.931	159.925	-0.02	-0.03	± 0.10	± 0.10
6	199.952	199.952	199.907	199.890	-0.02	-0.03	± 0.10	± 0.10
7	239.949	239.949	239.868	239.870	-0.03	-0.03	± 0.10	± 0.10
8	279.945	279.945	279.854	279.865	-0.03	-0.03	± 0.10	± 0.10
9	319.940	319.940	319.853	319.860	-0.03	-0.03	± 0.10	± 0.10
10	359.938	359.938	359.845	359.952	-0.03	0.00	± 0.10	± 0.10
11	399.920		399.799		-0.03		± 0.10	

Before calibration the transmitter has been set to zero.

The transmitter is mounted in a frame and the whole is calibrated in the horizontal position.

The read-out of the transmitter was done using the software Studio302 / ThermoLyse on a laptop of the customer.

Customer ID. no. : P 2395

Customer ref. : 9.099.74103420.400

Our ref. : 61500533

Customer : DNV GL

Calibrated by
TCL Technician

C. Martinus
Cal. date : 16 April 2015

Approved by
Head of TCL
S. Bandjmath-Misier
Date : 16 April 2015
Berkel en Rodenrijs



The Calibration Company

T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 1 of 2

Certificate number : 21500569

Applicant	DNV GL Utrechtseweg 310 6812 AR Amhem
Instrument	Pressure transmitter
Manufacturer	ABB
Type	266GST
Serial number	3K650000006888
Service number	18213
Customer identification number	P 2399
Calibration method	This calibration is carried out with : Deadweight tester type : M2200/1 S/N : 4792/87 Cal. Due : 24 April 2019

During calibration a testpressure is put under a calibrated measuring piston which is loaded with calibrated weights

The instrument is calibrated in combination with oil/gas separator type 8335.

Environmental conditions	Temperature: 20.0°C ± 2°C Humidity: 55 %rh ± 25 %rh
Date / period of calibration	15 April 2015

Results	See following page(s)
Uncertainty	± 0.014 % of reading with use of correction figures in the range of 20 - 100 % of full scale

The reported uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %.
The standard uncertainty has been determined in accordance with document EA-4/02.

Calculated by software revision: 2.7.6.6/2.33

Traceability	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	15 April 2015

Name
S. Baidjnath-Misier
Head of TCL

Industrieweg 74
2651 BD Berkel en Rodenrijs
The Netherlands
Tel.: +31(0)105112911
Telefax: +31 (0)105115114

All quotations and deliveries are subject to the general delivery- and payment conditions of the "Coöperatieve Vereniging Het Instrument U.A." filed with the Registry of the District Court in Utrecht on 13-01-1993 and with the Chamber of Commerce and Industry in Amersfoort

Reproduction of the complete certificate is allowed.
Parts of the certificate may only be reproduced after written permission by T.C.L.

This certificate is issued provided that neither T.C.L. nor the RvA assumes any liability



The Calibration Company

T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 2 of 2

Certificate number : 21500569

	Standard	Instrument
Service number		18213
Type	M2200/1	266GST
Manufacturer	Tradinco Instruments	ABB
Description	Deadweight tester	Pressure transmitter
Serial number	4792/87	3K65000006888
Range	(2.7 ± 700) bar	(0 ± 400) bar
Medium	Oil	Air
Accuracy	±0.012 % R	±0.1 % R
Temperature	20.0°C ± 0.5°C	

MP.	STANDARD		INSTRUMENT					
	INPUT UP bar	INPUT DOWN bar	READING UP bar	READING DOWN bar	ERROR UP % R	ERROR DOWN % R	LIMIT UP % R	LIMIT DOWN % R
1	0.00000	0.00000	0.000	-0.001	0.00		± 0.10	± 0.10
2	39.9910	39.9910	39.980	39.977	-0.03	-0.03	± 0.10	± 0.10
3	79.9837	79.9837	79.960	79.968	-0.03	-0.02	± 0.10	± 0.10
4	119.979	119.979	119.953	119.957	-0.02	-0.02	± 0.10	± 0.10
5	159.976	159.976	159.945	159.947	-0.02	-0.02	± 0.10	± 0.10
6	199.958	199.958	199.934	199.936	-0.01	-0.01	± 0.10	± 0.10
7	239.955	239.955	239.925	239.932	-0.01	-0.01	± 0.10	± 0.10
8	279.951	279.951	279.932	279.951	-0.01	0.00	± 0.10	± 0.10
9	319.947	319.947	319.916	319.935	-0.01	0.00	± 0.10	± 0.10
10	359.945	359.945	359.922	359.918	-0.01	-0.01	± 0.10	± 0.10
11	399.927		399.917		0.00		± 0.10	

Before calibration the transmitter has been set to zero.

The transmitter is mounted in a frame and the whole is calibrated in the horizontal position.

The read-out of the transmitter was done using the software Studio302 / ThermoLyse on a laptop of the customer.

Customer ID. no. : P 2399

Customer ref. : 9.099.74103420.400

Our ref. : 61500533

Customer : DNV GL

Calibrated by
TCL Technician

C. Martinus
Cal. date : 15 April 2015

Approved by
Head of TCL
S. Bandjmath-Misier
Date : 15 April 2015
Berkel en Rodenrijs



T.C.L. Tradinco Calibration Laboratory

Page 1 of 2



CALIBRATION CERTIFICATE

Certificate number : 21500409

Applicant	Kema Nederland BV Utrechtseweg 310 6812 AR Arnhem		
Instrument	Digital pressure indicator + Volt output		
Manufacturer	Druck		
Type	DPI 142		
Serial number	2805148		
Service number	18155		
Customer identification number	KPS-TDM 8123		
Calibration method	This calibration is carried out with :		
	Pressure Controller	type : DPI 515	S/N : 51500850 Cal. Due : 10 April 2015
	Digital Multimeter	type : 1281	S/N : 43394 Cal. Due : 2 March 2016

Environmental conditions Temperature: 20.0°C ± 2°C
Humidity: 55 %rh ± 25 %rh

Date / period of calibration 18 March 2015

Results See following page(s)
Uncertainty ± 0.015 % of full scale with use of correction figures in the range of (950 ± 1050) mbar (abs)

The reported uncertainty is based on a standard uncertainty multiplied by a coverage factor of $k = 2$,
which provides a confidence level of approximately 95 %.
The standard uncertainty has been determined in accordance with document EA-4/02.

Calculated by software revision: 2.7.6.6/2.33

Traceability The measurements have been executed using standards for which the traceability to
(inter)national standards has been demonstrated towards the RvA.

Date 18 March 2015

Name S. Baidjnath-Misier
Head of TCL

Industrieweg 74
2651 BD Berkel en Rodenrijs
The Netherlands
Tel. : +31(0)105112911
Telefax : +31 (0)105115114

All quotations and deliveries are subject to
the general delivery- and payment conditions of
the "Coöperatieve Vereniging Het Instrument U.A."
filed with the Registry of the District Court
in Utrecht on 13-01-1993 and with the Chamber of
Commerce and Industry in Amersfoort

Reproduction of the complete certificate is
allowed. Parts of the certificate may only be
reproduced after written permission by T.C.L.

This certificate is issued provided that neither
T.C.L. nor the RvA assumes any liability



The Calibration Company

T.C.L. Tradinco Calibration Laboratory



CALIBRATION CERTIFICATE

Page 2 of 2

Certificate number : 21500409

Service number	Standard	Standard	Instrument
Type	DPI 515	1281	18155
Manufacturer	Druck	Wavetek	DPI 142
Description	Pressure Controller	Digital Multimeter	Druck
Serial number	51500850	43394	Digital pressure indicator + mV output
Range	(750 ± 1150) mbar (abs)	(0 ± 10000) mV	2805148
Medium	Air		(750 ± 1150) mbar (abs)
Accuracy	±0.15 mbar	±0.002 % R	Air
Temperature	20.4°C ± 0.5°C	20.4°C ± 0.5°C	±0.05 % FS

MP.	STANDARD			INSTRUMENT				
	INPUT UP mbar (abs)	INPUT DOWN mbar (abs)	READING UP mV	READING DOWN mV	ERROR UP % FS	ERROR DOWN % FS	LIMIT UP % FS	LIMIT DOWN % FS
1	950.000	950.000	5008.6	5008.7	0.030	0.030	± 0.050	± 0.050
2	960.000	960.000	5258.5	5258.7	0.030	0.030	± 0.050	± 0.050
3	970.000	970.000	5508.6	5508.8	0.030	0.031	± 0.050	± 0.050
4	980.000	980.000	5758.6	5758.8	0.030	0.031	± 0.050	± 0.050
5	990.000	990.000	6008.8	6008.8	0.031	0.031	± 0.050	± 0.050
6	1000.000	1000.000	6258.6	6258.6	0.030	0.030	± 0.050	± 0.050
7	1010.000	1010.000	6508.6	6508.6	0.030	0.030	± 0.050	± 0.050
8	1020.000	1020.000	6758.6	6758.6	0.030	0.030	± 0.050	± 0.050
9	1030.000	1030.000	7008.6	7008.7	0.030	0.030	± 0.050	± 0.050
10	1040.000	1040.000	7258.7	7258.7	0.030	0.030	± 0.050	± 0.050
11	1050.000		7508.8		0.031		± 0.050	

The instrument has not been adjusted (As found is as left calibration).

Customer ID. no. : KPS-TDM 8123
 Customer ref. : 1.099.74103420.200
 Our ref. : 61500643
 Customer : Kema Nederland BV

Calibrated by
Deputy Head of TCL

A.G. v.d. Berghe
Cal. date : 18 March 2015

Approved by
Head of TCL
S. Padijn-Misier
Date : 18 March 2015
Berkel en Rodenrijs



DNV-GL
Utrechtseweg 310
6812 AR Arnhem

Beroekadres Kamerlingh Onnesstraat 2
7271 AZ Borculo
Postadres Postbus 15
7270 AA Borculo
Telefoon +31 (0)545 28 09 80
E-mail info@cijborculo.nl
Internet www.cijborculo.nl

Calibration certificate

Certificatenumber	:	1503013	page	1	of	2
Instrument	:	temp/Rv.-meter	Specifications	:	unknown	
Manufacturer	:	E+E				
Type	:	EE31				
Serialnumber	:	324331502	Barcode	:	104169	
Identificationnumber	:	KPS-TDM 0013				
Calibration method	:	The calibration is executed by comparing the readout of the unit under test with the value generated by the calibrator.				
Results	:	see next pages				

Remark	:	No adjustment was required
Calibration date	:	19-Mar-2015
Due	:	19-Mar-2016
Enviromental conditions	:	Temperature (23,0 ± 2,0) ° C ; humidity (55 ± 10) %
Traceability	:	The calibration has been executed using the standards, mentioned below, which are traceable to the (inter)national standards.
Uncertainty	:	

calibrationstandards:

Manufacturer	Type	Certificatenumber	Calibration date
Michell	DEWMET-01-TDH	10606.552	12-jun-2013

Executed by : Geert Veldink
Team Leader measuring instruments

This certificate is issued provided that neither CII Borculo B.V. nor the Raad voor Accreditatie accepts any liability.
Reproduction of the entire certificate is allowed. Partial reproduction of this certificate is only allowed on written approval of the calibration laboratory.

Op al onze leveringen en services zijn onze algemene voorwaarden van toepassing, gedeponeerd bij de Kamer van Koophandel te Apeldoorn, waarvan wij u op verzoek een kopie zullen toesturen.





Certificatenumber: **1503013**

Page **2** of **2**

Beroekadres Kamerling Onnesstraat 2

7271 AZ Borculo

Postadres Postbus 15

7270 AA Borculo

Telefoon +31 (0)545 28 09 80

E-mail info@cijborculo.nl

Internet www.cijborculo.nl

Results:

Humidity		
Input	Reading	Equals
30,70 %	1,557 V	31,14 %
40,48 %	2,050 V	41,01 %
59,47 %	2,973 V	59,47 %
84,45 %	4,215 V	84,29 %

Temperature		
Input	Reading	
24,60 °C	24,55 °C	

Op al onze leveringen en services zijn onze algemene voorwaarden van toepassing, gedeponeerd bij de Kamer van Koophandel te Apeldoorn, waarvan wij u op verzoek een kopie zullen toesturen.



Page 1 of 2

CERTIFICATE
Number: R15130

Applicant	:	KEMA NEDERLAND BV UTRECHTSEWEG 310 6812 AR ARNHEM THE NETHERLANDS
Instrument	:	Temperature indicator which consists of computer & controller box + Fieldbus Foundation PR-topTransmitter incl. Pt100 /4W
Computer	:	DELL laptop
IDnr	:	KEMA 350946
Type	:	Modelnr PP18L
Controller box	:	SMAR System Fieldbus Universal bridge
Type	:	DFI 302 ME
ID. Nr	:	KPS-TDM-8397
Software for PC	:	Studio 302 version 1.11.0.7 & System 302 version 7.3.5
Transmitter	:	PR-electronics
Type	:	5350B
Serialnr.	:	121407488
Resolution	:	0,01 °C
Calibration method	:	The thermometer has been calibrated in liquid bath's, with a minimum immersion of 200 mm, by comparison with a standard thermometer. After the calibration at the highest temperature the thermometer calibration at 0 °C has been repeated.
Environmental conditions	:	The laboratory temperature was conditioned at 23 °C ± 2 °C.
Date of calibration	:	30-06-2015
Results	:	The results are specified at the attached sheet(s) The table indicates : 1 The calibration temperature t_{90} defined according the ITS-90; 2 The actual reading; 3 The deviation in °C.
Uncertainty	:	The uncertainty is 0,13 °C. The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	:	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	:	9 July 2015


J. Spruit
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page : 2 of 2

Certificate No. : R15130

Calibration Temperature [°C]	Actual Reading [°C]	Deviation [°C]
0,00	-0,09	-0,09
50,00	49,99	-0,01
100,00	100,05	0,05
150,00	150,09	0,09
200,00	200,10	0,10



Page 1 of 2

CERTIFICATE
Number: R15131

Applicant	:	KEMA NEDERLAND BV UTRECHTSEWEG 310 6812 AR ARNHEM THE NETHERLANDS
Instrument	:	Temperature indicator which consists of computer & controller box + Fieldbus Foundation PR-topTransmitter incl. Pt100 /4W
Computer	:	DELL laptop
IDnr	:	KEMA 350946
Type	:	Modelnr PP18L
Controller box	:	SMAR System Fieldbus Universal bridge
Type	:	DFI 302 ME
ID. Nr	:	KPS-TDM-8397
Software for PC	:	Studio 302 version 1.11.0.7 & System 302 version 7.3.5
Transmitter	:	PR-electronics
Type	:	5350B
Serialnr.	:	121407489
Resolution	:	0,01 °C
Calibration method	:	The thermometer has been calibrated in liquid bath's, with a minimum immersion of 200 mm, by comparison with a standard thermometer. After the calibration at the highest temperature the thermometer calibration at 0 °C has been repeated.
Environmental conditions	:	The laboratory temperature was conditioned at 23 °C ± 2 °C.
Date of calibration	:	30-06-2015
Results	:	The results are specified at the attached sheet(s) The table indicates : 1 The calibration temperature t_{90} defined according the ITS-90; 2 The actual reading; 3 The deviation in °C.
Uncertainty	:	The uncertainty is 0,09 °C. The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	:	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	:	9 July 2015

J. Spruit
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page : 2 of 2

Certificate No. : R15131

Calibration Temperature [°C]	Actual Reading [°C]	Deviation [°C]
0,00	-0,09	-0,09
50,00	49,98	-0,02
100,00	100,03	0,03
150,00	150,07	0,07
200,00	200,08	0,08



Page 1 of 2

CERTIFICATE
Number: R15129

Applicant	:	KEMA NEDERLAND BV UTRECHTSEWEG 310 6812 AR ARNHEM THE NETHERLANDS
Instrument	:	Temperature indicator which consists of computer & controller box + Fieldbus Foundation PR-topTransmitter incl. Pt100 /4W
Computer	:	DELL laptop
IDnr	:	KEMA 350946
Type	:	Modelnr PP18L
Controller box	:	SMAR System Fieldbus Universal bridge
Type	:	DFI 302 ME
ID. Nr	:	KPS-TDM-8397
Software for PC	:	Studio 302 version 1.11.0.7 & System 302 version 7.3.5
Transmitter	:	PR-electronics
Type	:	5350B
Serialnr.	:	121407491
Resolution	:	0,01 °C
Calibration method	:	The thermometer has been calibrated in liquid bath's, with a minimum immersion of 200 mm, by comparison with a standard thermometer. After the calibration at the highest temperature the thermometer calibration at 0 °C has been repeated.
Environmental conditions	:	The laboratory temperature was conditioned at 23 °C ± 2 °C.
Date of calibration	:	30-06-2015
Results	:	The results are specified at the attached sheet(s) The table indicates : 1 The calibration temperature t_{90} defined according the ITS-90; 2 The actual reading; 3 The deviation in °C.
Uncertainty	:	The uncertainty is 0,09 °C. The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	:	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	:	9 July 2015

J. Spruit
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page : 2 of 2

Certificate No. : R15129

Calibration Temperature [°C]	Actual Reading [°C]	Deviation [°C]
0,00	-0,00	-0,00
50,00	49,86	-0,14
100,00	99,66	-0,34
150,00	149,42	-0,58
200,00	199,12	-0,88



Page 1 of 2

CERTIFICATE
Number: R15127

Applicant	:	KEMA NEDERLAND BV UTRECHTSEWEG 310 6812 AR ARNHEM THE NETHERLANDS
Instrument	:	Temperature indicator which consists of computer & controller box + Fieldbus Foundation PR-topTransmitter incl. Pt100 /4W
Computer	:	DELL laptop
IDnr	:	KEMA 350946
Type	:	Modelnr PP18L
Controller box	:	SMAR System Fieldbus Universal bridge
Type	:	DFI 302 ME
ID. Nr	:	KPS-TDM-8397
Software for PC	:	Studio 302 version 1.11.0.7 & System 302 version 7.3.5
Transmitter	:	PR-electronics
Type	:	5350B
Serialnr.	:	121407486
Resolution	:	0,01 °C
Calibration method	:	The thermometer has been calibrated in liquid bath's, with a minimum immersion of 200 mm, by comparison with a standard thermometer. After the calibration at the highest temperature the thermometer calibration at 0 °C has been repeated.
Environmental conditions	:	The laboratory temperature was conditioned at 23 °C ± 2 °C.
Date of calibration	:	30-06-2015
Results	:	The results are specified at the attached sheet(s) The table indicates : 1 The calibration temperature t_{90} defined according the ITS-90; 2 The actual reading; 3 The deviation in °C.
Uncertainty	:	The uncertainty is 0.09 °C. The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	:	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	:	9 July 2015


J. Spruit
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page : 2 of 2

Certificate No. : R15127

Calibration Temperature [°C]	Actual Reading [°C]	Deviation [°C]
0,00	0,00	0,00
50,00	50,00	0,00
100,00	99,96	-0,04
150,00	149,89	-0,11
200,00	199,77	-0,23



Page 1 of 2

CERTIFICATE
Number: R15132

Applicant	:	KEMA NEDERLAND BV UTRECHTSEWEG 310 6812 AR ARNHEM THE NETHERLANDS
Instrument	:	Temperature indicator which consists of computer & controller box + Fieldbus Foundation PR-topTransmitter incl. TC type K
Computer	:	DELL laptop
IDnr	:	KEMA 350946
Type	:	Modelnr PP18L
Controller box	:	SMAR System Fieldbus Universal bridge
Type	:	DFI 302 ME
ID. Nr	:	KPS-TDM-8397
Software for PC	:	Studio 302 version 1.11.0.7 & System 302 version 7.3.5
Transmitter	:	PR-electronics
Type	:	5350B
Serialnr.	:	121407505
Resolution	:	0,1 °C
Calibration method	:	Prior to the calibration the thermocouple has been heat treated for a period of 5 hours at 650 °C with an immersion depth of 400 mm. The thermometer has been calibrated in liquid bath's, with a minimum immersion of 200 mm, and in a tube furnace with a minimum immersion depth of 360 mm, by comparison with a standard thermometer.
Environmental conditions	:	The laboratory temperature was conditioned at 23 °C ± 2 °C.
Period of calibration	:	02-07-2015 to 09-07-2015
Results	:	The results are specified at the attached sheet(s) The table indicates : 1 The calibration temperature t_{90} defined according the ITS-90; 2 The actual reading; 3 The deviation in °C.
Uncertainty	:	The uncertainty is 2,2 °C. The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	:	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	:	9 July 2015

ing. H.T.V. Do
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page : 2 of 2

Certificate No. : R15132

Calibration Temperature [°C]	Actual Reading [°C]	Deviation [°C]
50,0	50,8	0,8
150,0	151,1	1,1
250,0	251,5	1,5
350,0	351,9	1,9
450,0	452,4	2,4
550,0	553,0	3,0
650,0	653,6	3,6



Page 1 of 2

CERTIFICATE
Number: R15140

Applicant	:	KEMA NEDERLAND BV UTRECHTSEWEG 310 6812 AR ARNHEM THE NETHERLANDS
Instrument	:	Temperature indicator which consists of computer & controller box + Fieldbus Foundation PR-topTransmitter incl. TC type K
Computer	:	DELL laptop
IDnr	:	KEMA 350946
Type	:	Modelnr PP18L
Controller box	:	SMAR System Fieldbus Universal bridge
Type	:	DFI 302 ME
ID. Nr	:	KPS-TDM-8397
Software for PC	:	Studio 302 version 1.11.0.7 & System 302 version 7.3.5
Transmitter	:	PR-electronics
Type	:	5350B
Serial nr.	:	121407485
Resolution	:	0,1 °C
Calibration method	:	Prior to the calibration the thermocouple has been heat treated for a period of 5 hours at 650 °C with an immersion depth of 400 mm. The thermometer has been calibrated in liquid bath's, with a minimum immersion of 200 mm, and in a tube furnace with a minimum immersion depth of 360 mm, by comparison with a standard thermometer.
Environmental conditions	:	The laboratory temperature was conditioned at 23 °C ± 2 °C.
Period of calibration	:	02-07-2015 to 09-07-2015
Results	:	The results are specified at the attached sheet(s) The table indicates : 1 The calibration temperature t_{90} defined according the ITS-90; 2 The actual reading; 3 The deviation in °C.
Uncertainty	:	The uncertainty is 1,6 °C. The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	:	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	:	9 July 2015

ing. H.T.V. Do
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page : 2 of 2

Certificate No. : R15140

Calibration Temperature [°C]	Actual Reading [°C]	Deviation [°C]
50,0	50,5	0,5
150,0	150,6	0,6
250,0	250,7	0,7
350,0	350,8	0,8
450,0	450,8	0,8
550,0	551,0	1,0
650,0	651,1	1,1



Page 1 of 2

CERTIFICATE
Number: R15137A

Applicant	: KEMA NEDERLAND BV UTRECHTSEWEG 310 6812 AR ARNHEM THE NETHERLANDS
Instrument	: Temperature indicator which consists of computer & controller box + Fieldbus Foundation PR-topTransmitter incl. TC type K
Computer	: DELL laptop
IDnr	: KEMA 350946
Type	: Modelnr PP18L
Controller box	: SMAR System Fieldbus Universal bridge
Type	: DFI 302 ME
ID. Nr	: KPS-TDM-8397
Software for PC	: Studio 302 version 1.11.0.7 & System 302 version 7.3.5
Transmitter	: PR-electronics
Type	: 5350B
Serial nr.	: 121407487
Resolution	: 0,1 °C
Calibration method	: Prior to the calibration the thermocouple has been heat treated for a period of 5 hours at 650 °C with an immersion depth of 400 mm. The thermometer has been calibrated in liquid bath's, with a minimum immersion of 200 mm, and in a tube furnace with a minimum immersion depth of 360 mm, by comparison with a standard thermometer.
Environmental conditions	: The laboratory temperature was conditioned at 23 °C ± 2 °C.
Period of calibration	: 02-07-2015 to 09-07-2015
Results	: The results are specified at the attached sheet(s) The table indicates : 1 The calibration temperature t_{90} defined according the ITS-90; 2 The actual reading; 3 The deviation in °C.
Uncertainty	: The uncertainty is 1,6°C. The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	: The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	: 23 July 2015


J. Spruit
Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page : 1 of 2

Certificate No. : R15137A

Calibration Temperature [°C]	Actual Reading [°C]	Deviation [°C]
50,000	50,603	0,603
150,000	150,680	0,680
250,000	250,827	0,827
350,000	350,999	0,999
450,000	451,153	1,153
550,000	551,248	1,248
650,000	651,240	1,240



Page 1 of 2

CERTIFICATE
Number: R15138

Applicant	: KEMA NEDERLAND BV UTRECHTSEWEG 310 6812 AR ARNHEM THE NETHERLANDS
Instrument	: Temperature indicator which consists of computer & controller box + Fieldbus Foundation PR-topTransmitter incl. TC type K
Computer	: DELL laptop
IDnr	: KEMA 350946
Type	: Modelnr PP18L
Controller box	: SMAR System Fieldbus Universal bridge
Type	: DFI 302 ME
ID. Nr	: KPS-TDM-8397
Software for PC	: Studio 302 version 1.11.0.7 & System 302 version 7.3.5
Transmitter	: PR-electronics
Type	: 5350B
Serial nr.	: 121407502
Resolution	: 0,1 °C
Calibration method	: Prior to the calibration the thermocouple has been heat treated for a period of 5 hours at 650 °C with an immersion depth of 400 mm. The thermometer has been calibrated in liquid bath's, with a minimum immersion of 200 mm, and in a tube furnace with a minimum immersion depth of 360 mm, by comparison with a standard thermometer.
Environmental conditions	: The laboratory temperature was conditioned at 23 °C ± 2 °C.
Period of calibration	: 02-07-2015 to 09-07-2015
Results	: The results are specified at the attached sheet(s) The table indicates : 1 The calibration temperature t_{90} defined according the ITS-90; 2 The actual reading; 3 The deviation in °C.
Uncertainty	: The uncertainty is 1,7 °C. The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	: The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	: 9 July 2015

ing. H.T.V. Do
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page : 2 of 2

Certificate No. : R15138

Calibration Temperature [°C]	Actual Reading [°C]	Deviation [°C]
50,0	50,7	0,7
150,0	150,8	0,8
250,0	250,8	0,8
350,0	350,9	0,9
450,0	451,0	1,0
550,0	551,2	1,2
650,0	651,3	1,3



Page 1 of 2

CERTIFICATE
Number: R15134

Applicant	: KEMA NEDERLAND BV UTRECHTSEWEG 310 6812 AR ARNHEM THE NETHERLANDS
Instrument	: Temperature indicator which consists of computer & controller box + Fieldbus Foundation PR-topTransmitter incl. TC type K
Computer	: DELL laptop
IDnr	: KEMA 350946
Type	: Modelnr PP18L
Controller box	: SMAR System Fieldbus Universal bridge
Type	: DFI 302 ME
ID. Nr	: KPS-TDM-8397
Software for PC	: Studio 302 version 1.11.0.7 & System 302 version 7.3.5
Transmitter	: PR-electronics
Type	: 5350B
Serial nr.	: 121407501
Resolution	: 0,1 °C
Calibration method	: Prior to the calibration the thermocouple has been heat treated for a period of 5 hours at 650 °C with an immersion depth of 400 mm. The thermometer has been calibrated in liquid bath's, with a minimum immersion of 200 mm, and in a tube furnace with a minimum immersion depth of 360 mm, by comparison with a standard thermometer.
Environmental conditions	: The laboratory temperature was conditioned at 23 °C ± 2 °C.
Period of calibration	: 02-07-2015 to 09-07-2015
Results	: The results are specified at the attached sheet(s) The table indicates : 1 The calibration temperature t_{90} defined according the ITS-90; 2 The actual reading; 3 The deviation in °C.
Uncertainty	: The uncertainty is 1,7 °C. The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	: The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	: 9 July 2015

ing. H.T.V. Do
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page : 2 of 2

Certificate No. : R15134

Calibration Temperature [°C]	Actual Reading [°C]	Deviation [°C]
50,0	50,6	0,6
150,0	150,6	0,6
250,0	250,6	0,6
350,0	350,7	0,7
450,0	450,8	0,8
550,0	551,0	1,0
650,0	651,3	1,3



Page 1 of 2

CERTIFICATE
Number: R15142

Applicant	: KEMA NEDERLAND BV UTRECHTSEWEG 310 6812 AR ARNHEM THE NETHERLANDS
Instrument	: Temperature indicator which consists of computer & controller box + Fieldbus Foundation PR-topTransmitter incl. TC type K
Computer	: DELL laptop
IDnr	: KEMA 350946
Type	: Modelnr PP18L
Controller box	: SMAR System Fieldbus Universal bridge
Type	: DFI 302 ME
ID. Nr	: KPS-TDM-8397
Software for PC	: Studio 302 version 1.11.0.7 & System 302 version 7.3.5
Transmitter	: PR-electronics
Type	: 5350B
Serial nr.	: 121407495
Resolution	: 0,1 °C
Calibration method	: Prior to the calibration the thermocouple has been heat treated for a period of 5 hours at 650 °C with an immersion depth of 400 mm. The thermometer has been calibrated in liquid bath's, with a minimum immersion of 200 mm, and in a tube furnace with a minimum immersion depth of 360 mm, by comparison with a standard thermometer.
Environmental conditions	: The laboratory temperature was conditioned at 23 °C ± 2 °C.
Period of calibration	: 02-07-2015 to 09-07-2015
Results	: The results are specified at the attached sheet(s) The table indicates : 1 The calibration temperature t_{90} defined according the ITS-90; 2 The actual reading; 3 The deviation in °C.
Uncertainty	: The uncertainty is 1,6 °C. The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	: The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	: 9 July 2015

ing. H.T.V. Do
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page : 2 of 2

Certificate No. : R15142

Calibration Temperature [°C]	Actual Reading [°C]	Deviation [°C]
50,0	50,7	0,7
150,0	150,9	0,9
250,0	251,0	1,0
350,0	351,1	1,1
450,0	451,1	1,1
550,0	551,1	1,1
650,0	651,0	1,0



Page 1 of 2

CERTIFICATE
Number: R15141

Applicant	: KEMA NEDERLAND BV UTRECHTSEWEG 310 6812 AR ARNHEM THE NETHERLANDS
Instrument	: Temperature indicator which consists of computer & controller box + Fieldbus Foundation PR-topTransmitter incl. TC type K
Computer	: DELL laptop
IDnr	: KEMA 350946
Type	: Modelnr PP18L
Controller box	: SMAR System Fieldbus Universal bridge
Type	: DFI 302 ME
ID. Nr	: KPS-TDM-8397
Software for PC	: Studio 302 version 1.11.0.7 & System 302 version 7.3.5
Transmitter	: PR-electronics
Type	: 5350B
Serial nr.	: 121407496
Resolution	: 0,1 °C
Calibration method	: Prior to the calibration the thermocouple has been heat treated for a period of 5 hours at 650 °C with an immersion depth of 400 mm. The thermometer has been calibrated in liquid bath's, with a minimum immersion of 200 mm, and in a tube furnace with a minimum immersion depth of 360 mm, by comparison with a standard thermometer.
Environmental conditions	: The laboratory temperature was conditioned at 23 °C ± 2 °C.
Period of calibration	: 02-07-2015 to 09-07-2015
Results	: The results are specified at the attached sheet(s) The table indicates : 1 The calibration temperature t_{90} defined according the ITS-90; 2 The actual reading; 3 The deviation in °C.
Uncertainty	: The uncertainty is 1,6 °C. The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	: The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	: 9 July 2015

ing. H.T.V. Do
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page : 2 of 2

Certificate No. : R15141

Calibration Temperature [°C]	Actual Reading [°C]	Deviation [°C]
50,0	50,7	0,7
150,0	151,1	1,1
250,0	251,4	1,4
350,0	351,7	1,7
450,0	452,0	2,0
550,0	552,3	2,3
650,0	652,6	2,6



Page 1 of 2

CERTIFICATE
Number: R15135

Applicant	: KEMA NEDERLAND BV UTRECHTSEWEG 310 6812 AR ARNHEM THE NETHERLANDS
Instrument	: Temperature indicator which consists of computer & controller box + Fieldbus Foundation PR-topTransmitter incl. TC type K
Computer	: DELL laptop
IDnr	: KEMA 350946
Type	: Modelnr PP18L
Controller box	: SMAR System Fieldbus Universal bridge
Type	: DFI 302 ME
ID. Nr	: KPS-TDM-8397
Software for PC	: Studio 302 version 1.11.0.7 & System 302 version 7.3.5
Transmitter	: PR-electronics
Type	: 5350B
Serial nr.	: 121407484
Resolution	: 0,1 °C
Calibration method	: Prior to the calibration the thermocouple has been heat treated for a period of 5 hours at 650 °C with an immersion depth of 400 mm. The thermometer has been calibrated in liquid bath's, with a minimum immersion of 200 mm, and in a tube furnace with a minimum immersion depth of 360 mm, by comparison with a standard thermometer.
Environmental conditions	: The laboratory temperature was conditioned at 23 °C ± 2 °C.
Period of calibration	: 02-07-2015 to 09-07-2015
Results	: The results are specified at the attached sheet(s) The table indicates : 1 The calibration temperature t_{90} defined according the ITS-90; 2 The actual reading; 3 The deviation in °C.
Uncertainty	: The uncertainty is 1,7 °C. The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	: The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	: 9 July 2015

ing. H.T.V. Do
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page : 2 of 2

Certificate No. : R15135

Calibration Temperature [°C]	Actual Reading [°C]	Deviation [°C]
50,0	50,6	0,6
150,0	150,6	0,6
250,0	250,7	0,7
350,0	350,8	0,8
450,0	450,9	0,9
550,0	551,2	1,2
650,0	651,4	1,4



Page 1 of 2

CERTIFICATE
Number: R15144

Applicant	: KEMA NEDERLAND BV UTRECHTSEWEG 310 6812 AR ARNHEM THE NETHERLANDS
Instrument	: Temperature indicator which consists of computer & controller box + Fieldbus Foundation PR-topTransmitter incl. TC type K
Computer	: DELL laptop
IDnr	: KEMA 350946
Type	: Modelnr PP18L
Controller box	: SMAR System Fieldbus Universal bridge
Type	: DFI 302 ME
ID. Nr	: KPS-TDM-8397
Software for PC	: Studio 302 version 1.11.0.7 & System 302 version 7.3.5
Transmitter	: PR-electronics
Type	: 5350B
Serial nr.	: 121407494
Resolution	: 0,1 °C
Calibration method	: Prior to the calibration the thermocouple has been heat treated for a period of 5 hours at 650 °C with an immersion depth of 400 mm. The thermometer has been calibrated in liquid bath's, with a minimum immersion of 200 mm, and in a tube furnace with a minimum immersion depth of 360 mm, by comparison with a standard thermometer.
Environmental conditions	: The laboratory temperature was conditioned at 23 °C ± 2 °C.
Period of calibration	: 02-07-2015 to 09-07-2015
Results	: The results are specified at the attached sheet(s) The table indicates : 1 The calibration temperature t_{90} defined according the ITS-90; 2 The actual reading; 3 The deviation in °C.
Uncertainty	: The uncertainty is 1,7 °C. The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	: The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	: 9 July 2015

ing. H.T.V. Do
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page : 2 of 2

Certificate No. : R15144

Calibration Temperature [°C]	Actual Reading [°C]	Deviation [°C]
50,0	50,6	0,6
150,0	150,7	0,7
250,0	250,8	0,8
350,0	350,9	0,9
450,0	451,0	1,0
550,0	551,1	1,1
650,0	651,3	1,3



Page 1 of 2

CERTIFICATE
Number: R15143

Applicant	:	KEMA NEDERLAND BV UTRECHTSEWEG 310 6812 AR ARNHEM THE NETHERLANDS
Instrument	:	Temperature indicator which consists of computer & controller box + Fieldbus Foundation PR-topTransmitter incl. TC type K
Computer	:	DELL laptop
IDnr	:	KEMA 350946
Type	:	Modelnr PP18L
Controller box	:	SMAR System Fieldbus Universal bridge
Type	:	DFI 302 ME
ID. Nr	:	KPS-TDM-8397
Software for PC	:	Studio 302 version 1.11.0.7 & System 302 version 7.3.5
Transmitter	:	PR-electronics
Type	:	5350B
Serial nr.	:	121407499
Resolution	:	0,1 °C
Calibration method	:	Prior to the calibration the thermocouple has been heat treated for a period of 5 hours at 650 °C with an immersion depth of 400 mm. The thermometer has been calibrated in liquid bath's, with a minimum immersion of 200 mm, and in a tube furnace with a minimum immersion depth of 360 mm, by comparison with a standard thermometer.
Environmental conditions	:	The laboratory temperature was conditioned at 23 °C ± 2 °C.
Period of calibration	:	02-07-2015 to 09-07-2015
Results	:	The results are specified at the attached sheet(s) The table indicates : 1 The calibration temperature t_{90} defined according the ITS-90; 2 The actual reading; 3 The deviation in °C.
Uncertainty	:	The uncertainty is 1,6 °C. The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	:	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	:	9 July 2015

ing. H.T.V. Do
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page : 2 of 2

Certificate No. : R15143

Calibration Temperature [°C]	Actual Reading [°C]	Deviation [°C]
50,0	50,7	0,7
150,0	150,8	0,8
250,0	250,8	0,8
350,0	351,0	1,0
450,0	451,2	1,2
550,0	551,4	1,4
650,0	651,6	1,6



Page 1 of 2

CERTIFICATE
Number: R15145

Applicant	:	KEMA NEDERLAND BV UTRECHTSEWEG 310 6812 AR ARNHEM THE NETHERLANDS
Instrument	:	Temperature indicator which consists of computer & controller box + Fieldbus Foundation PR-topTransmitter incl. TC type K
Computer	:	DELL laptop
IDnr	:	KEMA 350946
Type	:	Modelnr PP18L
Controller box	:	SMAR System Fieldbus Universal bridge
Type	:	DFI 302 ME
ID. Nr	:	KPS-TDM-8397
Software for PC	:	Studio 302 version 1.11.0.7 & System 302 version 7.3.5
Transmitter	:	PR-electronics
Type	:	5350B
Serial nr.	:	121407492
Resolution	:	0,1 °C
Calibration method	:	Prior to the calibration the thermocouple has been heat treated for a period of 5 hours at 650 °C with an immersion depth of 400 mm. The thermometer has been calibrated in liquid bath's, with a minimum immersion of 200 mm, and in a tube furnace with a minimum immersion depth of 360 mm, by comparison with a standard thermometer.
Environmental conditions	:	The laboratory temperature was conditioned at 23 °C ± 2 °C.
Period of calibration	:	02-07-2015 to 09-07-2015
Results	:	The results are specified at the attached sheet(s) The table indicates : 1 The calibration temperature t_{90} defined according the ITS-90; 2 The actual reading; 3 The deviation in °C.
Uncertainty	:	The uncertainty is 1,6 °C. The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	:	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	:	9 July 2015

ing. H.T.V. Do
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page : 2 of 2

Certificate No. : R15145

Calibration Temperature [°C]	Actual Reading [°C]	Deviation [°C]
50,0	50,5	0,5
150,0	150,6	0,6
250,0	250,7	0,7
350,0	350,8	0,8
450,0	450,9	0,9
550,0	551,1	1,1
650,0	651,3	1,3



Page 1 of 2

CERTIFICATE
Number: R15136

Applicant	:	KEMA NEDERLAND BV UTRECHTSEWEG 310 6812 AR ARNHEM THE NETHERLANDS
Instrument	:	Temperature indicator which consists of computer & controller box + Fieldbus Foundation PR-topTransmitter incl. TC type K
Computer	:	DELL laptop
IDnr	:	KEMA 350946
Type	:	Modelnr PP18L
Controller box	:	SMAR System Fieldbus Universal bridge
Type	:	DFI 302 ME
ID. Nr	:	KPS-TDM-8397
Software for PC	:	Studio 302 version 1.11.0.7 & System 302 version 7.3.5
Transmitter	:	PR-electronics
Type	:	5350B
Serial nr.	:	121407497
Resolution	:	0,1 °C
Calibration method	:	Prior to the calibration the thermocouple has been heat treated for a period of 5 hours at 650 °C with an immersion depth of 400 mm. The thermometer has been calibrated in liquid bath's, with a minimum immersion of 200 mm, and in a tube furnace with a minimum immersion depth of 360 mm, by comparison with a standard thermometer.
Environmental conditions	:	The laboratory temperature was conditioned at 23 °C ± 2 °C.
Period of calibration	:	02-07-2015 to 09-07-2015
Results	:	The results are specified at the attached sheet(s) The table indicates : 1 The calibration temperature t_{90} defined according the ITS-90; 2 The actual reading; 3 The deviation in °C.
Uncertainty	:	The uncertainty is 1,7 °C. The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	:	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	:	9 July 2015

ing. H.T.V. Do
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page : 2 of 2

Certificate No. : R15136

Calibration Temperature [°C]	Actual Reading [°C]	Deviation [°C]
50,0	50,7	0,7
150,0	150,7	0,7
250,0	250,8	0,8
350,0	350,9	0,9
450,0	451,1	1,1
550,0	551,2	1,2
650,0	651,4	1,4



Page 1 of 2

CERTIFICATE
Number: R15139

Applicant	: KEMA NEDERLAND BV UTRECHTSEWEG 310 6812 AR ARNHEM THE NETHERLANDS
Instrument	: Temperature indicator which consists of computer & controller box + Fieldbus Foundation PR-topTransmitter incl. TC type K
Computer	: DELL laptop
IDnr	: KEMA 350946
Type	: Modelnr PP18L
Controller box	: SMAR System Fieldbus Universal bridge
Type	: DFI 302 ME
ID. Nr	: KPS-TDM-8397
Software for PC	: Studio 302 version 1.11.0.7 & System 302 version 7.3.5
Transmitter	: PR-electronics
Type	: 5350B
Serial nr.	: 121407498
Resolution	: 0,1 °C
Calibration method	: Prior to the calibration the thermocouple has been heat treated for a period of 5 hours at 650 °C with an immersion depth of 400 mm. The thermometer has been calibrated in liquid bath's, with a minimum immersion of 200 mm, and in a tube furnace with a minimum immersion depth of 360 mm, by comparison with a standard thermometer.
Environmental conditions	: The laboratory temperature was conditioned at 23 °C ± 2 °C.
Period of calibration	: 02-07-2015 to 09-07-2015
Results	: The results are specified at the attached sheet(s) The table indicates : 1 The calibration temperature t_{90} defined according the ITS-90; 2 The actual reading; 3 The deviation in °C.
Uncertainty	: The uncertainty is 1,6 °C. The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which provides a confidence level of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	: The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	: 9 July 2015

ing. H.T.V. Do
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page : 2 of 2

Certificate No. : R15139

Calibration Temperature [°C]	Actual Reading [°C]	Deviation [°C]
50,0	50,7	0,7
150,0	150,8	0,8
250,0	250,9	0,9
350,0	351,0	1,0
450,0	451,1	1,1
550,0	551,3	1,3
650,0	651,4	1,4



Page 1 of 4

CERTIFICATE
Number: R15166

Applicant	:	KEMA B.V. UTRECHTSEWEG 310 GEBOUW B08 – EXPEDITIE 6812 AR ARNHEM THE NETHERLANDS
Instrument Manufacturer	:	22 pcs. Thermocouples type K
Item no.	:	Thermo Electric Instrumentation B.V.
Serial number	:	9297465
Calibration Method	:	R15166-1 to -22
Environmental Conditions:	:	Prior to the calibration the thermocouple has been heat treated for a period of 12 hours at 500 °C. The thermocouple has been calibrated in liquid bath's, with a minimum immersion depth of 200 mm, by comparison with a standard thermometer. The cold junction has been realised by using an ice bath.
Period of Calibration	:	The laboratory temperature was conditioned at 23 °C ± 2 °C. 10-08-2015 to 19-08-2015
Results	:	The results are specified at the attached sheet(s) The table indicates : 1 The serial number / tag number; 2 The temperature t90 defined according the ITS-90; 3 The microvolt value Et as per the relevant tables at t90 according IEC 60584-1 (2013); 4 The actual measured microvolt value E; 5 The deviation in microvolt; 6 The deviation in °C; 7 The expanded uncertainty in °C.
Uncertainty	:	The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which for a normal distribution corresponds to a coverage probability of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	:	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	:	24 August 2015

ing. H.T.V. Do
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page 2 of 4

Number: R15166

Tag No.	Temperature [°C]	Tabel Value [µV]	Measured Value [µV]	Deviation		Expanded Uncertainty [°C]
				[µV]	[°C]	
R15166-1	50,0	2023,08	2042,85	19,77	0,48	0,9
	150,0	6138,34	6180,40	42,06	1,04	
	250,0	10153,37	10226,58	73,21	1,80	
	350,0	14293,15	14406,37	113,22	2,70	
	450,0	18515,81	18677,90	162,10	3,81	
R15166-2	50,0	2023,08	2043,39	20,32	0,49	1
	150,0	6138,34	6181,88	43,54	1,08	
	250,0	10153,37	10228,44	75,07	1,84	
	350,0	14293,15	14408,07	114,92	2,74	
	450,0	18515,81	18678,89	163,08	3,84	
R15166-3	50,0	2023,08	2044,01	20,94	0,51	1
	150,0	6138,34	6183,73	45,39	1,13	
	250,0	10153,37	10230,82	77,45	1,90	
	350,0	14293,15	14410,27	117,12	2,79	
	450,0	18515,81	18680,21	164,40	3,87	
R15166-4	50,0	2023,08	2043,98	20,90	0,51	1,2
	150,0	6138,34	6183,30	44,96	1,12	
	250,0	10153,37	10231,06	77,69	1,91	
	350,0	14293,15	14412,24	119,09	2,84	
	450,0	18515,81	18684,97	169,17	3,98	
R15166-5	50,0	2023,08	2044,01	20,93	0,51	1
	150,0	6138,34	6183,26	44,92	1,12	
	250,0	10153,37	10229,81	76,44	1,88	
	350,0	14293,15	14408,64	115,49	2,76	
	450,0	18515,81	18677,87	162,06	3,81	
R15166-6	50,0	2023,08	2042,57	19,49	0,47	0,8
	150,0	6138,34	6179,60	41,26	1,02	
	250,0	10153,37	10225,51	72,15	1,77	
	350,0	14293,15	14405,29	112,14	2,68	
	450,0	18515,81	18677,06	161,25	3,80	
R15166-7	50,0	2023,08	2042,98	19,90	0,48	0,8
	150,0	6138,34	6181,97	43,63	1,08	
	250,0	10153,37	10230,33	76,96	1,89	
	350,0	14293,15	14413,05	119,90	2,86	
	450,0	18515,81	18688,26	172,45	4,06	
R15166-8	50,0	2023,08	2043,31	20,23	0,49	0,9
	150,0	6138,34	6182,23	43,89	1,09	
	250,0	10153,37	10229,60	76,23	1,87	
	350,0	14293,15	14410,40	117,25	2,80	
	450,0	18515,81	18682,77	166,97	3,93	
R15166-9	50,0	2023,08	2042,78	19,70	0,48	0,8
	150,0	6138,34	6180,16	41,81	1,04	
	250,0	10153,37	10226,75	73,38	1,80	
	350,0	14293,15	14407,56	114,41	2,73	
	450,0	18515,81	18680,69	164,89	3,88	



Calibration Certificate

Page 3 of 4

Number: R15166

Tag No.	Temperature [°C]	Tabel Value [µV]	Measured Value [µV]	Deviation		Expanded Uncertainty [°C]
				[µV]	[°C]	
R15166-10	50,0	2023,08	2042,08	19,00	0,46	0,7
	150,0	6138,34	6179,47	41,13	1,02	
	250,0	10153,37	10226,42	73,05	1,79	
	350,0	14293,15	14407,91	114,77	2,74	
	450,0	18515,81	18682,08	166,27	3,91	
R15166-11	50,0	2023,08	2043,19	20,11	0,49	1
	150,0	6138,34	6180,55	42,21	1,05	
	250,0	10153,37	10226,72	73,35	1,80	
	350,0	14293,15	14406,67	113,52	2,71	
	450,0	18515,81	18678,54	162,73	3,83	
R15166-12	50,0	2023,08	2043,87	20,79	0,50	1
	150,0	6138,34	6181,11	42,76	1,06	
	250,0	10153,37	10226,59	73,23	1,80	
	350,0	14293,15	14405,32	112,17	2,68	
	450,0	18515,81	18675,41	159,60	3,76	
R15166-13	50,0	2023,08	2043,18	20,10	0,49	1,1
	150,0	6138,34	6180,09	41,74	1,04	
	250,0	10153,37	10225,63	72,26	1,78	
	350,0	14293,15	14404,80	111,65	2,66	
	450,0	18515,81	18675,72	159,91	3,76	
R15166-14	50,0	2023,08	2044,11	21,03	0,51	1,1
	150,0	6138,34	6182,03	43,68	1,08	
	250,0	10153,37	10227,95	74,58	1,83	
	350,0	14293,15	14406,87	113,72	2,71	
	450,0	18515,81	18676,91	161,11	3,79	
R15166-15	50,0	2023,08	2043,20	20,12	0,49	1,1
	150,0	6138,34	6180,73	42,39	1,05	
	250,0	10153,37	10226,97	73,60	1,81	
	350,0	14293,15	14406,91	113,76	2,71	
	450,0	18515,81	18678,68	162,87	3,83	
R15166-16	50,0	2023,08	2043,72	20,64	0,50	1,2
	150,0	6138,34	6180,34	42,00	1,04	
	250,0	10153,37	10225,89	72,52	1,78	
	350,0	14293,15	14405,34	112,19	2,68	
	450,0	18515,81	18676,84	161,03	3,79	
R15166-17	50,0	2023,08	2044,18	21,11	0,51	1,3
	150,0	6138,34	6180,56	42,21	1,05	
	250,0	10153,37	10225,37	72,00	1,77	
	350,0	14293,15	14403,62	110,47	2,64	
	450,0	18515,81	18673,42	157,61	3,71	
R15166-18	50,0	2023,08	2044,19	21,11	0,51	1,4
	150,0	6138,34	6181,24	42,89	1,06	
	250,0	10153,37	10227,16	73,79	1,81	
	350,0	14293,15	14406,97	113,82	2,72	
	450,0	18515,81	18678,78	162,97	3,84	



Calibration Certificate

Page 4 of 4

Number: R15166

Tag No.	Temperature [°C]	Tabel Value [μV]	Measured Value [μV]	Deviation		Expanded Uncertainty [°C]
				[μV]	[°C]	
R15166-19	50,0	2023,08	2045,15	22,07	0,54	1,3
	150,0	6138,34	6183,63	45,29	1,12	
	250,0	10153,37	10229,76	76,39	1,88	
	350,0	14293,15	14408,54	115,39	2,75	
	450,0	18515,81	18678,08	162,27	3,82	
R15166-20	50,0	2023,08	2044,46	21,38	0,52	1,4
	150,0	6138,34	6182,24	43,89	1,09	
	250,0	10153,37	10228,38	75,01	1,84	
	350,0	14293,15	14407,89	114,74	2,74	
	450,0	18515,81	18678,88	163,07	3,84	
R15166-21	50,0	2023,08	2044,47	21,39	0,52	1,5
	150,0	6138,34	6181,74	43,40	1,08	
	250,0	10153,37	10227,21	73,84	1,81	
	350,0	14293,15	14405,87	112,72	2,69	
	450,0	18515,81	18675,83	160,02	3,77	
R15166-22	50,0	2023,08	2044,00	20,93	0,51	1,4
	150,0	6138,34	6180,91	42,56	1,06	
	250,0	10153,37	10227,40	74,03	1,82	
	350,0	14293,15	14408,47	115,32	2,75	
	450,0	18515,81	18682,26	166,45	3,92	



Page 1 of 4

CERTIFICATE
Number: R15167

Applicant	:	KEMA B.V. UTRECHTSEWEG 310 GEBOUW B08 – EXPEDITIE 6812 AR ARNHEM THE NETHERLANDS
Instrument Manufacturer	:	22 pcs. Thermocouples type K
Item no.	:	Thermo Electric Instrumentation B.V.
Serial number	:	9413553
Calibration Method	:	R15167-1 to -22
Environmental Conditions:	:	Prior to the calibration the thermocouple has been heat treated for a period of 12 hours at 500 °C. The thermocouple has been calibrated in liquid bath's, with a minimum immersion depth of 200 mm, by comparison with a standard thermometer. The cold junction has been realised by using an ice bath.
Period of Calibration	:	The laboratory temperature was conditioned at 23 °C ± 2 °C. 10-08-2015 to 19-08-2015
Results	:	The results are specified at the attached sheet(s) The table indicates : 1 The serial number / tag number; 2 The temperature t90 defined according the ITS-90; 3 The microvolt value Et as per the relevant tables at t90 according IEC 60584-1 (2013); 4 The actual measured microvolt value E; 5 The deviation in microvolt; 6 The deviation in °C; 7 The expanded uncertainty in °C.
Uncertainty	:	The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which for a normal distribution corresponds to a coverage probability of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	:	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	:	24 August 2015

ing. H.T.V. Do
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page 2 of 4

Number: R15167

Tag No.	Temperature [°C]	Tabel Value [µV]	Measured Value [µV]	Deviation		Expanded Uncertainty [°C]
				[µV]	[°C]	
R15167-1	50,0	2023,08	2056,99	33,91	0,82	1,3
	150,0	6138,34	6207,80	69,45	1,72	
	250,0	10153,37	10250,99	97,62	2,40	
	350,0	14293,15	14411,56	118,41	2,83	
	450,0	18515,81	18647,62	131,82	3,10	
R15167-2	50,0	2023,08	2057,87	34,79	0,84	1,1
	150,0	6138,34	6209,33	70,99	1,76	
	250,0	10153,37	10252,43	99,06	2,43	
	350,0	14293,15	14412,15	119,00	2,84	
	450,0	18515,81	18646,61	130,81	3,08	
R15167-3	50,0	2023,08	2056,05	32,98	0,80	1,2
	150,0	6138,34	6204,64	66,29	1,65	
	250,0	10153,37	10246,92	93,55	2,30	
	350,0	14293,15	14407,89	114,74	2,74	
	450,0	18515,81	18645,68	129,87	3,06	
R15167-4	50,0	2023,08	2058,08	35,00	0,85	1,3
	150,0	6138,34	6211,48	73,14	1,82	
	250,0	10153,37	10257,39	104,02	2,56	
	350,0	14293,15	14420,78	127,64	3,05	
	450,0	18515,81	18659,79	143,99	3,39	
R15167-5	50,0	2023,08	2058,06	34,98	0,85	1,1
	150,0	6138,34	6208,35	70,00	1,74	
	250,0	10153,37	10248,20	94,83	2,33	
	350,0	14293,15	14402,62	109,47	2,61	
	450,0	18515,81	18629,72	113,91	2,68	
R15167-6	50,0	2023,08	2056,61	33,53	0,81	1,2
	150,0	6138,34	6207,02	68,68	1,71	
	250,0	10153,37	10251,19	97,82	2,40	
	350,0	14293,15	14414,10	120,95	2,89	
	450,0	18515,81	18653,88	138,07	3,25	
R15167-7	50,0	2023,08	2057,34	34,26	0,83	1,4
	150,0	6138,34	6209,55	71,20	1,77	
	250,0	10153,37	10252,53	99,17	2,44	
	350,0	14293,15	14411,30	118,16	2,82	
	450,0	18515,81	18643,98	128,17	3,02	
R15167-8	50,0	2023,08	2058,27	35,19	0,85	1,1
	150,0	6138,34	6213,04	74,69	1,85	
	250,0	10153,37	10258,50	105,13	2,58	
	350,0	14293,15	14419,66	126,51	3,02	
	450,0	18515,81	18654,62	138,82	3,27	
R15167-9	50,0	2023,08	2057,90	34,82	0,84	1
	150,0	6138,34	6211,90	73,56	1,83	
	250,0	10153,37	10256,76	103,39	2,54	
	350,0	14293,15	14417,45	124,31	2,97	
	450,0	18515,81	18652,12	136,31	3,21	



Calibration Certificate

Page 3 of 4

Number: R15167

Tag No.	Temperature [°C]	Tabel Value [µV]	Measured Value [µV]	Deviation		Expanded Uncertainty [°C]
				[µV]	[°C]	
R15167-10	50,0	2023,08	2058,31	35,23	0,85	1,1
	150,0	6138,34	6212,21	73,86	1,83	
	250,0	10153,37	10255,21	101,84	2,50	
	350,0	14293,15	14412,32	119,17	2,84	
	450,0	18515,81	18641,66	125,85	2,96	
R15167-11	50,0	2023,08	2058,11	35,03	0,85	1,1
	150,0	6138,34	6211,40	73,06	1,81	
	250,0	10153,37	10254,68	101,31	2,49	
	350,0	14293,15	14412,94	119,79	2,86	
	450,0	18515,81	18644,31	128,50	3,02	
R15167-12	50,0	2023,08	2057,08	34,00	0,82	1,2
	150,0	6138,34	6209,67	71,33	1,77	
	250,0	10153,37	10252,83	99,46	2,44	
	350,0	14293,15	14411,55	118,40	2,83	
	450,0	18515,81	18643,94	128,13	3,02	
R15167-13	50,0	2023,08	2058,22	35,14	0,85	1,1
	150,0	6138,34	6209,62	71,28	1,77	
	250,0	10153,37	10250,63	97,26	2,39	
	350,0	14293,15	14406,25	113,11	2,70	
	450,0	18515,81	18634,61	118,80	2,80	
R15167-14	50,0	2023,08	2058,85	35,77	0,87	1,1
	150,0	6138,34	6212,04	73,70	1,83	
	250,0	10153,37	10253,36	99,99	2,46	
	350,0	14293,15	14407,80	114,66	2,74	
	450,0	18515,81	18633,49	117,68	2,77	
R15167-15	50,0	2023,08	2057,56	34,48	0,84	1,2
	150,0	6138,34	6210,95	72,61	1,80	
	250,0	10153,37	10253,95	100,58	2,47	
	350,0	14293,15	14411,54	118,40	2,83	
	450,0	18515,81	18641,86	126,05	2,97	
R15167-16	50,0	2023,08	2055,94	32,86	0,80	1,1
	150,0	6138,34	6205,09	66,75	1,66	
	250,0	10153,37	10244,97	91,60	2,25	
	350,0	14293,15	14400,58	107,43	2,56	
	450,0	18515,81	18630,03	114,22	2,69	
R15167-17	50,0	2023,08	2056,78	33,70	0,82	1,1
	150,0	6138,34	6207,69	69,34	1,72	
	250,0	10153,37	10248,15	94,78	2,33	
	350,0	14293,15	14403,16	110,01	2,63	
	450,0	18515,81	18630,84	115,03	2,71	
R15167-18	50,0	2023,08	2056,42	33,34	0,81	1,1
	150,0	6138,34	6205,57	67,22	1,67	
	250,0	10153,37	10245,44	92,08	2,26	
	350,0	14293,15	14401,05	107,90	2,57	
	450,0	18515,81	18630,50	114,69	2,70	



Calibration Certificate

Page 4 of 4

Number: R15167

Tag No.	Temperature [°C]	Tabel Value [µV]	Measured Value [µV]	Deviation		Expanded Uncertainty [°C]
				[µV]	[°C]	
R15167-19	50,0	2023,08	2058,15	35,08	0,85	1
	150,0	6138,34	6211,50	73,16	1,82	
	250,0	10153,37	10253,10	99,74	2,45	
	350,0	14293,15	14407,96	114,81	2,74	
	450,0	18515,81	18634,19	118,38	2,79	
R15167-20	50,0	2023,08	2056,01	32,93	0,80	1,1
	150,0	6138,34	6204,81	66,47	1,65	
	250,0	10153,37	10245,01	91,64	2,25	
	350,0	14293,15	14401,58	108,43	2,59	
	450,0	18515,81	18632,65	116,85	2,75	
R15167-21	50,0	2023,08	2059,14	36,06	0,87	1,1
	150,0	6138,34	6215,64	77,30	1,92	
	250,0	10153,37	10261,05	107,68	2,65	
	350,0	14293,15	14420,35	127,20	3,04	
	450,0	18515,81	18651,66	135,86	3,20	
R15167-22	50,0	2023,08	2056,55	33,48	0,81	1,1
	150,0	6138,34	6209,35	71,01	1,76	
	250,0	10153,37	10253,82	100,45	2,47	
	350,0	14293,15	14414,96	121,81	2,91	
	450,0	18515,81	18650,89	135,08	3,18	



Page 1 of 4

CERTIFICATE
Number: R15168

Applicant	:	KEMA B.V. UTRECHTSEWEG 310 GEBOUW B08 – EXPEDITIE 6812 AR ARNHEM THE NETHERLANDS
Instrument Manufacturer	:	22 pcs. Thermocouples type K
Item no.	:	Thermo Electric Instrumentation B.V.
Serial number	:	9260543
Calibration Method	:	R15168-1 to -22
Environmental Conditions:	:	Prior to the calibration the thermocouple has been heat treated for a period of 12 hours at 500 °C. The thermocouple has been calibrated in liquid bath's, with a minimum immersion depth of 200 mm, by comparison with a standard thermometer. The cold junction has been realised by using an ice bath.
Period of Calibration	:	The laboratory temperature was conditioned at 23 °C ± 2 °C. 10-08-2015 to 20-08-2015
Results	:	The results are specified at the attached sheet(s) The table indicates : 1 The serial number / tag number; 2 The temperature t90 defined according the ITS-90; 3 The microvolt value Et as per the relevant tables at t90 according IEC 60584-1 (2013); 4 The actual measured microvolt value E; 5 The deviation in microvolt; 6 The deviation in °C; 7 The expanded uncertainty in °C.
Uncertainty	:	The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which for a normal distribution corresponds to a coverage probability of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	:	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	:	24 August 2015

ing. H.T.V. Do
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page 2 of 4

Number: R15168

Tag No.	Temperature [°C]	Tabel Value [µV]	Measured Value [µV]	Deviation		Expanded Uncertainty [°C]
				[µV]	[°C]	
R15168-1	50,0	2023,08	2058,90	35,83	0,87	1,6
	150,0	6138,34	6219,93	81,59	2,03	
	250,0	10153,37	10266,20	112,83	2,77	
	350,0	14293,15	14422,70	129,55	3,09	
	450,0	18515,81	18647,56	131,76	3,10	
R15168-2	50,0	2023,08	2059,33	36,25	0,88	1,6
	150,0	6138,34	6223,41	85,06	2,11	
	250,0	10153,37	10272,68	119,31	2,93	
	350,0	14293,15	14432,16	139,01	3,32	
	450,0	18515,81	18659,95	144,14	3,39	
R15168-3	50,0	2023,08	2057,10	34,03	0,82	1,5
	150,0	6138,34	6216,01	77,67	1,93	
	250,0	10153,37	10261,70	108,33	2,66	
	350,0	14293,15	14419,18	126,03	3,01	
	450,0	18515,81	18646,55	130,75	3,08	
R15168-4	50,0	2023,08	2058,95	35,87	0,87	1,5
	150,0	6138,34	6221,02	82,67	2,05	
	250,0	10153,37	10268,79	115,42	2,84	
	350,0	14293,15	14427,26	134,11	3,20	
	450,0	18515,81	18654,55	138,74	3,27	
R15168-5	50,0	2023,08	2059,04	35,96	0,87	1,5
	150,0	6138,34	6220,64	82,29	2,04	
	250,0	10153,37	10266,07	112,71	2,77	
	350,0	14293,15	14420,36	127,21	3,04	
	450,0	18515,81	18641,61	125,80	2,96	
R15168-6	50,0	2023,08	2059,73	36,65	0,89	1,9
	150,0	6138,34	6223,94	85,59	2,12	
	250,0	10153,37	10272,71	119,34	2,93	
	350,0	14293,15	14431,04	137,89	3,29	
	450,0	18515,81	18657,06	141,26	3,32	
R15168-7	50,0	2023,08	2058,96	35,88	0,87	1,5
	150,0	6138,34	6221,84	83,50	2,07	
	250,0	10153,37	10271,44	118,07	2,90	
	350,0	14293,15	14432,75	139,60	3,33	
	450,0	18515,81	18663,90	148,09	3,49	
R15168-8	50,0	2023,08	2060,52	37,45	0,91	1,5
	150,0	6138,34	6224,33	85,99	2,13	
	250,0	10153,37	10272,66	119,29	2,93	
	350,0	14293,15	14430,50	137,35	3,28	
	450,0	18515,81	18655,98	140,17	3,30	
R15168-9	50,0	2023,08	2060,09	37,02	0,90	1,3
	150,0	6138,34	6219,62	81,28	2,02	
	250,0	10153,37	10267,74	114,37	2,81	
	350,0	14293,15	14429,44	136,30	3,25	
	450,0	18515,81	18662,86	147,05	3,46	



Calibration Certificate

Page 3 of 4

Number: R15168

Tag No.	Temperature [°C]	Tabel Value [µV]	Measured Value [µV]	Deviation		Expanded Uncertainty [°C]
				[µV]	[°C]	
R15168-10	50,0	2023,08	2058,78	35,70	0,87	1,2
	150,0	6138,34	6214,66	76,32	1,89	
	250,0	10153,37	10259,99	106,62	2,62	
	350,0	14293,15	14419,74	126,59	3,02	
	450,0	18515,81	18652,05	136,24	3,21	
R15168-11	50,0	2023,08	2060,76	37,68	0,91	1,3
	150,0	6138,34	6220,54	82,20	2,04	
	250,0	10153,37	10267,88	114,51	2,81	
	350,0	14293,15	14427,77	134,62	3,21	
	450,0	18515,81	18658,34	142,53	3,35	
R15168-12	50,0	2023,08	2061,90	38,82	0,94	1,3
	150,0	6138,34	6221,37	83,02	2,06	
	250,0	10153,37	10266,00	112,63	2,77	
	350,0	14293,15	14420,80	127,65	3,05	
	450,0	18515,81	18643,88	128,07	3,01	
R15168-13	50,0	2023,08	2067,88	44,80	1,09	1,9
	150,0	6138,34	6225,03	86,69	2,15	
	250,0	10153,37	10251,58	98,21	2,41	
	350,0	14293,15	14372,51	79,36	1,89	
	450,0	18515,81	18545,94	30,13	0,71	
R15168-14	50,0	2023,08	2059,95	36,87	0,89	1,4
	150,0	6138,34	6218,71	80,37	2,00	
	250,0	10153,37	10265,19	111,82	2,75	
	350,0	14293,15	14424,38	131,23	3,13	
	450,0	18515,81	18654,41	138,60	3,26	
R15168-15	50,0	2023,08	2059,58	36,50	0,88	1,2
	150,0	6138,34	6217,03	78,68	1,95	
	250,0	10153,37	10263,06	109,69	2,69	
	350,0	14293,15	14422,67	129,52	3,09	
	450,0	18515,81	18653,99	138,18	3,25	
R15168-16	50,0	2023,08	2061,03	37,95	0,92	1,4
	150,0	6138,34	6216,84	78,49	1,95	
	250,0	10153,37	10259,83	106,47	2,62	
	350,0	14293,15	14415,02	121,87	2,91	
	450,0	18515,81	18640,51	124,71	2,93	
R15168-17	50,0	2023,08	2061,06	37,99	0,92	1,5
	150,0	6138,34	6219,08	80,74	2,00	
	250,0	10153,37	10266,20	112,83	2,77	
	350,0	14293,15	14427,43	134,28	3,20	
	450,0	18515,81	18660,87	145,06	3,41	
R15168-18	50,0	2023,08	2061,80	38,73	0,94	1,5
	150,0	6138,34	6221,45	83,11	2,06	
	250,0	10153,37	10269,18	115,81	2,84	
	350,0	14293,15	14429,99	136,84	3,27	
	450,0	18515,81	18662,00	146,20	3,44	



Calibration Certificate

Page 4 of 4

Number: R15168


Tag No.	Temperature [°C]	Tabel Value [μV]	Measured Value [μV]	Deviation		Expanded Uncertainty [°C]
				[μV]	[°C]	
R15168-19	50,0	2023,08	2059,67	36,60	0,89	1,3
	150,0	6138,34	6213,57	75,22	1,87	
	250,0	10153,37	10257,40	104,03	2,56	
	350,0	14293,15	14416,17	123,03	2,94	
	450,0	18515,81	18648,01	132,20	3,11	
R15168-20	50,0	2023,08	2062,99	39,91	0,97	1,6
	150,0	6138,34	6224,71	86,36	2,14	
	250,0	10153,37	10272,71	119,34	2,93	
	350,0	14293,15	14432,00	138,85	3,31	
	450,0	18515,81	18660,69	144,88	3,41	
R15168-21	50,0	2023,08	2060,82	37,75	0,92	1,3
	150,0	6138,34	6216,13	77,78	1,93	
	250,0	10153,37	10258,75	105,38	2,59	
	350,0	14293,15	14413,68	120,53	2,88	
	450,0	18515,81	18639,05	123,24	2,90	
R15168-22	50,0	2023,08	2061,50	38,42	0,93	1,4
	150,0	6138,34	6219,53	81,18	2,02	
	250,0	10153,37	10265,80	112,43	2,76	
	350,0	14293,15	14425,31	132,16	3,15	
	450,0	18515,81	18656,19	140,38	3,30	



Page 1 of 6

CERTIFICATE
Number: R15169

Applicant	:	KEMA B.V. UTRECHTSEWEG 310 GEBOUW B08 – EXPEDITIE 6812 AR ARNHEM THE NETHERLANDS
Instrument Manufacturer	:	30 pcs. Thermocouples type K
Item no.	:	Supplied by Customer (Used Thermocouples)
Serial number	:	----
Calibration Method	:	Prior to the calibration the thermocouple has been heat treated for a period of 5 hours at 650 °C. The thermocouple has been calibrated in liquid bath's, with a minimum immersion depth of 200 mm, by comparison with a standard thermometer. The cold junction has been realised by using an ice bath.
Environmental Conditions:		The laboratory temperature was conditioned at 23 °C ± 2 °C.
Period of Calibration	:	11-08-2015 to 20-08-2015
Results	:	The results are specified at the attached sheet(s) The table indicates : 1 The serial number / tag number; 2 The temperature t90 defined according the ITS-90; 3 The microvolt value Et as per the relevant tables at t90 according IEC 60584-1 (2013); 4 The actual measured microvolt value E; 5 The deviation in microvolt; 6 The deviation in °C; 7 The expanded uncertainty in °C.
Uncertainty	:	The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which for a normal distribution corresponds to a coverage probability of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	:	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	:	24 August 2015


ing. H.T.V. Do
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page 2 of 6

Number: R15169

Tag No.	Temperature [°C]	Tabel Value [μV]	Measured Value [μV]	Deviation		Expanded Uncertainty [°C]
				[μV]	[°C]	
3221	50,0	2023,08	2042,78	19,70	0,48	4,9
	150,0	6138,34	6163,76	25,41	0,63	
	250,0	10153,37	10187,21	33,84	0,83	
	350,0	14293,15	14338,14	44,99	1,07	
	450,0	18515,81	18574,66	58,86	1,39	
	550,0	22776,43	22851,87	75,44	1,77	
3222	50,0	2023,08	2042,22	19,14	0,46	4,3
	150,0	6138,34	6163,01	24,67	0,61	
	250,0	10153,37	10186,27	32,90	0,81	
	350,0	14293,15	14337,00	43,85	1,05	
	450,0	18515,81	18573,32	57,51	1,35	
	550,0	22776,43	22850,31	73,89	1,73	
3224	50,0	2023,08	2042,75	19,67	0,48	4,8
	150,0	6138,34	6164,63	26,29	0,65	
	250,0	10153,37	10188,28	34,91	0,86	
	350,0	14293,15	14338,70	45,55	1,09	
	450,0	18515,81	18574,01	58,21	1,37	
	550,0	22776,43	22849,30	72,87	1,71	
3228	50,0	2023,08	2039,59	16,51	0,40	4,8
	150,0	6138,34	6153,65	15,31	0,38	
	250,0	10153,37	10173,07	19,70	0,48	
	350,0	14293,15	14322,84	29,70	0,71	
	450,0	18515,81	18561,09	45,29	1,07	
	550,0	22776,43	22842,90	66,48	1,56	
3235	50,0	2023,08	2042,36	19,28	0,47	4,5
	150,0	6138,34	6162,66	24,32	0,60	
	250,0	10153,37	10184,78	31,42	0,77	
	350,0	14293,15	14333,72	40,57	0,97	
	450,0	18515,81	18567,59	51,78	1,22	
	550,0	22776,43	22841,48	65,05	1,53	
3241	50,0	2023,08	2041,43	18,35	0,44	1
	150,0	6138,34	6164,74	26,39	0,66	
	250,0	10153,37	10189,27	35,90	0,88	
	350,0	14293,15	14340,04	46,89	1,12	
	450,0	18515,81	18575,15	59,34	1,40	
	550,0	22776,43	22849,70	73,27	1,72	
3246	50,0	2023,08	2040,67	17,60	0,43	0,9
	150,0	6138,34	6161,70	23,36	0,58	
	250,0	10153,37	10185,02	31,65	0,78	
	350,0	14293,15	14335,62	42,47	1,01	
	450,0	18515,81	18571,62	55,82	1,31	
	550,0	22776,43	22848,12	71,69	1,68	



Calibration Certificate

Page 3 of 6

Number: R15169

Tag No.	Temperature [°C]	Tabel Value [µV]	Measured Value [µV]	Deviation		Expanded Uncertainty [°C]
				[µV]	[°C]	
3250	50,0	2023,08	2044,24	21,16	0,51	2,3
	150,0	6138,34	6171,44	33,09	0,82	
	250,0	10153,37	10197,83	44,46	1,09	
	350,0	14293,15	14348,43	55,28	1,32	
	450,0	18515,81	18581,35	65,54	1,54	
	550,0	22776,43	22851,67	75,24	1,76	
3253	50,0	2023,08	2040,70	17,62	0,43	1,1
	150,0	6138,34	6162,09	23,75	0,59	
	250,0	10153,37	10185,16	31,79	0,78	
	350,0	14293,15	14334,89	41,74	1,00	
	450,0	18515,81	18569,42	53,61	1,26	
	550,0	22776,43	22843,82	67,39	1,58	
3260	50,0	2023,08	2039,77	16,69	0,40	3,2
	150,0	6138,34	6158,90	20,55	0,51	
	250,0	10153,37	10181,29	27,92	0,69	
	350,0	14293,15	14331,94	38,79	0,93	
	450,0	18515,81	18568,98	53,17	1,25	
	550,0	22776,43	22847,48	71,05	1,67	
3267	50,0	2023,08	2040,40	17,32	0,42	1,6
	150,0	6138,34	6155,07	16,72	0,42	
	250,0	10153,37	10167,93	14,56	0,36	
	350,0	14293,15	14304,00	10,85	0,26	
	450,0	18515,81	18521,38	5,57	0,13	
	550,0	22776,43	22775,17	-1,26	-0,03	
3277	50,0	2023,08	2039,42	16,34	0,40	1,1
	150,0	6138,34	6153,17	14,82	0,37	
	250,0	10153,37	10165,58	12,21	0,30	
	350,0	14293,15	14301,66	8,51	0,20	
	450,0	18515,81	18519,52	3,71	0,09	
	550,0	22776,43	22774,25	-2,18	-0,05	
3280	50,0	2023,08	2046,68	23,60	0,57	2
	150,0	6138,34	6174,28	35,93	0,89	
	250,0	10153,37	10193,64	40,27	0,99	
	350,0	14293,15	14329,75	36,60	0,87	
	450,0	18515,81	18540,74	24,94	0,59	
	550,0	22776,43	22781,70	5,27	0,12	
3281	50,0	2023,08	2034,06	10,98	0,27	4,6
	150,0	6138,34	6133,22	-5,12	-0,13	
	250,0	10153,37	10139,58	-13,79	-0,34	
	350,0	14293,15	14278,13	-15,02	-0,36	
	450,0	18515,81	18507,00	-8,81	-0,21	
	550,0	22776,43	22781,27	4,85	0,11	



Calibration Certificate

Page 4 of 6

Number: R15169

Tag No.	Temperature [°C]	Tabel Value [μV]	Measured Value [μV]	Deviation		Expanded Uncertainty [°C]
				[μV]	[°C]	
3286	50,0	2023,08	2033,29	10,21	0,25	2
	150,0	6138,34	6134,93	-3,41	-0,08	
	250,0	10153,37	10141,99	-11,38	-0,28	
	350,0	14293,15	14279,47	-13,68	-0,33	
	450,0	18515,81	18505,49	-10,32	-0,24	
	550,0	22776,43	22775,13	-1,30	-0,03	
3288	50,0	2023,08	2036,31	13,23	0,32	2,8
	150,0	6138,34	6142,55	4,21	0,10	
	250,0	10153,37	10150,16	-3,21	-0,08	
	350,0	14293,15	14284,13	-9,02	-0,22	
	450,0	18515,81	18502,60	-13,21	-0,31	
	550,0	22776,43	22760,63	-15,79	-0,37	
3298	50,0	2023,08	2037,48	14,40	0,35	4,2
	150,0	6138,34	6140,46	2,12	0,05	
	250,0	10153,37	10146,90	-6,47	-0,16	
	350,0	14293,15	14281,81	-11,34	-0,27	
	450,0	18515,81	18503,30	-12,51	-0,29	
	550,0	22776,43	22766,46	-9,97	-0,23	
3300	50,0	2023,08	2031,02	7,94	0,19	2,8
	150,0	6138,34	6124,15	-14,19	-0,35	
	250,0	10153,37	10125,58	-27,79	-0,68	
	350,0	14293,15	14260,31	-32,84	-0,78	
	450,0	18515,81	18486,46	-29,35	-0,69	
	550,0	22776,43	22759,11	-17,32	-0,41	
3301	50,0	2023,08	2042,96	19,89	0,48	0,9
	150,0	6138,34	6163,23	24,88	0,62	
	250,0	10153,37	10177,64	24,27	0,60	
	350,0	14293,15	14311,19	18,04	0,43	
	450,0	18515,81	18522,01	6,20	0,15	
	550,0	22776,43	22765,18	-11,25	-0,26	
3302	50,0	2023,08	2037,74	14,66	0,36	0,8
	150,0	6138,34	6150,40	12,06	0,30	
	250,0	10153,37	10163,94	10,57	0,26	
	350,0	14293,15	14303,36	10,21	0,24	
	450,0	18515,81	18526,78	10,98	0,26	
	550,0	22776,43	22789,29	12,86	0,30	
3306	50,0	2023,08	2046,62	23,54	0,57	1,4
	150,0	6138,34	6172,92	34,58	0,86	
	250,0	10153,37	10191,02	37,65	0,92	
	350,0	14293,15	14325,92	32,77	0,78	
	450,0	18515,81	18535,74	19,93	0,47	
	550,0	22776,43	22775,57	-0,86	-0,02	



Calibration Certificate

Page 5 of 6

Number: R15169

Tag No.	Temperature [°C]	Tabel Value [μV]	Measured Value [μV]	Deviation		Expanded Uncertainty [°C]
				[μV]	[°C]	
3309	50,0	2023,08	2043,40	20,32	0,49	1,1
	150,0	6138,34	6166,12	27,78	0,69	
	250,0	10153,37	10184,61	31,24	0,77	
	350,0	14293,15	14323,86	30,71	0,73	
	450,0	18515,81	18541,99	26,19	0,62	
	550,0	22776,43	22794,09	17,66	0,41	
3313	50,0	2023,08	2044,04	20,96	0,51	1
	150,0	6138,34	6167,91	29,57	0,73	
	250,0	10153,37	10187,17	33,80	0,83	
	350,0	14293,15	14326,80	33,65	0,80	
	450,0	18515,81	18544,94	29,13	0,69	
	550,0	22776,43	22796,67	20,24	0,47	
3314	50,0	2023,08	2044,73	21,65	0,52	1,6
	150,0	6138,34	6168,57	30,22	0,75	
	250,0	10153,37	10188,36	34,99	0,86	
	350,0	14293,15	14329,11	35,96	0,86	
	450,0	18515,81	18548,94	33,13	0,78	
	550,0	22776,43	22802,93	26,50	0,62	
3315	50,0	2023,08	2039,88	16,80	0,41	1,3
	150,0	6138,34	6157,80	19,46	0,48	
	250,0	10153,37	10176,10	22,73	0,56	
	350,0	14293,15	14319,78	26,63	0,64	
	450,0	18515,81	18546,96	31,15	0,73	
	550,0	22776,43	22812,72	36,29	0,85	
3316	50,0	2023,08	2040,69	17,61	0,43	0,8
	150,0	6138,34	6157,99	19,65	0,49	
	250,0	10153,37	10174,23	20,86	0,51	
	350,0	14293,15	14314,40	21,25	0,51	
	450,0	18515,81	18536,62	20,82	0,49	
	550,0	22776,43	22795,98	19,55	0,46	
3317	50,0	2023,08	2042,05	18,97	0,46	0,8
	150,0	6138,34	6161,06	22,72	0,56	
	250,0	10153,37	10177,60	24,24	0,60	
	350,0	14293,15	14316,67	23,52	0,56	
	450,0	18515,81	18536,39	20,59	0,48	
	550,0	22776,43	22791,85	15,42	0,36	
3318	50,0	2023,08	2040,27	17,20	0,42	0,8
	150,0	6138,34	6157,06	18,72	0,46	
	250,0	10153,37	10173,60	20,23	0,50	
	350,0	14293,15	14314,87	21,72	0,52	
	450,0	18515,81	18539,02	23,21	0,55	
	550,0	22776,43	22801,11	24,69	0,58	



Calibration Certificate

Page 6 of 6

Number: R15169


Tag No.	Temperature [°C]	Tabel Value [µV]	Measured Value [µV]	Deviation		Expanded Uncertainty [°C]
				[µV]	[°C]	
3319	50,0	2023,08	2041,43	18,36	0,45	0,8
	150,0	6138,34	6160,54	22,20	0,55	
	250,0	10153,37	10178,43	25,06	0,62	
	350,0	14293,15	14320,09	26,94	0,64	
	450,0	18515,81	18543,64	27,83	0,66	
	550,0	22776,43	22804,18	27,75	0,65	
3320	50,0	2023,08	2041,83	18,76	0,45	0,8
	150,0	6138,34	6162,57	24,22	0,60	
	250,0	10153,37	10181,58	28,21	0,69	
	350,0	14293,15	14323,88	30,73	0,73	
	450,0	18515,81	18547,58	31,77	0,75	
	550,0	22776,43	22807,77	31,34	0,74	



CERTIFICATE
Number: R15206

Page 1 of 2

Applicant	:	KEMA B.V. UTRECHTSEWEG 310 GEBOUW B08 – EXPEDITIE 6812 AR ARNHEM THE NETHERLANDS
Instrument Manufacturer	:	8 pcs. Thermocouples type K
Item no.	:	Thermo Electric Instrumentation B.V.
Serial number	:	9410268
Calibration Method	:	R15206-1 to -8
Environmental Conditions:	:	Prior to the calibration the thermocouple has been heat treated for a period of 12 hours at 500 °C. The thermocouple has been calibrated in a tube type furnace, with an immersion depth of 360 mm by comparison with a standard thermometer. The cold junction has been realised by using an ice bath.
Period of Calibration	:	The laboratory temperature was conditioned at 23 °C ± 2 °C. 15-10-2015 to 16-10-2015
Results	:	The results are specified at the attached sheet(s) The table indicates : 1 The serial number / tag number; 2 The temperature t90 defined according the ITS-90; 3 The microvolt value Et as per the relevant tables at t90 according IEC 60584-1 (2013); 4 The actual measured microvolt value E; 5 The deviation in microvolt; 6 The deviation in °C; 7 The expanded uncertainty in °C.
Uncertainty	:	The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which for a normal distribution corresponds to a coverage probability of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	:	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	:	19 October 2015


ing. H.T.V. Do
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page 2 of 2

Number: R15206


Tag No.	Temperature [°C]	Tabel Value [µV]	Measured Value [µV]	Deviation		Expanded Uncertainty [°C]
				[µV]	[°C]	
R15206-1	250,0	10153,37	10235,00	81,63	2,01	1,7
	350,0	14293,15	14379,97	86,83	2,07	
	450,0	18515,81	18596,36	80,55	1,90	
R15206-2	250,0	10153,37	10233,72	80,35	1,97	1,9
	350,0	14293,15	14372,39	79,24	1,89	
	450,0	18515,81	18579,07	63,26	1,49	
R15206-3	250,0	10153,37	10225,53	72,16	1,77	1,9
	350,0	14293,15	14367,28	74,13	1,77	
	450,0	18515,81	18580,62	64,81	1,53	
R15206-4	250,0	10153,37	10231,68	78,31	1,92	1,6
	350,0	14293,15	14371,11	77,96	1,86	
	450,0	18515,81	18579,67	63,87	1,50	
R15206-5	250,0	10153,37	10237,29	83,92	2,06	1,8
	350,0	14293,15	14375,41	82,27	1,96	
	450,0	18515,81	18580,36	64,55	1,52	
R15206-6	250,0	10153,37	10220,64	67,27	1,65	1,7
	350,0	14293,15	14357,52	64,37	1,54	
	450,0	18515,81	18564,31	48,50	1,14	
R15206-7	250,0	10153,37	10227,44	74,07	1,82	1,8
	350,0	14293,15	14367,30	74,16	1,77	
	450,0	18515,81	18577,24	61,44	1,45	
R15206-8	250,0	10153,37	10230,03	76,66	1,88	1,7
	350,0	14293,15	14372,45	79,30	1,89	
	450,0	18515,81	18585,75	69,94	1,65	



CERTIFICATE
Number: R15207

Page 1 of 2

Applicant	:	KEMA B.V. UTRECHTSEWEG 310 GEBOUW B08 – EXPEDITIE 6812 AR ARNHEM THE NETHERLANDS
Instrument Manufacturer	:	8 pcs. Thermocouples type K
Item no.	:	Thermo Electric Instrumentation B.V.
Serial number	:	9215974
Calibration Method	:	R15207-1 to -8
Environmental Conditions:	:	Prior to the calibration the thermocouple has been heat treated for a period of 12 hours at 500 °C. The thermocouple has been calibrated in a tube type furnace, with an immersion depth of 360 mm by comparison with a standard thermometer. The cold junction has been realised by using an ice bath.
Period of Calibration	:	The laboratory temperature was conditioned at 23 °C ± 2 °C. 15-10-2015 to 16-10-2015
Results	:	The results are specified at the attached sheet(s) The table indicates : 1 The serial number / tag number; 2 The temperature t90 defined according the ITS-90; 3 The microvolt value Et as per the relevant tables at t90 according IEC 60584-1 (2013); 4 The actual measured microvolt value E; 5 The deviation in microvolt; 6 The deviation in °C; 7 The expanded uncertainty in °C.
Uncertainty	:	The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which for a normal distribution corresponds to a coverage probability of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	:	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	:	19 October 2015


ing. H.T.V. Do
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page 2 of 2

Number: R15207


Tag No.	Temperature [°C]	Tabel Value [µV]	Measured Value [µV]	Deviation		Expanded Uncertainty [°C]
				[µV]	[°C]	
R15207-1	250,0	10153,37	10246,05	92,69	2,28	1,6
	350,0	14293,15	14392,80	99,65	2,38	
	450,0	18515,81	18609,54	93,73	2,21	
R15207-2	250,0	10153,37	10249,07	95,70	2,35	1,5
	350,0	14293,15	14392,72	99,57	2,38	
	450,0	18515,81	18603,80	88,00	2,07	
R15207-3	250,0	10153,37	10247,66	94,29	2,32	1,6
	350,0	14293,15	14391,59	98,44	2,35	
	450,0	18515,81	18603,37	87,56	2,06	
R15207-4	250,0	10153,37	10238,02	84,65	2,08	1,5
	350,0	14293,15	14382,25	89,10	2,13	
	450,0	18515,81	18596,95	81,14	1,91	
R15207-5	250,0	10153,37	10244,11	90,74	2,23	1,6
	350,0	14293,15	14388,96	95,81	2,29	
	450,0	18515,81	18603,06	87,25	2,05	
R15207-6	250,0	10153,37	10249,31	95,94	2,36	1,5
	350,0	14293,15	14396,40	103,25	2,46	
	450,0	18515,81	18612,92	97,12	2,29	
R15207-7	250,0	10153,37	10247,94	94,57	2,32	1,7
	350,0	14293,15	14394,13	100,98	2,41	
	450,0	18515,81	18609,41	93,60	2,20	
R15207-8	250,0	10153,37	10245,87	92,50	2,27	1,8
	350,0	14293,15	14393,00	99,85	2,38	
	450,0	18515,81	18610,17	94,36	2,22	



CERTIFICATE
Number: R15208

Page 1 of 2

Applicant	:	KEMA B.V. UTRECHTSEWEG 310 GEBOUW B08 – EXPEDITIE 6812 AR ARNHEM THE NETHERLANDS
Instrument Manufacturer	:	8 pcs. Thermocouples type K
Item no.	:	Thermo Electric Instrumentation B.V.
Serial number	:	9222233
Calibration Method	:	R15208-1 to -8
Environmental Conditions:	:	Prior to the calibration the thermocouple has been heat treated for a period of 12 hours at 500 °C. The thermocouple has been calibrated in a tube type furnace, with an immersion depth of 360 mm by comparison with a standard thermometer. The cold junction has been realised by using an ice bath.
Period of Calibration	:	The laboratory temperature was conditioned at 23 °C ± 2 °C. 15-10-2015 to 16-10-2015
Results	:	The results are specified at the attached sheet(s) The table indicates : 1 The serial number / tag number; 2 The temperature t90 defined according the ITS-90; 3 The microvolt value Et as per the relevant tables at t90 according IEC 60584-1 (2013); 4 The actual measured microvolt value E; 5 The deviation in microvolt; 6 The deviation in °C; 7 The expanded uncertainty in °C.
Uncertainty	:	The reported uncertainty is based on the standard uncertainty multiplied by a coverage factor of $k = 2$, which for a normal distribution corresponds to a coverage probability of approximately 95 %. The standard uncertainty has been determined in accordance with EA-4/02.
Traceability	:	The measurements have been executed using standards for which the traceability to (inter)national standards has been demonstrated towards the RvA.
Date	:	19 October 2015


ing. H.T.V. Do
Sr. Calibration Engineer

| Coenecoop 71-73 | 2741 PH | P.O. Box 85 | 2740 AB | Waddinxveen | The Netherlands
| t. +31 [0] 85 760 73 00 | e. info@te-instrumentation.com
| www.te-instrumentation.com
| CoC 59410205 | VAT NL8534.67.961.B01

Reproduction of the complete certificate is allowed. Parts of the certificate may only be reproduced with written approval of the calibration laboratory.
This certificate is issued with reservation that the Dutch Council for Accreditation RvA does not assume any liability. RvA is one of the signatories to the EA Multilateral Agreement and to the ILAC Mutual Recognition Arrangements (MRA) for the mutual recognition of calibration certificates.



Calibration Certificate

Page 2 of 2

Number: R15208

Tag No.	Temperature [°C]	Tabel Value [µV]	Measured Value [µV]	Deviation		Expanded Uncertainty [°C]
				[µV]	[°C]	
R15208-1	250,0	10153,37	10257,25	103,88	2,55	1,5
	350,0	14293,15	14400,71	107,56	2,57	
	450,0	18515,81	18609,49	93,69	2,20	
R15208-2	250,0	10153,37	10260,66	107,29	2,64	1,6
	350,0	14293,15	14409,37	116,22	2,77	
	450,0	18515,81	18625,54	109,74	2,58	
R15208-3	250,0	10153,37	10254,46	101,09	2,48	1,5
	350,0	14293,15	14400,66	107,51	2,57	
	450,0	18515,81	18614,34	98,53	2,32	
R15208-4	250,0	10153,37	10222,35	68,98	1,69	1,6
	350,0	14293,15	14357,96	64,81	1,55	
	450,0	18515,81	18562,51	46,70	1,10	
R15208-5	250,0	10153,37	10268,15	114,78	2,82	1,6
	350,0	14293,15	14418,83	125,68	3,00	
	450,0	18515,81	18636,29	120,48	2,84	
R15208-6	250,0	10153,37	10236,51	83,15	2,04	1,5
	350,0	14293,15	14380,89	87,74	2,09	
	450,0	18515,81	18595,83	80,02	1,88	
R15208-7	250,0	10153,37	10266,53	113,17	2,78	1,7
	350,0	14293,15	14420,68	127,53	3,04	
	450,0	18515,81	18644,09	128,29	3,02	
R15208-8	250,0	10153,37	10251,74	98,37	2,42	1,6
	350,0	14293,15	14395,70	102,55	2,45	
	450,0	18515,81	18606,37	90,56	2,13	



APPENDIX A4

AES Calibration Certificates

PowerLogic™

Certificate of Compliance and Calibration

Schneider Electric certifies that the PowerLogic product listed below meets the published specifications and has been calibrated and tested using equipment and standards traceable to the National Institute of Standards and Technology (NIST) in the US or the National Research Council of Canada (NRC).

Model	Part #	Serial #	Calibration Date
ION8600	P8600B4C0H5E0B0B	PT-0807A565-01	01-Aug-2008
AUTOMATED TESTING	<ul style="list-style-type: none">• Power supply levels tested and adjusted on variable power supply units• Communications verified• Unit ID and serial number programmed• Voltage and current inputs calibrated• Aux I/O calibrated and tested (if applicable)• Required software options programmed• Calibration constants saved to external file (if applicable)		
FINAL TESTING AND INSPECTION	<ul style="list-style-type: none">• Serial number verified• Firmware version verified• LCD/Keypad functionality checked (if applicable)• Memory checked• Calibration verified• Software options downloaded and verified (if applicable)• Applicable counters and registers cleared• Dielectric Withstand Test Passed		
TEST EQUIPMENT USED TO CALIBRATE METER (If Applicable)	Model	Serial #	Test Equipment Calibration Due Date
	HP 3458A Rotek 8000 BC Rotek 8000 A	2823A06876 133BC 133	21-Dec-2008 23-Nov-2008 23-Nov-2008
 Alexander Stoettner Quality Manager		 Jennifer Jacques Plant Manager	

Quality System
Certified to ISO 9001

Schneider
Electric


PowerLogic is a trademark of Schneider Electric.



APPENDIX B

Correction Curves


AMBIENT AIR TEMPERATURE CORRECTION
FOR BOILER EFFICIENCY
(COAL FIRING)



MOISTURE IN AIR CORRECTION

FOR BOILER EFFICIENCY


(COAL FIRING)



CONDENSER VACUUM CORRECTION

TO

HEAT RATE



JIS A4 180 · 250 mm

SEKIPESI NO 401 C

NUEVA TOCOPILLA UNIT-1


156500 KVA, 133025 KW, 85.00 % PF, 50 HZ, 3000 RPM

13.8 KV, 6547 A, 2 KG/CM² GAS PRESS., 295 V EXC.

HYDROGEN-COOLED TURBINE GENERATOR

EFFICIENCY CORRECTION CURVE

EFFICIENCY AT 85.00 % PF CAN BE ESTIMATED BY ADDING EFFICIENCY
DIFFERENCE VALUE TO EFFICIENCY AT A CERTAIN POWER FACTOR.



APPROVED	M. Nakamura M. Sakurai
CHECKED	H. Ohishi
DESIGNED	1994-4-13 A. Yoshii

KC494985



APPENDIX C

Results Analysis Coal, Bottom Ash and Fly Ash

APPENDIX C1

Results Analysis Coal, Bottom and Fly Ash Test at 100% Load



PCM Ltda.
Laboratorio de Combustibles
Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.tie.cl
Padre Orellana 1421 - Santiago
Certificada bajo los Estándares de la Norma ISO 9001-2008
En proceso de Implementación de la Norma Nch ISO 17025-2005

ISO 9001-2008
Nro Certificado: 3774 – Año 2008
Bureau Veritas

INFORME DE ANÁLISIS N° NG- 3837

Santiago, 20 de enero de 2016

Documento 36354

O.C. Cliente Pendiente

INFORMACIÓN DEL CLIENTE

Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com

IDENTIFICACIÓN DE LA MUESTRA

Fecha Recepción	13/01/2016	Fecha de Muestreo	15 de Diciembre 2015 09:00 Till 11:00 h
ID PCM	36676	Tipo de Muestra	Carbón
ID Cliente	Carbón NT-02 C.E.N. (Prueba 1; 136 MWe)	Fecha Análisis	20/01/2016
Representatividad	ND	Lugar de Muestreo	Unidad 2

RESULTADOS DEL ANÁLISIS

Parámetro	NORMA	Como Recibido	Base Seca
Humedad Total (%)	ASTM D 3302	18,62	
Humedad Residual (%)	ASTM D 3173 /7582	9,38	
Cenizas (%)	ASTM D 3174 /7582	5,77	7,10
Materia Volátil (%)	ASTM D 3175 /7582	32,96	40,50
Carbono Fijo (%)	ASTM D 3172	42,64	52,40
Azufre(%)	ASTM D 4239	0,41	0,50
Poder Calorífico Superior (kcal/kg)	ASTM D 5865	5.632	6.921
Poder Calorífico Inferior (kcal/kg)	ASTM D 5865	5.334	6.687
Carbono (%)	ASTM D 5373	59,08	72,61
Hidrógeno (%)	ASTM D 5373	3,70	4,54
Nitrógeno (%)	ASTM D 5373	0,94	1,15
Oxígeno (%)	ASTM D 3180	11,48	14,10

OBSERVACIONES :

La muestra fue preparada en PCM.
El Hidrógeno y Oxígeno reportados en base "Como Recibido" no incluyen el contenido de éstos elementos en el agua.

Responsable Verificación

Responsable Aprobación

Consuelo Araya C.
Jefe de Laboratorio

Ernesto Pérez de Arce G.
Gerente General

- NOTAS
- Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante.
 - El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda.
 - Las opiniones e interpretaciones de los resultados se realizarán sólo en el caso que el cliente lo solicite formalmente.
 - En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo.
 - En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente.
 - El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.

Hoja 1 de 1



PCM Ltda.
Laboratorio de Combustibles
Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.cl
Padre Orellana 1421 - Santiago
Certificada bajo los Estándares de la Norma ISO 9001-2008
En proceso de Implementación de la Norma Nch ISO 17025-2005

ISO 9001-2008
Nro Certificado: 3774 – Año 2008
Bureau Veritas

INFORME DE ANÁLISIS Nº NG- 3831

Santiago, 19 de enero de 2016

# Documento	36348
# O.C. Cliente:	Pendiente

INFORMACIÓN DEL CLIENTE

Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com

IDENTIFICACIÓN DE LA MUESTRA

Fecha Recepción	13/01/2016	Fecha de Muestreo	15 de Diciembre 2015 09:00 Till 11:00 h
ID PCM	36670	Tipo de Muestra	Carbón
ID Cliente	Carbón NT-02 C.E.N. (Prueba 1; 136 MWe) Humedad	Fecha Análisis	18/01/2016
Representatividad	ND	Lugar de Muestreo	Unidad 2

RESULTADOS DEL ANÁLISIS

Parámetro	NORMA	Como Recibido	Base Seca
Humedad Total (%)	ASTM D 3302	18,88	
Humedad Residual (%)	ASTM D 3173 /7582	9,85	

OBSERVACIONES :

La muestra fue preparada en PCM.

Responsable Verificación

Responsable Aprobación

Consuelo Araya C.
Jefe de Laboratorio

Ernesto Pérez de Arce G.
Gerente General

1. Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante.

2. El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda.

3. Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente.

- 4.- En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo.

- 5.- En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente.

- 6.- El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.

NOTAS

Hoja 1 de 1



PCM Ltda.
Laboratorio de Combustibles
Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.cl
Padre Orellana 1421 - Santiago
Certificada bajo los Estándares de la Norma ISO 9001-2008
En proceso de Implementación de la Norma Nch ISO 17025-2005

ISO 9001-2008
Nro Certificado: 3774 – Año 2008
Bureau Veritas

INFORME DE ANÁLISIS Nº NG- 3849

Santiago, 19 de enero de 2016

# Documento	36366
# O.C. Cliente:	Pendiente

INFORMACIÓN DEL CLIENTE

Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com

IDENTIFICACIÓN DE LA MUESTRA

Fecha Recepción	13/01/2016	Fecha de Muestreo	15 de Diciembre 2015 09:00 Till 11:00 h
ID PCM	36688	Tipo de Muestra	Escoria
ID Cliente	BOTTOM-ASH NT-02 C.E.N. (Prueba 1; 136MWe)	Fecha Análisis	19/01/2016
Representatividad	ND	Lugar de Muestreo	Unidad 2

RESULTADOS DEL ANÁLISIS

Parámetro	NORMA	Como Recibido	Base Seca
Humedad Total (%)	ASTM D 3302	53,73	
Humedad Residual (%)	ASTM D 3173 /7582	1,13	
LOI (%)	ASTM D 7348	4,07	8,80

OBSERVACIONES :

La muestra fue preparada en PCM.

Responsable Verificación

Responsable Aprobación

Consuelo Araya C.
Jefe de Laboratorio

Ernesto Pérez de Arce G.
Gerente General

1. Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante.

2. El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda.

3. Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente.

- 4.- En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo.

- 5.- En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente.

- 6.- El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.

NOTAS

Hoja 1 de 1



PCM Ltda.
Laboratorio de Combustibles
Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.cl
Padre Orellana 1421 - Santiago
Certificada bajo los Estándares de la Norma ISO 9001-2008
En proceso de Implementación de la Norma Nch ISO 17025-2005

ISO 9001-2008
Nro Certificado: 3774 – Año 2008
Bureau Veritas

INFORME DE ANÁLISIS

Nº NG- 3843

Santiago, 18 de enero de 2016

# Documento	36360
# O.C. Cliente:	Pendiente

INFORMACIÓN DEL CLIENTE

Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com

IDENTIFICACIÓN DE LA MUESTRA

Fecha Recepción	13/01/2016	Fecha de Muestreo	15 de Diciembre 2015 09:00 Till 11:00 h
ID PCM	36682	Tipo de Muestra	Ceniza
ID Cliente	FLY-ASH NT-02 C.E.N. (Prueba 1; 136 MWe)	Fecha Análisis	18/01/2016
Representatividad	ND	Lugar de Muestreo	Unidad 2

RESULTADOS DEL ANÁLISIS

Parámetro	NORMA	Como Recibido	Base Seca
Humedad Total (%)	ASTM D 3302	0,25	
Humedad Residual (%)	ASTM D 3173 /7582	< 0,27	
LOI (%)	ASTM D 7348	2,58	2,59

OBSERVACIONES :

La muestra fue preparada en PCM.

Responsable Verificación

Consuelo Araya C.
Jefe de Laboratorio



Responsable Aprobación

Ernesto Pérez de Arce G.
Gerente General

NOTAS

1. Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante.
2. El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda.
3. Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente.
- 4.- En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo.
- 5.- En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente.
- 6.- El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.

Hoja 1 de 1

APPENDIX C2

Results Analysis Coal, Bottom and Fly Ash Test at 95% Load



PCM Ltda.
Laboratorio de Combustibles
Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.tie.cl
Padre Orellana 1421 - Santiago
Certificada bajo los Estándares de la Norma ISO 9001-2008
En proceso de Implementación de la Norma Nch ISO 17025-2005

ISO 9001-2008
Nro Certificado: 3774 – Año 2008
Bureau Veritas

INFORME DE ANÁLISIS N° NG- 3838

Santiago, 20 de enero de 2016

# Documento	36355
# O.C. Cliente:	Pendiente

INFORMACIÓN DEL CLIENTE

Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com

IDENTIFICACIÓN DE LA MUESTRA

Fecha Recepción	13/01/2016	Fecha de Muestreo	16 de Diciembre 2015 09:00 Till 11:00 h
ID PCM	36677	Tipo de Muestra	Carbón
ID Cliente	Carbón NT-02 C.E.N. (Prueba 1; 129,2 MWe)	Fecha Análisis	20/01/2016
Representatividad	ND	Lugar de Muestreo	Unidad 2

RESULTADOS DEL ANÁLISIS

Parámetro	NORMA	Como Recibido	Base Seca
Humedad Total (%)	ASTM D 3302	18,98	
Humedad Residual (%)	ASTM D 3173 /7582	9,70	
Cenizas (%)	ASTM D 3174 /7582	5,66	6,99
Materia Volátil (%)	ASTM D 3175 /7582	33,00	40,73
Carbono Fijo (%)	ASTM D 3172	42,36	52,28
Azufre(%)	ASTM D 4239	0,42	0,52
Poder Calorífico Superior (kcal/kg)	ASTM D 5865	5.640	6.962
Poder Calorífico Inferior (kcal/kg)	ASTM D 5865	5.340	6.726
Carbono (%)	ASTM D 5373	59,26	73,15
Hidrógeno (%)	ASTM D 5373	3,71	4,57
Nitrógeno (%)	ASTM D 5373	0,95	1,17
Oxígeno (%)	ASTM D 3180	11,02	13,60

OBSERVACIONES :

La muestra fue preparada en PCM.
El Hidrógeno y Oxígeno reportados en base "Como Recibido" no incluyen el contenido de éstos elementos en el agua.

Responsable Verificación

Responsable Aprobación

Consuelo Araya C.
Jefe de Laboratorio

Ernesto Pérez de Arce G.
Gerente General

- NOTAS
- Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante.
 - El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda.
 - Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente.
 - En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo.
 - En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente.
 - El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.

Hoja 1 de 1



PCM Ltda.
Laboratorio de Combustibles
Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.cl
Padre Orellana 1421 - Santiago
Certificada bajo los Estándares de la Norma ISO 9001-2008
En proceso de Implementación de la Norma Nch ISO 17025-2005

ISO 9001-2008
Nro Certificado: 3774 – Año 2008
Bureau Veritas

INFORME DE ANÁLISIS Nº NG- 3832

Santiago, 19 de enero de 2016

# Documento	36349
# O.C. Cliente:	Pendiente

INFORMACIÓN DEL CLIENTE

Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com

IDENTIFICACIÓN DE LA MUESTRA

Fecha Recepción	13/01/2016	Fecha de Muestreo	16 de Diciembre 2015 09:00 Till 11:00 h
ID PCM	36671	Tipo de Muestra	Carbón
ID Cliente	Carbón NT-02 C.E.N. (Prueba 1; 129,2 MWe)Humedad	Fecha Análisis	18/01/2016
Representatividad	ND	Lugar de Muestreo	Unidad 2

RESULTADOS DEL ANÁLISIS

Parámetro	NORMA	Como Recibido	Base Seca
Humedad Total (%)	ASTM D 3302	19,36	
Humedad Residual (%)	ASTM D 3173 /7582	9,68	

OBSERVACIONES :

La muestra fue preparada en PCM.

Responsable Verificación

Responsable Aprobación

Consuelo Araya C.
Jefe de Laboratorio

Ernesto Pérez de Arce G.
Gerente General

- NOTAS
1. Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante.
 2. El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda.
 3. Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente.
 - 4.- En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo.
 - 5.- En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente.
 - 6.- El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.

Hoja 1 de 1



PCM Ltda.
Laboratorio de Combustibles
Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.cl
Padre Orellana 1421 - Santiago
Certificada bajo los Estándares de la Norma ISO 9001-2008
En proceso de Implementación de la Norma Nch ISO 17025-2005

ISO 9001-2008
Nro Certificado: 3774 – Año 2008
Bureau Veritas

INFORME DE ANÁLISIS Nº NG- 3850

Santiago, 19 de enero de 2016

# Documento	36367
# O.C. Cliente:	Pendiente

INFORMACIÓN DEL CLIENTE

Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com

IDENTIFICACIÓN DE LA MUESTRA

Fecha Recepción	13/01/2016	Fecha de Muestreo	16 de Diciembre 2015 09:00 Till 11:00 h
ID PCM	36689	Tipo de Muestra	Escoria
ID Cliente	BOTTOM-ASH NT-02 C.E.N. (Prueba 1; 129,2 MWe)	Fecha Análisis	19/01/2016
Representatividad	ND	Lugar de Muestreo	Unidad 2

RESULTADOS DEL ANÁLISIS

Parámetro	NORMA	Como Recibido	Base Seca
Humedad Total (%)	ASTM D 3302	54,63	
Humedad Residual (%)	ASTM D 3173 /7582	1,27	
LOI (%)	ASTM D 7348	4,83	10,66

OBSERVACIONES :

La muestra fue preparada en PCM.

Responsable Verificación

Responsable Aprobación

Consuelo Araya C.
Jefe de Laboratorio

Ernesto Pérez de Arce G.
Gerente General

1. Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante.

2. El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda.

3. Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente.

- 4.- En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo.

- 5.- En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente.

- 6.- El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.

NOTAS

Hoja 1 de 1



 PCM Ltda. Laboratorio de Combustibles Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.cl Padre Orellana 1421 - Santiago <i>Certificada bajo los Estándares de la Norma ISO 9001-2008</i> <i>En proceso de Implementación de la Norma Nch ISO 17025-2005</i>		ISO 9001-2008 <i>Nro Certificado: 3774 – Año 2008</i> <i>Bureau Veritas</i>			
INFORME DE ANÁLISIS Nº NG- 3844					
Santiago, 18 de enero de 2016					
# Documento 36361 # O.C. Cliente: Pendiente					
INFORMACIÓN DEL CLIENTE					
Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com
IDENTIFICACIÓN DE LA MUESTRA					
Fecha Recepción	13/01/2016	Fecha de Muestreo	16 de Diciembre 2015 09:00 Till 11:00 h		
ID PCM	36683	Tipo de Muestra	Ceniza		
ID Cliente	FLY-ASH NT-02 C.E.N. (Prueba 1: 129,2 MWe)	Fecha Análisis	18/01/2016		
Representatividad	ND	Lugar de Muestreo	Unidad 2		
RESULTADOS DEL ANÁLISIS					
Parámetro	NORMA	Como Recibido	Base Seca		
Humedad Total (%)	ASTM D 3302	0,46			
Humedad Residual (%)	ASTM D 3173 /7582	0,46			
LOI (%)	ASTM D 7348	3,49	3,50		
OBSERVACIONES :					
La muestra fue preparada en PCM.					
Responsable Verificación				Responsable Aprobación	
 Consuelo Araya C. Jefe de Laboratorio				 Ernesto Pérez de Arce G. Gerente General	
NOTAS	1. Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante. 2. El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda. 3. Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente. 4.- En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo. 5- En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente. 6- El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.				
	Hoja 1 de 1				

APPENDIX C3

Results Analysis Coal, Bottom and Fly Ash Test at 90% Load



PCM Ltda.
Laboratorio de Combustibles
Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.tie.cl
Padre Orellana 1421 - Santiago
Certificada bajo los Estándares de la Norma ISO 9001-2008
En proceso de Implementación de la Norma Nch ISO 17025-2005

ISO 9001-2008
Nro Certificado: 3774 – Año 2008
Bureau Veritas

INFORME DE ANÁLISIS N° NG- 3839

Santiago, 20 de enero de 2016

# Documento	36356
# O.C. Cliente:	Pendiente

INFORMACIÓN DEL CLIENTE

Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com

IDENTIFICACIÓN DE LA MUESTRA

Fecha Recepción	13/01/2016	Fecha de Muestreo	16 de Diciembre 2015 12:45 Till 14:45 h
ID PCM	36678	Tipo de Muestra	Carbón
ID Cliente	Carbón NT-02 C.E.N. (Prueba 2; 122,4 MWe)	Fecha Análisis	20/01/2016
Representatividad	ND	Lugar de Muestreo	Unidad 2

RESULTADOS DEL ANÁLISIS

Parámetro	NORMA	Como Recibido	Base Seca
Humedad Total (%)	ASTM D 3302	18,97	
Humedad Residual (%)	ASTM D 3173 /7582	9,97	
Cenizas (%)	ASTM D 3174 /7582	5,70	7,04
Materia Volátil (%)	ASTM D 3175 /7582	32,82	40,50
Carbono Fijo (%)	ASTM D 3172	42,51	52,46
Azufre(%)	ASTM D 4239	0,46	0,56
Poder Calorífico Superior (kcal/kg)	ASTM D 5865	5.623	6.939
Poder Calorífico Inferior (kcal/kg)	ASTM D 5865	5.323	6.704
Carbono (%)	ASTM D 5373	59,24	73,11
Hidrógeno (%)	ASTM D 5373	3,71	4,57
Nitrógeno (%)	ASTM D 5373	0,94	1,16
Oxígeno (%)	ASTM D 3180	10,98	13,56

OBSERVACIONES :

La muestra fue preparada en PCM.
El Hidrógeno y Oxígeno reportados en base "Como Recibido" no incluyen el contenido de éstos elementos en el agua.

Responsable Verificación

Responsable Aprobación

Consuelo Araya C.
Jefe de Laboratorio

Ernesto Pérez de Arce G.
Gerente General

- NOTAS
- Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante.
 - El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda.
 - Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente.
 - En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo.
 - En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente.
 - El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.

Hoja 1 de 1



PCM Ltda.
Laboratorio de Combustibles
Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.cl
Padre Orellana 1421 - Santiago
Certificada bajo los Estándares de la Norma ISO 9001-2008
En proceso de Implementación de la Norma Nch ISO 17025-2005

ISO 9001-2008
Nro Certificado: 3774 – Año 2008
Bureau Veritas

INFORME DE ANÁLISIS Nº NG- 3833

Santiago, 19 de enero de 2016

# Documento	36350
# O.C. Cliente:	Pendiente

INFORMACIÓN DEL CLIENTE

Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com

IDENTIFICACIÓN DE LA MUESTRA

Fecha Recepción	13/01/2016	Fecha de Muestreo	16 de Diciembre 2015 12:45 Till 14:45 h
ID PCM	36672	Tipo de Muestra	Carbón
ID Cliente	Carbón NT-02 C.E.N. (Prueba 2; 122,4 MWe)Humedad	Fecha Análisis	18/01/2016
Representatividad	ND	Lugar de Muestreo	Unidad 2

RESULTADOS DEL ANÁLISIS

Parámetro	NORMA	Como Recibido	Base Seca
Humedad Total (%)	ASTM D 3302	19,06	
Humedad Residual (%)	ASTM D 3173 /7582	10,97	

OBSERVACIONES :

La muestra fue preparada en PCM.

Responsable Verificación

Responsable Aprobación

Consuelo Araya C.
Jefe de Laboratorio

Ernesto Pérez de Arce G.
Gerente General

1. Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante.

2. El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda.

3. Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente.

- 4.- En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo.

- 5.- En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente.

- 6.- El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.

NOTAS

Hoja 1 de 1



PCM Ltda.
Laboratorio de Combustibles
Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.cl
Padre Orellana 1421 - Santiago
Certificada bajo los Estándares de la Norma ISO 9001-2008
En proceso de Implementación de la Norma Nch ISO 17025-2005

ISO 9001-2008
Nro Certificado: 3774 – Año 2008
Bureau Veritas

INFORME DE ANÁLISIS Nº NG- 3851

Santiago, 19 de enero de 2016

# Documento	36368
# O.C. Cliente:	Pendiente

INFORMACIÓN DEL CLIENTE

Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com

IDENTIFICACIÓN DE LA MUESTRA

Fecha Recepción	13/01/2016	Fecha de Muestreo	16 de Diciembre 2015 12:45 Till 14:45 h
ID PCM	36690	Tipo de Muestra	Escoria
ID Cliente	BOTTOM-ASH NT-02 C.E.N. (Prueba 2; 122,4 MWe)	Fecha Análisis	19/01/2016
Representatividad	ND	Lugar de Muestreo	Unidad 2

RESULTADOS DEL ANÁLISIS

Parámetro	NORMA	Como Recibido	Base Seca
Humedad Total (%)	ASTM D 3302	52,83	
Humedad Residual (%)	ASTM D 3173 /7582	1,15	
LOI (%)	ASTM D 7348	4,41	9,36

OBSERVACIONES :

La muestra fue preparada en PCM.

Responsable Verificación

Responsable Aprobación


Consuelo Araya C.
Jefe de Laboratorio

Ernesto Pérez de Arce G.
Gerente General

- NOTAS
1. Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante.
 2. El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda.
 3. Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente.
 - 4.- En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo.
 - 5.- En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente.
 - 6.- El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.

Hoja 1 de 1



 <p>PCM lab GESTIÓN ENERGÉTICA</p>		PCM Ltda. Laboratorio de Combustibles Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.cl Padre Orellana 1421 - Santiago Certificada bajo los Estándares de la Norma ISO 9001-2008 En proceso de Implementación de la Norma NCh ISO 17025-2005		<small>ISO 9001-2008 Nro Certificado: 3774 – Año 2008 Bureau Veritas</small>	
INFORME DE ANÁLISIS Nº NG- 3845					
Santiago, 18 de enero de 2016					
# Documento 36362 # O.C. Cliente: Pendiente					
INFORMACIÓN DEL CLIENTE					
Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com
IDENTIFICACIÓN DE LA MUESTRA					
Fecha Recepción	13/01/2016	Fecha de Muestreo	16 de Diciembre 2015 12:45 Till 14:45 h		
ID PCM	36684	Tipo de Muestra	Ceniza		
ID Cliente	FLY-ASH NT-02 C.E.N. (Prueba 2; 122,4 MWe)	Fecha Análisis	18/01/2016		
Representatividad	ND	Lugar de Muestreo	Unidad 2		
RESULTADOS DEL ANÁLISIS					
Parámetro	NORMA	Como Recibido	Base Seca		
Humedad Total (%)	ASTM D 3302	0,24			
Humedad Residual (%)	ASTM D 3173 /7582	< 0,27			
LOI (%)	ASTM D 7348	2,30	2,30		
OBSERVACIONES :					
La muestra fue preparada en PCM.					
Responsable Verificación				Responsable Aprobación	
 Consuelo Araya C. Jefe de Laboratorio				 Ernesto Pérez de Arce G. Gerente General	
NOTAS	1. Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante. 2. El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda. 3. Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente. 4.- En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo. 5.- En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente. 6.- El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.				
Hoja 1 de 1					

APPENDIX C4

Results Analysis Coal, Bottom and Fly Ash Test at 80% Load



PCM Ltda.
Laboratorio de Combustibles
Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.tie.cl
Padre Orellana 1421 - Santiago
Certificada bajo los Estándares de la Norma ISO 9001-2008
En proceso de Implementación de la Norma Nch ISO 17025-2005

ISO 9001-2008
Nro Certificado: 3774 – Año 2008
Bureau Veritas

INFORME DE ANÁLISIS N° NG- 3840

Santiago, 20 de enero de 2016

# Documento	36357
# O.C. Cliente:	Pendiente

INFORMACIÓN DEL CLIENTE

Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com

IDENTIFICACIÓN DE LA MUESTRA

Fecha Recepción	13/01/2016	Fecha de Muestreo	17 de Diciembre 2015 09:30 Till 11:30 h
ID PCM	36679	Tipo de Muestra	Carbón
ID Cliente	Carbón NT-02 C.E.N. (Prueba 1; 108 MWe)	Fecha Análisis	20/01/2016
Representatividad	ND	Lugar de Muestreo	Unidad 2

RESULTADOS DEL ANÁLISIS

Parámetro	NORMA	Como Recibido	Base Seca
Humedad Total (%)	ASTM D 3302	18,24	
Humedad Residual (%)	ASTM D 3173 /7582	9,67	
Cenizas (%)	ASTM D 3174 /7582	5,59	6,84
Materia Volátil (%)	ASTM D 3175 /7582	33,22	40,63
Carbono Fijo (%)	ASTM D 3172	42,94	52,53
Azufre(%)	ASTM D 4239	0,44	0,54
Poder Calorífico Superior (kcal/kg)	ASTM D 5865	5.679	6.946
Poder Calorífico Inferior (kcal/kg)	ASTM D 5865	5.381	6.711
Carbono (%)	ASTM D 5373	59,79	73,13
Hidrógeno (%)	ASTM D 5373	3,74	4,57
Nitrógeno (%)	ASTM D 5373	1,12	1,37
Oxígeno (%)	ASTM D 3180	11,08	13,56

OBSERVACIONES :

La muestra fue preparada en PCM.
El Hidrógeno y Oxígeno reportados en base "Como Recibido" no incluyen el contenido de éstos elementos en el agua.

Responsable Verificación

Responsable Aprobación

Consuelo Araya C.
Jefe de Laboratorio

Ernesto Pérez de Arce G.
Gerente General

- NOTAS
- Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante.
 - El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda.
 - Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente.
 - En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo.
 - En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente.
 - El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.

Hoja 1 de 1



PCM Ltda.
Laboratorio de Combustibles
Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.cl
Padre Orellana 1421 - Santiago
Certificada bajo los Estándares de la Norma ISO 9001-2008
En proceso de Implementación de la Norma Nch ISO 17025-2005

ISO 9001-2008
Nro Certificado: 3774 – Año 2008
Bureau Veritas

INFORME DE ANÁLISIS Nº NG- 3834

Santiago, 19 de enero de 2016

# Documento	36351
# O.C. Cliente:	Pendiente

INFORMACIÓN DEL CLIENTE

Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com

IDENTIFICACIÓN DE LA MUESTRA

Fecha Recepción	13/01/2016	Fecha de Muestreo	17 de Diciembre 2015 09:30 Till 11:30 h
ID PCM	36673	Tipo de Muestra	Carbón
ID Cliente	Carbón NT-02 C.E.N. (Prueba 1; 108 MWe)Humedad	Fecha Análisis	19/01/2016
Representatividad	ND	Lugar de Muestreo	Unidad 2

RESULTADOS DEL ANÁLISIS

Parámetro	NORMA	Como Recibido	Base Seca
Humedad Total (%)	ASTM D 3302	18,25	
Humedad Residual (%)	ASTM D 3173 /7582	10,75	

OBSERVACIONES :

La muestra fue preparada en PCM.

Responsable Verificación

Responsable Aprobación

Consuelo Araya C.
Jefe de Laboratorio

Ernesto Pérez de Arce G.
Gerente General

1. Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante.

2. El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda.

3. Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente.

- 4.- En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo.

- 5.- En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente.

- 6.- El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.

NOTAS

Hoja 1 de 1



PCM Ltda.
Laboratorio de Combustibles
Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.cl
Padre Orellana 1421 - Santiago
Certificada bajo los Estándares de la Norma ISO 9001-2008
En proceso de Implementación de la Norma Nch ISO 17025-2005

ISO 9001-2008
Nro Certificado: 3774 – Año 2008
Bureau Veritas

INFORME DE ANÁLISIS Nº NG- 3852

Santiago, 19 de enero de 2016

# Documento	36369
# O.C. Cliente:	Pendiente

INFORMACIÓN DEL CLIENTE

Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com

IDENTIFICACIÓN DE LA MUESTRA

Fecha Recepción	13/01/2016	Fecha de Muestreo	17 de Diciembre 2015 09:30 Till 11:30 h
ID PCM	36691	Tipo de Muestra	Escoria
ID Cliente	BOTTOM-ASH NT-02 C.E.N. (Prueba 1; 108 MW _e)	Fecha Análisis	19/01/2016
Representatividad	ND	Lugar de Muestreo	Unidad 2

RESULTADOS DEL ANÁLISIS

Parámetro	NORMA	Como Recibido	Base Seca
Humedad Total (%)	ASTM D 3302	54,90	
Humedad Residual (%)	ASTM D 3173 /7582	1,96	
LOI (%)	ASTM D 7348	10,09	22,36

OBSERVACIONES :

La muestra fue preparada en PCM.

Responsable Verificación

Responsable Aprobación

Consuelo Araya C.
Jefe de Laboratorio

Ernesto Pérez de Arce G.
Gerente General

- NOTAS
1. Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante.
 2. El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda.
 3. Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente.
 - 4.- En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo.
 - 5.- En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente.
 - 6.- El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.

Hoja 1 de 1



PCM Ltda.
Laboratorio de Combustibles
Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.cl
Padre Orellana 1421 - Santiago
Certificada bajo los Estándares de la Norma ISO 9001-2008
En proceso de Implementación de la Norma NCh ISO 17025-2005

ISO 9001-2008
Nro Certificado: 3774 – Año 2008
Bureau Veritas

INFORME DE ANÁLISIS

Nº NG- 3846

Santiago, 18 de enero de 2016

Documento 36363

O.C. Cliente: Pendiente

INFORMACIÓN DEL CLIENTE

Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com

IDENTIFICACIÓN DE LA MUESTRA

Fecha Recepción	13/01/2016	Fecha de Muestreo	17 de Diciembre 2015 09:30 Till 11:30 h
ID PCM	36685	Tipo de Muestra	Ceniza
ID Cliente	FLY-ASH NT-02 C.E.N. (Prueba 1; 108 MWe)	Fecha Análisis	18/01/2016
Representatividad	ND	Lugar de Muestreo	Unidad 2

RESULTADOS DEL ANÁLISIS

Parámetro	NORMA	Como Recibido	Base Seca
Humedad Total (%)	ASTM D 3302	0,39	
Humedad Residual (%)	ASTM D 3173 /7582	0,39	
LOI (%)	ASTM D 7348	2,15	2,15

OBSERVACIONES :

La muestra fue preparada en PCM.

Responsable Verificación

Consuelo Araya C.
Jefe de Laboratorio

Responsable Aprobación

Ernesto Pérez de Arce G.
Gerente General

1. Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante.

2. El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda.

3. Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente.

4.- En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo.

5.- En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente.

6.- El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.

NOTAS

Hoja 1 de 1

APPENDIX C5

Results Analysis Coal, Bottom and Fly Ash Test at 70% Load



PCM Ltda.
Laboratorio de Combustibles
Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.tie.cl
Padre Orellana 1421 - Santiago
Certificada bajo los Estándares de la Norma ISO 9001-2008
En proceso de Implementación de la Norma Nch ISO 17025-2005

ISO 9001-2008
Nro Certificado: 3774 – Año 2008
Bureau Veritas

INFORME DE ANÁLISIS Nº NG- 3841

Santiago, 20 de enero de 2016

# Documento	36358
# O.C. Cliente:	Pendiente

INFORMACIÓN DEL CLIENTE

Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com

IDENTIFICACIÓN DE LA MUESTRA

Fecha Recepción	13/01/2016	Fecha de Muestreo	17 de Diciembre 2015 13:00 Till 15:00 h
ID PCM	36680	Tipo de Muestra	Carbón
ID Cliente	Carbón NT-02 C.E.N. (Prueba 2; 95 MW/e)	Fecha Análisis	20/01/2016
Representatividad	ND	Lugar de Muestreo	Unidad 2

RESULTADOS DEL ANÁLISIS

Parámetro	NORMA	Como Recibido	Base Seca
Humedad Total (%)	ASTM D 3302	19,08	
Humedad Residual (%)	ASTM D 3173 /7582	9,89	
Cenizas (%)	ASTM D 3174 /7582	5,55	6,86
Materia Volátil (%)	ASTM D 3175 /7582	33,41	41,29
Carbono Fijo (%)	ASTM D 3172	41,95	51,84
Azufre(%)	ASTM D 4239	0,43	0,53
Poder Calorífico Superior (kcal/kg)	ASTM D 5865	5.623	6.949
Poder Calorífico Inferior (kcal/kg)	ASTM D 5865	5.322	6.713
Carbono (%)	ASTM D 5373	59,01	72,93
Hidrógeno (%)	ASTM D 5373	3,70	4,58
Nitrógeno (%)	ASTM D 5373	1,18	1,45
Oxígeno (%)	ASTM D 3180	11,04	13,65

OBSERVACIONES :

La muestra fue preparada en PCM.
El Hidrógeno y Oxígeno reportados en base "Como Recibido" no incluyen el contenido de éstos elementos en el agua.

Responsable Verificación

Responsable Aprobación

Consuelo Araya C.
Jefe de Laboratorio

Ernesto Pérez de Arce G.
Gerente General

- NOTAS
- Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante.
 - El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda.
 - Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente.
 - En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo.
 - En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente.
 - El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.

Hoja 1 de 1



PCM Ltda.
Laboratorio de Combustibles
Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.cl
Padre Orellana 1421 - Santiago
Certificada bajo los Estándares de la Norma ISO 9001-2008
En proceso de Implementación de la Norma Nch ISO 17025-2005

ISO 9001-2008
Nro Certificado: 3774 – Año 2008
Bureau Veritas

INFORME DE ANÁLISIS Nº NG- 3835

Santiago, 19 de enero de 2016

# Documento	36352
# O.C. Cliente:	Pendiente

INFORMACIÓN DEL CLIENTE

Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com

IDENTIFICACIÓN DE LA MUESTRA

Fecha Recepción	13/01/2016	Fecha de Muestreo	17 de Diciembre 2015 13:00 Till 15:00 h
ID PCM	36674	Tipo de Muestra	Carbón
ID Cliente	Carbón NT-02 C.E.N. (Prueba 2; 95 MWe)Humedad	Fecha Análisis	19/01/2016
Representatividad	ND	Lugar de Muestreo	Unidad 2

RESULTADOS DEL ANÁLISIS

Parámetro	NORMA	Como Recibido	Base Seca
Humedad Total (%)	ASTM D 3302	18,91	
Humedad Residual (%)	ASTM D 3173 /7582	10,64	

OBSERVACIONES :

La muestra fue preparada en PCM.

Responsable Verificación

Responsable Aprobación

Consuelo Araya C.
Jefe de Laboratorio

Ernesto Pérez de Arce G.
Gerente General

- NOTAS
1. Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante.
 2. El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda.
 3. Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente.
 - 4.- En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo.
 - 5.- En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente.
 - 6.- El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.

Hoja 1 de 1



PCM Ltda.
Laboratorio de Combustibles
Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.cl
Padre Orellana 1421 - Santiago
Certificada bajo los Estándares de la Norma ISO 9001-2008
En proceso de Implementación de la Norma Nch ISO 17025-2005

ISO 9001-2008
Nro Certificado: 3774 – Año 2008
Bureau Veritas

INFORME DE ANÁLISIS Nº NG- 3853

Santiago, 19 de enero de 2016

# Documento	36370
# O.C. Cliente:	Pendiente

INFORMACIÓN DEL CLIENTE

Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com

IDENTIFICACIÓN DE LA MUESTRA

Fecha Recepción	13/01/2016	Fecha de Muestreo	17 de Diciembre 2015 13:00 Till 15:00 h
ID PCM	36692	Tipo de Muestra	Escoria
ID Cliente	BOTTOM-ASH NT-02 C.E.N. (Prueba 1; 95 MWe)	Fecha Análisis	19/01/2016
Representatividad	ND	Lugar de Muestreo	Unidad 2

RESULTADOS DEL ANÁLISIS

Parámetro	NORMA	Como Recibido	Base Seca
Humedad Total (%)	ASTM D 3302	52,78	
Humedad Residual (%)	ASTM D 3173 /7582	1,51	
LOI (%)	ASTM D 7348	7,29	15,44

OBSERVACIONES :

La muestra fue preparada en PCM.

Responsable Verificación

Responsable Aprobación

Consuelo Araya C.
Jefe de Laboratorio

Ernesto Pérez de Arce G.
Gerente General

- NOTAS
1. Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante.
 2. El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda.
 3. Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente.
 - 4.- En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo.
 - 5.- En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente.
 - 6.- El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.

Hoja 1 de 1



PCM Ltda.
Laboratorio de Combustibles
Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.cl
Padre Orellana 1421 - Santiago
Certificada bajo los Estándares de la Norma ISO 9001-2008
En proceso de implementación de la Norma Nch ISO 17025-2005

ISO 9001-2008
Nro Certificado: 3774 – Año 2008
Bureau Veritas

INFORME DE ANÁLISIS

Nº NG- 3847

Santiago, 18 de enero de 2016

Documento 36364
O.C. Cliente: Pendiente

INFORMACIÓN DEL CLIENTE

Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com

IDENTIFICACIÓN DE LA MUESTRA

Fecha Recepción	13/01/2016	Fecha de Muestreo	17 de Diciembre 2015 11:30 Till 15:00 h
ID PCM	36686	Tipo de Muestra	Ceniza
ID Cliente	FLY-ASH NT-02 C.E.N. (Prueba 2; 95 MWe)	Fecha Análisis	18/01/2016
Representatividad	ND	Lugar de Muestreo	Unidad 2


RESULTADOS DEL ANÁLISIS

Parámetro	NORMA	Como Recibido	Base Seca
Humedad Total (%)	ASTM D 3302	< 0, 15	
Humedad Residual (%)	ASTM D 3173 /7582	< 0, 27	
LOI (%)	ASTM D 7348	0,55	0,55


OBSERVACIONES :

La muestra fue preparada en PCM.

Responsable Verificación


Consuelo Araya C.
Jefe de Laboratorio

Responsable Aprobación


Ernesto Pérez de Arce G.
Gerente General

- NOTAS
1. Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante.
 2. El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda.
 3. Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente.
 4. En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo.
 5. En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente.
 6. El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón

Hoja 1 de 1



APPENDIX C6

Results Analysis Coal, Bottom and Fly Ash Test at 47% Load



PCM Ltda.
Laboratorio de Combustibles
Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.tie.cl
Padre Orellana 1421 - Santiago
Certificada bajo los Estándares de la Norma ISO 9001-2008
En proceso de Implementación de la Norma Nch ISO 17025-2005

ISO 9001-2008
Nro Certificado: 3774 – Año 2008
Bureau Veritas

INFORME DE ANÁLISIS N° NG- 3842

Santiago, 20 de enero de 2016

Documento 36359

O.C. Cliente Pendiente

INFORMACIÓN DEL CLIENTE

Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com

IDENTIFICACIÓN DE LA MUESTRA

Fecha Recepción	13/01/2016	Fecha de Muestreo	17 de Diciembre 2015 17:00 Till 19:00 h
ID PCM	36681	Tipo de Muestra	Carbón
ID Cliente	Carbón NT-02 C.E.N. (Prueba 3; 65 MW _e)	Fecha Análisis	20/01/2016
Representatividad	ND	Lugar de Muestreo	Unidad 2

RESULTADOS DEL ANÁLISIS

Parámetro	NORMA	Como Recibido	Base Seca
Humedad Total (%)	ASTM D 3302	18,99	
Humedad Residual (%)	ASTM D 3173 /7582	10,93	
Cenizas (%)	ASTM D 3174 /7582	5,62	6,94
Materia Volátil (%)	ASTM D 3175 /7582	33,50	41,36
Carbono Fijo (%)	ASTM D 3172	41,88	51,70
Azufre(%)	ASTM D 4239	0,43	0,53
Poder Calorífico Superior (kcal/kg)	ASTM D 5865	5.614	6.930
Poder Calorífico Inferior (kcal/kg)	ASTM D 5865	5.315	6.696
Carbono (%)	ASTM D 5373	59,11	72,97
Hidrógeno (%)	ASTM D 5373	3,67	4,54
Nitrógeno (%)	ASTM D 5373	1,18	1,46
Oxígeno (%)	ASTM D 3180	10,98	13,56

OBSERVACIONES :

La muestra fue preparada en PCM.
El Hidrógeno y Oxígeno reportados en base "Como Recibido" no incluyen el contenido de éstos elementos en el agua.

Responsable Verificación

Responsable Aprobación

Consuelo Araya C.
Jefe de Laboratorio

Ernesto Pérez de Arce G.
Gerente General

- NOTAS
- Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante.
 - El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda.
 - Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente.
 - En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo.
 - En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente.
 - El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.

Hoja 1 de 1



PCM Ltda.
Laboratorio de Combustibles
Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.cl
Padre Orellana 1421 - Santiago
Certificada bajo los Estándares de la Norma ISO 9001-2008
En proceso de Implementación de la Norma Nch ISO 17025-2005

ISO 9001-2008
Nro Certificado: 3774 – Año 2008
Bureau Veritas

INFORME DE ANÁLISIS Nº NG- 3836

Santiago, 19 de enero de 2016

Documento 36353

O.C. Cliente: Pendiente

INFORMACIÓN DEL CLIENTE

Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com

IDENTIFICACIÓN DE LA MUESTRA

Fecha Recepción	13/01/2016	Fecha de Muestreo	17 de Diciembre 2015 17:00 Till 19:00 h
ID PCM	36675	Tipo de Muestra	Carbón
ID Cliente	Carbón NT-02 C.E.N. (Prueba 3; 65 MWe)Humedad	Fecha Análisis	19/01/2016
Representatividad	ND	Lugar de Muestreo	Unidad 2

RESULTADOS DEL ANÁLISIS

Parámetro	NORMA	Como Recibido	Base Seca
Humedad Total (%)	ASTM D 3302	19,03	
Humedad Residual (%)	ASTM D 3173 /7582	10,67	

OBSERVACIONES :

La muestra fue preparada en PCM.

Responsable Verificación

Responsable Aprobación

Consuelo Araya C.
Jefe de Laboratorio

Ernesto Pérez de Arce G.
Gerente General

1. Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante.

2. El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda.

3. Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente.

- 4.- En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo.

- 5.- En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente.

- 6.- El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.

NOTAS

Hoja 1 de 1



PCM Ltda.
Laboratorio de Combustibles
Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.cl
Padre Orellana 1421 - Santiago
Certificada bajo los Estándares de la Norma ISO 9001-2008
En proceso de Implementación de la Norma Nch ISO 17025-2005

ISO 9001-2008
Nro Certificado: 3774 – Año 2008
Bureau Veritas

INFORME DE ANÁLISIS Nº NG- 3854

Santiago, 19 de enero de 2016

Documento 36371

O.C. Cliente: Pendiente

INFORMACIÓN DEL CLIENTE

Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com

IDENTIFICACIÓN DE LA MUESTRA

Fecha Recepción	13/01/2016	Fecha de Muestreo	17 de Diciembre 2015 17:00 Till 19:00 h
ID PCM	36693	Tipo de Muestra	Escoria
ID Cliente	BOTTOM-ASH NT-02 C.E.N. (Prueba 2; 65 MWe)	Fecha Análisis	19/01/2016
Representatividad	ND	Lugar de Muestreo	Unidad 2

RESULTADOS DEL ANÁLISIS

Parámetro	NORMA	Como Recibido	Base Seca
Humedad Total (%)	ASTM D 3302	48,92	
Humedad Residual (%)	ASTM D 3173 /7582	1,79	
LOI (%)	ASTM D 7348	10,26	20,08

OBSERVACIONES :

La muestra fue preparada en PCM.

Responsable Verificación

Responsable Aprobación

Consuelo Araya C.
Jefe de Laboratorio

Ernesto Pérez de Arce G.
Gerente General

1. Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante.

2. El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda.

3. Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente.

- 4.- En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo.

- 5.- En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente.

- 6.- El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.

NOTAS

Hoja 1 de 1



PCM Ltda. Laboratorio de Combustibles Fono 551 69 83 - Fax 551 74 55 - e-mail laboratorio@pcmlab.tie.cl Padre Orellana 1421 - Santiago Certificada bajo los Estándares de la Norma ISO 9001-2008 En proceso de Implementación de la Norma Nch ISO 17025-2005	ISO 9001-2008 Nro Certificado: 3774 – Año 2008 Bureau Veritas				
INFORME DE ANÁLISIS Nº NG- 3848					
Santiago, 18 de enero de 2016					
# Documento: 36365 # O.C. Cliente: Pendiente					
INFORMACIÓN DEL CLIENTE					
Cliente	AES Gener - NORGENER	Contacto Comercial	Adolfo Rodriguez	RUT	94.272.000-9
Dirección	Rosario norte 532- Piso 19	Teléfono	6804882	Fax	6804895
Comuna	Las Condes	Giro	Gener. Trans. y Venta de Energía Eléctrica	e-mail	adolfo.rodriguez@aes.com
IDENTIFICACIÓN DE LA MUESTRA					
Fecha Recepción	13/01/2016	Fecha de Muestreo	17 de Diciembre 2015 17:00 Till 19:00 h		
ID PCM	36687	Tipo de Muestra	Ceniza		
ID Cliente	FLY-ASH NT-02 C.E.N. (Prueba 3; 65 MWe)	Fecha Análisis	18/01/2016		
Representatividad	ND	Lugar de Muestreo	Unidad 2		
RESULTADOS DEL ANÁLISIS					
Parámetro	NORMA	Como Recibido	Base Seca		
Humedad Total (%)	ASTM D 3302	0,18			
Humedad Residual (%)	ASTM D 3173 /7582	< 0,27			
LOI (%)	ASTM D 7348	0,46	0,46		
OBSERVACIONES :					
La muestra fue preparada en PCM.					
Responsable Verificación					Responsable Aprobación
 Consuelo Araya C. Jefe de Laboratorio					 Ernesto Pérez de Arce G. Gerente General
NOTAS	1. Los resultados reportados son válidos para la muestra ensayada, la que fue proporcionada por el solicitante. 2. El certificado de análisis no se debe reproducir sin la aprobación escrita del Laboratorio de PCM Ltda. 3. Las opiniones e interpretaciones de los resultados se realizarán solo en el caso que el cliente lo solicite formalmente. 4. En caso que PCM haya realizado el Servicio de Muestreo, se indicará en las observaciones del certificado la fecha de muestreo, el lugar de muestreo, las condiciones ambientales del muestreo y el procedimiento de muestreo. 5. En el caso en que PCM Ltda. subcontrate servicios de análisis será informado al cliente previamente. 6. El alcance de la Acreditación incluye: Preparación, Análisis Inmediato y Elemental, Poder Calorífico, Punto de Fusión de Cenizas y HGI para muestras de Carbón.				
Hoja 1 de 1					



APPENDIX D

Measurement Data, DNV GL, Algoritmos and AES



APPENDIX D1

Measurement Data Test at 100% Load

Tag	Performance Test Unit Date Time	100% Norgener #2 15 december 2015 09:00 hr. - 11:00 hr.	Unit	Average	Max	Min	Std	Origin
@0013	Condensate Inlet Deaerator Differential Pressure	mbar	180.72	187.65	175.45	2.602	0.019	DNV GL
@0020	Condensate Inlet Deaerator Pressure	bar(a)	10.205	10.247	10.145	0.019	0.019	DNV GL
@0021	Condensate Inlet Deaerator Temperature	°C	136.59	136.78	136.30	0.084	0.018	DNV GL
@0050	Extraction Steam Pressure Deaerator	bar(a)	8.710	8.747	8.652	0.490	0.073	DNV GL
@0051	Extraction Steam Temperature Deaerator	°C	356.56	357.47	354.04	0.490	0.073	DNV GL
@0060	Feed Water Inlet Temperature Pump#1	°C	173.83	173.97	173.61	0.000	0.073	DNV GL
@0061	Feed Water Inlet Temperature Pump#2	°C	0.00	0.00	0.00	0.000	0.000	DNV GL
@0062	Feed Water Inlet Temperature Pump#3	°C	173.69	173.87	173.47	0.081	0.081	DNV GL
@0077	Extraction Steam Pressure High Pressure Heater#5	bar(a)	21.73	21.82	21.59	0.045	0.045	DNV GL
@0078	Extraction Steam Temperature High Pressure Heater#5	°C	273.49	273.89	272.98	0.174	0.174	DNV GL
@0080	Barometer Pressure	bar(a)	1.00959	1.00985	1.00936	0.0002	0.0002	DNV GL
@0081	Ambient Air Temperature	°C	20.814	21.440	20.350	0.235	0.235	DNV GL
@0082	Relative Humidity Ambient Air	%	64.824	66.979	62.367	0.989	0.989	DNV GL
@0100	HP Feed Water Inlet Boiler Differential Pressure	mbar	440.88	450.82	431.10	3.817	3.817	DNV GL
@0101	HP Feed Water Inlet Boiler Pressure	bar(a)	213.53	215.99	209.97	1.434	1.434	DNV GL
@0102	HP Feed Water Inlet Boiler Temperature	°C	178.29	178.52	178.02	0.100	0.100	DNV GL
@0105	HP Spray Water #1 Boiler Differential Pressure	mbar	0.000	0.000	0.000	0.169	0.169	DNV GL
@0106	HP Spray Water #1 Boiler Pressure	bar(a)	168.69	169.22	167.81	0.279	0.279	DNV GL
@0110	ReHeat Spray Water Boiler Differential Pressure	mbar	78.06	89.65	58.83	8.458	8.458	DNV GL
@0111	ReHeat Spray Water Boiler Pressure	bar(a)	73.857	74.560	72.640	0.51	0.51	DNV GL
@0112	ReHeat Spray Water#1 Boiler Temperature	°C	175.75	175.94	175.50	0.087	0.087	DNV GL
@0113	ReHeat Spray Water#2 Boiler Temperature	°C	0.00	0.00	0.00	0.000	0.000	DNV GL
@0114	ReHeat Spray Water#3 Boiler Temperature	°C	175.46	175.64	175.22	0.091	0.091	DNV GL
@0115	HP Spray Water #2 Boiler Differential Pressure	mbar	0.758	1.090	0.350	0.123	0.123	DNV GL
@0116	HP Spray Water #2Boiler Pressure	bar(a)	168.69	169.21	167.82	0.278	0.278	DNV GL
@0120	Extraction Steam Pressure High Pressure Heater#6	bar(a)	39.147	39.310	38.890	0.078	0.078	DNV GL
@0121	Extraction Steam Temperature High Pressure Heater#6	°C	351.01	352.85	349.10	0.715	0.715	DNV GL
@0123	Feed Water Inlet Temperature High Pressure Heater#6	°C	215.59	215.79	215.30	0.104	0.104	DNV GL
@0124	Feed Water Outlet Pressure High Pressure Heater#6	bar(a)	184.71	185.32	183.78	0.301	0.301	DNV GL
@0125	Feed Water Outlet Temperature High Pressure Heater#6	°C	249.14	249.36	248.76	0.119	0.119	DNV GL
@0126	Drain Temperature High Pressure Heater#6	°C	221.09	221.29	220.79	0.104	0.104	DNV GL
@0127	Drain Temperature High Pressure Heater#5	°C	192.25	192.43	191.93	0.100	0.100	DNV GL
@0130	HP Steam Pressure Outlet Boiler	bar(a)	165.59	166.22	164.73	0.278	0.278	DNV GL
@0131	HP Steam Temperature Outlet Boiler	°C	540.37	543.05	537.28	1.045	1.045	DNV GL
@0133	Cold ReHeat Pressure Inlet Boiler	bar(a)	39.078	39.240	38.830	0.079	0.079	DNV GL
@0134	Cold ReHeat Temperature Inlet Boiler	°C	351.26	353.06	349.38	0.710	0.710	DNV GL
@0135	Hot ReHeat Pressure Outlet Boiler	bar(a)	35.931	36.090	35.700	0.076	0.076	DNV GL
@0136	Hot ReHeat Temperature Outlet Boiler	°C	545.61	547.72	543.95	0.742	0.742	DNV GL
@0140	Feed Water Inlet Temperature Boiler	bar(a)	182.30	182.90	181.41	0.289	0.289	DNV GL
@0141	Feed Water Inlet Pressure Boiler	°C	256.62	257.00	256.30	0.139	0.139	DNV GL
@0150	Cool Water Temperature Inlet Condenser (a)	°C	16.450	16.880	15.990	0.276	0.276	DNV GL
@0151	Cool Water Temperature Inlet Condenser (b)	°C	16.383	16.810	15.930	0.276	0.276	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A1	°C	362.64	364.89	360.25	1.041	1.041	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A2	°C	364.47	366.79	361.82	1.171	1.171	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A3	°C	363.97	366.13	361.54	1.103	1.103	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A4	°C	366.78	369.06	364.14	1.170	1.170	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A5	°C	367.71	369.91	365.22	1.105	1.105	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A6	°C	368.38	370.67	365.92	1.157	1.157	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A7	°C	369.07	371.63	366.42	1.178	1.178	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A8	°C	369.18	371.67	366.49	1.178	1.178	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A9	°C	370.03	372.49	367.43	1.170	1.170	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A10	°C	372.36	374.34	370.01	0.912	0.912	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A11	°C	374.79	377.51	371.88	1.376	1.376	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A12	°C	371.31	374.00	368.56	1.342	1.342	DNV GL

Tag	Performance Test Unit Date Time	100% Norgener #2 15 december 2015 09:00 hr. - 11:00 hr.	Unit	Average	Max	Min	Std	Origin
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A13	°C	369.60	371.85	367.36	1.108	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A14	°C	373.04	375.47	370.41	1.182	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A15	°C	371.25	373.49	368.87	1.108	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A16	°C	369.09	371.20	366.89	0.947	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A17	°C	373.82	376.07	371.38	1.104	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A18	°C	371.34	373.41	369.15	1.001	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A19	°C	360.18	362.17	358.43	0.779	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A20	°C	373.06	375.24	370.92	0.927	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A21	°C	369.40	371.50	367.41	0.935	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A22	°C	358.17	360.32	356.17	0.847	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A23	°C	365.02	367.08	363.29	0.765	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A24	°C	362.46	364.37	360.66	0.795	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A1	°C	136.89	138.06	135.99	0.693	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A2	°C	147.38	148.75	146.48	0.748	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A3	°C	155.93	157.36	154.93	0.781	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A4	°C	135.85	137.05	134.98	0.676	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A5	°C	143.80	145.05	142.91	0.721	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A6	°C	153.85	155.23	152.86	0.752	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A7	°C	133.64	134.80	132.87	0.647	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A8	°C	142.51	143.61	141.32	0.639	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A9	°C	152.51	153.84	151.51	0.735	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A10	°C	132.75	133.84	131.90	0.646	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A11	°C	143.22	144.48	141.91	0.688	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A12	°C	151.38	152.68	150.48	0.704	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A13	°C	131.63	132.79	130.72	0.661	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A14	°C	140.67	141.93	139.80	0.707	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A15	°C	150.84	152.18	149.92	0.745	DNV GL	
@0261	Oxigen (O2) Inlet Air Heater A	vol%	3.11	3.37	2.88	0.09	Algoritmos	
@0262	Oxigen (O2) Inlet Air Heater B	vol%	2.96	3.21	2.67	0.09	Algoritmos	
@0265	Oxigen (O2) Outlet Air Heater	vol%	6.55	7.38	5.41	0.57	Algoritmos	
@0267	Carbon Monoxide Outlet Air Heater	ppm	0.1	2.1	0.0	0.2	Algoritmos	

Tag	Performance Test Unit Date Time	100% Norgener #2 15 december 2015 09:00 hr. - 11:00 hr.	Unit	Average	Max	Min	Std	Origin
@0012	Condensate Inlet Deaerator Mass Flow	t/h	341.65	351.75	333.53	3.387	AES	
@0021	Condensate Inlet Deaerator Temperature	°C	137.00	137.18	136.76	0.091	AES	
@0040	Mass Flow Feed Water Pump#1	t/h	193.97	197.13	191.50	1.147	AES	
@0041	Mass Flow Feed Water Pump#2	t/h	0.000	0.000	0.000	0.000	AES	
@0042	Mass Flow Feed Water Pump#3	t/h	231.18	233.55	228.57	0.971	AES	
@0050	Extraction Steam Pressure Deaerator	bar(a)	9.048	9.114	9.013	0.048	AES	
@0051	Extraction Steam Temperature Deaerator	°C	367.10	367.89	366.36	0.369	AES	
@0060	Feed Water Temperature Deaerator	°C	173.83	173.89	173.69	0.077	AES	
@0095	Extraction Steam Pressure High Pressure Heater#5	bar(a)	22.427	22.592	22.240	0.058	AES	
@0096	Extraction Steam Temperature High Pressure Heater#5	°C	490.28	491.17	489.35	0.433	AES	
@0300	Cold Primair Air Temperature	°C	26.132	26.750	25.633	0.331	AES	
@0305	Cold Secundair Air Temperature 201	°C	25.175	25.775	24.671	0.328	AES	
@0306	Cold Secundair Air Temperature 202	°C	25.786	26.414	25.306	0.318	AES	
@0310	Hot Primair Air Temperature	°C	342.35	344.03	340.78	0.922	AES	
@0315	Hot Secundair Air Temperature 154	°C	327.02	328.41	325.70	0.869	AES	
@0316	Hot Secundair Air Temperature 155	°C	334.78	336.35	333.32	0.894	AES	
@0320	Airflow Hot Secundair 21	t/h	120.29	125.09	115.87	1.695	AES	
@0321	Airflow Hot Secundair 22	t/h	131.48	135.14	127.30	1.497	AES	
@0325	Mass Flow Coal Feeder A	t/h	10.507	10.584	10.477	0.045	AES	
@0326	Mass Flow Coal Feeder B	t/h	10.622	10.716	10.510	0.044	AES	
@0327	Mass Flow Coal Feeder C	t/h	14.384	14.521	14.271	0.060	AES	
@0328	Mass Flow Coal Feeder D	t/h	14.423	14.519	14.289	0.047	AES	
@0330	Mass Flow Primair Air Mill A	t/h	32.226	32.922	31.721	0.208	AES	
@0331	Mass Flow Primair Air Mill D	t/h	25.934	27.467	24.711	0.400	AES	
@0332	Mass Flow Primair Air Mill C	t/h	29.138	29.596	28.638	0.172	AES	
@0333	Mass Flow Primair Air Mill D	t/h	29.653	30.180	29.169	0.159	AES	
@0340	Oxygen (O2) Inlet Air Heater A	vol %	2.017	2.214	1.783	0.093	AES	
@0341	Oxygen (O2) Inlet Air Heater B	vol %	2.619	2.741	2.404	0.075	AES	
@0350	X Position HP Valves	%	82.328	84.609	79.055	2.278	AES	
@0360	Make-Up Water Mass Flow	t/h	4.366	6.782	0.002	2.079	AES	
@0500	Power Consumption Mill A	kW	295.22	303.29	290.56	2.464	AES	
@0501	Power Consumption Mill B	kW	293.54	301.96	286.31	2.849	AES	
@0502	Power Consumption Mill C	kW	303.82	310.20	298.25	2.377	AES	
@0503	Power Consumption Mill D	kW	296.33	305.47	287.88	2.917	AES	
@0530	Gross Power Generator (kWh)	kW	136251.7	-	-	-	AES	
@0531	Auxiliary Power Consumption (kWh)	kW	9868.4	-	-	-	AES	
@0535	Generator Excitation Current	A	306.50	334.00	276.00	6.928	AES	
@0550	Gross Power Generator	kW	136342.429	137163.000	135072.000	375.251	AES	
@0551	Voltage Generator	kV	13.260	13.375	13.159	0.053	AES	
@0552	Current Generator	KA	5.870	5.919	5.765	0.032	AES	
@0553	Phi Power Factor	-	0.999	1.000	0.998	0.000	AES	
@0554	Frequentie Generator	Hz	50.126	50.370	49.722	0.144	AES	
@0555	Rotor Speed	rpm	3013.55	3028.05	2989.28	8.889	AES	
@0556	Reactive Power Generator	MVar	-4.0	0.582	-9.059	1.854965	AES	
@0560	Net Power Unit (kWh)	kW	125479.47	-	-	-	AES	



APPENDIX D2

Measurement Data Test at 95% Load

Tag	Performance Test Unit Date Time	95% Norgener #2 16 december 2015 09:00 hr. - 11:00 hr.	Unit	Average	Max	Min	Std	Origin
@0013	Condensate Inlet Deaerator Differential Pressure	mbar	163.92	172.31	155.27	2.958	DNV GL	
@0020	Condensate Inlet Deaerator Pressure	bar(a)	9.776	9.803	9.740	0.011	DNV GL	
@0021	Condensate Inlet Deaerator Temperature	°C	135.18	135.33	135.03	0.061	DNV GL	
@0050	Extraction Steam Pressure Deaerator	bar(a)	8.301	8.327	8.273	0.010	DNV GL	
@0051	Extraction Steam Temperature Deaerator	°C	356.65	357.37	355.60	0.326	DNV GL	
@0060	Feed Water Inlet Temperature Pump#1	°C	171.85	172.01	171.73	0.048	DNV GL	
@0061	Feed Water Inlet Temperature Pump#2	°C	0.00	0.00	0.00	0.000	DNV GL	
@0062	Feed Water Inlet Temperature Pump#3	°C	171.57	171.70	171.45	0.044	DNV GL	
@0077	Extraction Steam Pressure High Pressure Heater#5	bar(a)	20.70	20.77	20.63	0.026	DNV GL	
@0078	Extraction Steam Temperature High Pressure Heater#5	°C	270.07	270.22	269.88	0.065	DNV GL	
@0080	Barometer Pressure	bar(a)	1.00947	1.00965	1.00920	0.0001	DNV GL	
@0081	Ambient Air Temperature	°C	21.488	23.000	20.230	0.850	DNV GL	
@0082	Relative Humidity Ambient Air	%	68.983	72.588	64.218	2.380	DNV GL	
@0100	HP Feed Water Inlet Boiler Differential Pressure	mbar	401.04	417.87	389.28	5.427	DNV GL	
@0101	HP Feed Water Inlet Boiler Pressure	bar(a)	218.77	222.35	214.97	1.457	DNV GL	
@0102	HP Feed Water Inlet Boiler Temperature	°C	176.47	176.74	176.25	0.094	DNV GL	
@0105	HP Spray Water #1 Boiler Differential Pressure	mbar	0.621	2.500	0.014	1.050	DNV GL	
@0106	HP Spray Water #1 Boiler Pressure	bar(a)	215.81	219.25	211.96	1.466	DNV GL	
@0110	ReHeat Spray Water Boiler Differential Pressure	mbar	30.91	47.91	19.12	5.170	DNV GL	
@0111	ReHeat Spray Water Boiler Pressure	bar(a)	75.951	77.140	74.620	0.47	DNV GL	
@0112	ReHeat Spray Water#1 Boiler Temperature	°C	173.74	173.90	173.56	0.058	DNV GL	
@0113	ReHeat Spray Water#2 Boiler Temperature	°C	0.00	0.00	0.00	0.000	DNV GL	
@0114	ReHeat Spray Water#3 Boiler Temperature	°C	173.35	173.51	173.10	0.075	DNV GL	
@0115	HP Spray Water #2Boiler Differential Pressure	mbar	18.854	29.390	12.620	3.165	DNV GL	
@0116	HP Spray Water #2Boiler Pressure	bar(a)	215.71	219.20	211.92	1.463	DNV GL	
@0120	Extraction Steam Pressure High Pressure Heater#6	bar(a)	37.211	37.350	37.050	0.047	DNV GL	
@0121	Extraction Steam Temperature High Pressure Heater#6	°C	345.34	346.86	344.26	0.572	DNV GL	
@0123	Feed Water Inlet Temperature High Pressure Heater#6	°C	213.32	213.48	213.18	0.055	DNV GL	
@0124	Feed Water Outlet Pressure High Pressure Heater#6	bar(a)	179.83	180.54	178.75	0.354	DNV GL	
@0125	Feed Water Outlet Temperature High Pressure Heater#6	°C	246.40	246.50	246.30	0.043	DNV GL	
@0126	Drain Temperature High Pressure Heater#6	°C	218.58	218.71	218.47	0.048	DNV GL	
@0127	Drain Temperature High Pressure Heater#5	°C	189.81	189.98	189.61	0.076	DNV GL	
@0130	HP Steam Pressure Outlet Boiler	bar(a)	162.09	162.97	160.77	0.417	DNV GL	
@0131	HP Steam Temperature Outlet Boiler	°C	535.12	538.04	532.92	1.050	DNV GL	
@0133	Cold ReHeat Pressure Inlet Boiler	bar(a)	37.136	37.270	36.970	0.047	DNV GL	
@0134	Cold ReHeat Temperature Inlet Boiler	°C	345.64	347.24	344.48	0.585	DNV GL	
@0135	Hot ReHeat Pressure Outlet Boiler	bar(a)	34.124	34.250	33.990	0.045	DNV GL	
@0136	Hot ReHeat Temperature Outlet Boiler	°C	544.95	548.51	542.17	1.278	DNV GL	
@0140	Feed Water Inlet Temperature Boiler	bar(a)	177.65	178.35	176.59	0.353	DNV GL	
@0141	Feed Water Inlet Pressure Boiler	°C	253.90	254.14	253.71	0.069	DNV GL	
@0150	Cool Water Temperature Inlet Condenser (a)	°C	16.642	16.980	16.380	0.134	DNV GL	
@0151	Cool Water Temperature Inlet Condenser (b)	°C	16.575	16.910	16.310	0.134	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A1	°C	357.91	360.04	356.00	0.783	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A2	°C	359.46	361.62	357.24	0.907	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A3	°C	359.02	361.16	357.09	0.864	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A4	°C	362.00	364.09	360.20	0.800	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A5	°C	362.86	365.22	360.77	0.886	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A6	°C	363.41	365.68	361.36	0.933	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A7	°C	364.49	367.03	362.30	1.004	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A8	°C	364.40	366.93	362.21	0.975	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A9	°C	365.15	367.61	362.92	1.008	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A10	°C	368.12	370.87	365.79	1.067	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A11	°C	369.59	372.11	367.41	1.014	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A12	°C	366.12	368.40	364.07	0.958	DNV GL	

Tag	Performance Test Unit Date Time	95% Norgener #2 16 december 2015 09:00 hr. - 11:00 hr.	Unit	Average	Max	Min	Std	Origin
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A13	°C	365.24	367.72	363.39	0.909	0.909	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A14	°C	367.83	370.31	365.70	0.966	0.966	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A15	°C	366.22	368.36	364.28	0.906	0.906	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A16	°C	365.02	367.58	362.91	0.972	0.972	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A17	°C	369.12	371.69	366.91	0.987	0.987	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A18	°C	366.51	368.74	364.60	0.859	0.859	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A19	°C	356.71	359.18	354.89	0.927	0.927	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A20	°C	368.42	371.11	365.98	1.038	1.038	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A21	°C	364.54	366.78	362.55	0.879	0.879	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A22	°C	354.42	357.17	351.97	1.106	1.106	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A23	°C	360.60	363.07	358.53	0.899	0.899	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A24	°C	357.65	359.74	355.91	0.779	0.779	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A1	°C	133.40	134.33	132.59	0.480	0.480	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A2	°C	143.03	143.93	142.26	0.466	0.466	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A3	°C	151.26	152.35	150.26	0.501	0.501	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A4	°C	132.56	133.49	131.66	0.479	0.479	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A5	°C	139.94	140.87	139.16	0.485	0.485	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A6	°C	149.53	150.57	148.48	0.495	0.495	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A7	°C	130.48	131.32	129.65	0.428	0.428	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A8	°C	138.70	139.60	137.79	0.463	0.463	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A9	°C	148.37	149.32	147.28	0.509	0.509	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A10	°C	129.66	130.47	128.81	0.409	0.409	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A11	°C	139.34	140.30	138.51	0.424	0.424	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A12	°C	147.23	148.13	146.17	0.454	0.454	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A13	°C	128.55	129.30	127.73	0.384	0.384	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A14	°C	136.92	137.78	136.10	0.415	0.415	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A15	°C	146.64	147.50	145.66	0.445	0.445	DNV GL
@0261	Oxigen (O2) Inlet Air Heater A	vol%	3.73	4.20	3.10	0.28	0.28	Algoritmos
@0262	Oxigen (O2) Inlet Air Heater B	vol%	3.09	3.33	2.91	0.10	0.10	Algoritmos
@0265	Oxigen (O2) Outlet Air Heater	vol%	6.69	7.65	5.60	0.58	0.58	Algoritmos
@0267	Carbon Monoxide Outlet Air Heater	ppm	0.0	1.9	0.0	0.2	0.2	Algoritmos

Tag	Performance Test Unit Date Time	95% Norgener #2 16 december 2015 09:00 hr. - 11:00 hr.	Unit	Average	Max	Min	Std	Origin
@0012	Condensate Inlet Deaerator Mass Flow	t/h	324.88	337.05	313.93	3.341	AES	
@0021	Condensate Inlet Deaerator Temperature	°C	135.59	135.72	135.40	0.069	AES	
@0040	Mass Flow Feed Water Pump#1	t/h	186.79	190.16	183.46	1.378	AES	
@0041	Mass Flow Feed Water Pump#2	t/h	0.000	0.000	0.000	0.000	AES	
@0042	Mass Flow Feed Water Pump#3	t/h	219.66	224.47	214.50	1.629	AES	
@0050	Extraction Steam Pressure Deaerator	bar(a)	8.599	8.599	8.599	0.000	AES	
@0051	Extraction Steam Temperature Deaerator	°C	367.37	368.56	366.39	0.460	AES	
@0060	Feed Water Temperature Deaerator	°C	171.87	171.88	171.78	0.038	AES	
@0095	Extraction Steam Pressure High Pressure Heater#5	bar(a)	21.363	21.375	21.272	0.033	AES	
@0096	Extraction Steam Temperature High Pressure Heater#5	°C	490.00	491.40	488.86	0.531	AES	
@0300	Cold Primair Air Temperature	°C	23.773	24.414	23.297	0.322	AES	
@0305	Cold Secundair Air Temperature 201	°C	22.839	23.466	22.364	0.327	AES	
@0306	Cold Secundair Air Temperature 202	°C	23.488	24.111	23.003	0.314	AES	
@0310	Hot Primair Air Temperature	°C	337.33	338.46	336.20	0.543	AES	
@0315	Hot Secundair Air Temperature 154	°C	322.25	323.23	321.46	0.482	AES	
@0316	Hot Secundair Air Temperature 155	°C	330.25	331.19	329.31	0.521	AES	
@0320	Airflow Hot Secundair 21	t/h	112.20	118.70	107.11	2.219	AES	
@0321	Airflow Hot Secundair 22	t/h	124.84	131.33	119.10	2.178	AES	
@0325	Mass Flow Coal Feeder A	t/h	10.342	10.601	10.072	0.117	AES	
@0326	Mass Flow Coal Feeder B	t/h	10.447	10.737	10.169	0.114	AES	
@0327	Mass Flow Coal Feeder C	t/h	13.393	13.771	13.098	0.152	AES	
@0328	Mass Flow Coal Feeder D	t/h	13.414	13.771	13.037	0.147	AES	
@0330	Mass Flow Primair Air Mill A	t/h	32.137	32.802	31.680	0.203	AES	
@0331	Mass Flow Primair Air Mill D	t/h	25.816	27.071	24.666	0.329	AES	
@0332	Mass Flow Primair Air Mill C	t/h	28.532	29.074	27.897	0.218	AES	
@0333	Mass Flow Primair Air Mill D	t/h	29.051	29.682	28.567	0.201	AES	
@0340	Oxygen (O2) Inlet Air Heater A	vol %	2.017	2.328	1.712	0.103	AES	
@0341	Oxygen (O2) Inlet Air Heater B	vol %	2.579	2.928	2.308	0.107	AES	
@0350	X Position HP Valves	%	65.447	67.883	63.100	1.558	AES	
@0360	Make-Up Water Mass Flow	t/h	4.912	9.394	0.001	2.157	AES	
@0500	Power Consumption Mill A	kW	297.90	304.20	291.70	2.549	AES	
@0501	Power Consumption Mill B	kW	294.67	303.40	286.34	3.152	AES	
@0502	Power Consumption Mill C	kW	302.37	307.40	295.60	2.364	AES	
@0503	Power Consumption Mill D	kW	298.23	304.59	290.81	2.866	AES	
@0530	Gross Power Generator (kWh)	kW	129267.4	-	-	-	AES	
@0531	Auxiliary Power Consumption (kWh)	kW	9553.2	-	-	-	AES	
@0535	Generator Excitation Current	A	276.55	309.00	239.00	7.331	AES	
@0550	Gross Power Generator	kW	129320.850	130236.000	128582.000	288.234	AES	
@0551	Voltage Generator	kV	13.330	13.484	13.185	0.047	AES	
@0552	Current Generator	KA	5.518	5.622	5.490	0.017	AES	
@0553	Phi Power Factor	-	1.000	1.000	1.000	0.000	AES	
@0554	Frequentie Generator	Hz	50.160	50.472	49.777	0.139	AES	
@0555	Rotor Speed	rpm	3015.51	3036.66	2990.08	8.476	AES	
@0556	Reactive Power Generator	MVar	-0.2	3.352	-3.746	1.317535	AES	
@0560	Net Power Unit (kWh)	kW	118877.32	-	-	-	AES	



APPENDIX D3

Measurement Data Test at 90% Load

Tag	Performance Test Unit Date Time	90% Norgener #2 16 december 2015 12:45 hr. - 14:45 hr.	Unit	Average	Max	Min	Std	Origin
@0013	Condensate Inlet Deaerator Differential Pressure	mbar	147.54	160.85	140.00	3.079	DNV GL	
@0020	Condensate Inlet Deaerator Pressure	bar(a)	9.339	9.381	9.303	0.012	DNV GL	
@0021	Condensate Inlet Deaerator Temperature	°C	133.62	133.77	133.45	0.061	DNV GL	
@0050	Extraction Steam Pressure Deaerator	bar(a)	7.888	7.912	7.863	0.010	DNV GL	
@0051	Extraction Steam Temperature Deaerator	°C	357.02	357.58	355.93	0.260	DNV GL	
@0060	Feed Water Inlet Temperature Pump#1	°C	169.75	169.86	169.62	0.042	DNV GL	
@0061	Feed Water Inlet Temperature Pump#2	°C	0.00	0.00	0.00	0.000	DNV GL	
@0062	Feed Water Inlet Temperature Pump#3	°C	169.62	169.76	169.48	0.057	DNV GL	
@0077	Extraction Steam Pressure High Pressure Heater#5	bar(a)	19.66	19.73	19.58	0.029	DNV GL	
@0078	Extraction Steam Temperature High Pressure Heater#5	°C	266.75	266.91	266.61	0.056	DNV GL	
@0080	Barometer Pressure	bar(a)	1.00821	1.00872	1.00762	0.0003	DNV GL	
@0081	Ambient Air Temperature	°C	21.230	21.830	20.840	0.241	DNV GL	
@0082	Relative Humidity Ambient Air	%	63.975	67.902	60.560	1.659	DNV GL	
@0100	HP Feed Water Inlet Boiler Differential Pressure	mbar	357.92	371.56	343.85	5.445	DNV GL	
@0101	HP Feed Water Inlet Boiler Pressure	bar(a)	222.82	225.50	218.94	1.772	DNV GL	
@0102	HP Feed Water Inlet Boiler Temperature	°C	174.69	174.96	174.45	0.100	DNV GL	
@0105	HP Spray Water #1 Boiler Differential Pressure	mbar	0.585	4.450	0.006	1.028	DNV GL	
@0106	HP Spray Water #1 Boiler Pressure	bar(a)	219.87	222.56	215.99	1.767	DNV GL	
@0110	ReHeat Spray Water Boiler Differential Pressure	mbar	19.83	29.43	8.26	5.054	DNV GL	
@0111	ReHeat Spray Water Boiler Pressure	bar(a)	77.217	78.070	75.880	0.56	DNV GL	
@0112	ReHeat Spray Water#1 Boiler Temperature	°C	171.70	171.87	171.56	0.048	DNV GL	
@0113	ReHeat Spray Water#2 Boiler Temperature	°C	0.00	0.00	0.00	0.000	DNV GL	
@0114	ReHeat Spray Water#3 Boiler Temperature	°C	171.14	171.41	169.71	0.233	DNV GL	
@0115	HP Spray Water #2Boiler Differential Pressure	mbar	63.468	74.510	52.440	4.406	DNV GL	
@0116	HP Spray Water #2Boiler Pressure	bar(a)	219.74	222.41	215.74	1.762	DNV GL	
@0120	Extraction Steam Pressure High Pressure Heater#6	bar(a)	35.254	35.430	35.050	0.065	DNV GL	
@0121	Extraction Steam Temperature High Pressure Heater#6	°C	342.94	344.01	342.23	0.387	DNV GL	
@0123	Feed Water Inlet Temperature High Pressure Heater#6	°C	210.91	211.05	210.73	0.060	DNV GL	
@0124	Feed Water Outlet Pressure High Pressure Heater#6	bar(a)	176.58	177.22	175.50	0.317	DNV GL	
@0125	Feed Water Outlet Temperature High Pressure Heater#6	°C	243.67	243.81	243.53	0.044	DNV GL	
@0126	Drain Temperature High Pressure Heater#6	°C	215.87	215.96	215.70	0.048	DNV GL	
@0127	Drain Temperature High Pressure Heater#5	°C	186.95	187.21	186.72	0.084	DNV GL	
@0130	HP Steam Pressure Outlet Boiler	bar(a)	160.40	161.36	159.13	0.377	DNV GL	
@0131	HP Steam Temperature Outlet Boiler	°C	535.20	536.85	533.72	0.677	DNV GL	
@0133	Cold ReHeat Pressure Inlet Boiler	bar(a)	35.169	35.360	34.960	0.067	DNV GL	
@0134	Cold ReHeat Temperature Inlet Boiler	°C	343.07	344.15	342.31	0.430	DNV GL	
@0135	Hot ReHeat Pressure Outlet Boiler	bar(a)	32.303	32.470	32.130	0.060	DNV GL	
@0136	Hot ReHeat Temperature Outlet Boiler	°C	545.02	547.40	542.43	1.137	DNV GL	
@0140	Feed Water Inlet Temperature Boiler	bar(a)	174.60	175.24	173.55	0.316	DNV GL	
@0141	Feed Water Inlet Pressure Boiler	°C	251.10	251.28	250.93	0.062	DNV GL	
@0150	Cool Water Temperature Inlet Condenser (a)	°C	17.642	17.880	17.430	0.110	DNV GL	
@0151	Cool Water Temperature Inlet Condenser (b)	°C	17.576	17.820	17.360	0.110	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A1	°C	355.54	357.34	354.10	0.682	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A2	°C	357.67	359.72	355.70	0.937	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A3	°C	356.62	358.50	354.93	0.861	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A4	°C	359.25	361.19	357.64	0.784	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A5	°C	360.08	362.07	358.22	0.908	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A6	°C	360.66	362.54	358.90	0.941	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A7	°C	361.00	363.05	359.36	0.821	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A8	°C	361.61	363.74	359.64	1.042	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A9	°C	362.17	364.15	360.34	1.001	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A10	°C	363.77	365.83	362.32	0.681	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A11	°C	366.95	369.28	364.69	1.276	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A12	°C	363.62	365.79	361.53	1.193	DNV GL	

Tag	Performance Test Unit Date Time	90% Norgener #2 16 december 2015 12:45 hr. - 14:45 hr.	Unit	Average	Max	Min	Std	Origin
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A13	°C	362.29	364.10	360.72	0.725	0.725	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A14	°C	365.27	367.09	363.55	0.798	0.798	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A15	°C	363.30	364.91	361.94	0.769	0.769	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A16	°C	361.29	363.13	359.85	0.674	0.674	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A17	°C	366.06	368.03	364.35	0.802	0.802	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A18	°C	363.23	364.74	361.95	0.688	0.688	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A19	°C	351.35	353.30	349.68	0.732	0.732	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A20	°C	364.88	367.04	363.29	0.808	0.808	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A21	°C	361.19	362.92	359.90	0.690	0.690	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A22	°C	348.99	350.97	347.41	0.715	0.715	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A23	°C	356.91	358.98	355.47	0.772	0.772	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A24	°C	354.27	356.07	352.98	0.712	0.712	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A1	°C	137.39	138.19	136.67	0.421	0.421	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A2	°C	146.28	147.17	145.55	0.427	0.427	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A3	°C	154.17	155.14	153.30	0.427	0.427	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A4	°C	136.51	137.32	135.80	0.413	0.413	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A5	°C	143.54	144.29	142.88	0.399	0.399	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A6	°C	152.60	153.48	151.83	0.415	0.415	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A7	°C	134.55	135.31	133.91	0.388	0.388	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A8	°C	142.22	142.98	141.39	0.447	0.447	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A9	°C	151.42	152.28	150.66	0.410	0.410	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A10	°C	133.80	134.63	133.20	0.404	0.404	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A11	°C	142.96	143.73	142.31	0.410	0.410	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A12	°C	150.42	151.26	149.69	0.409	0.409	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A13	°C	132.76	133.61	132.19	0.403	0.403	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A14	°C	140.69	141.42	140.06	0.402	0.402	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A15	°C	146.64	147.50	145.66	0.445	0.445	DNV GL
@0261	Oxigen (O2) Inlet Air Heater A	vol%	3.03	3.36	2.79	0.11	0.11	Algoritmos
@0262	Oxigen (O2) Inlet Air Heater B	vol%	4.04	4.65	3.87	0.13	0.13	Algoritmos
@0265	Oxigen (O2) Outlet Air Heater	vol%	6.73	7.81	5.68	0.55	0.55	Algoritmos
@0267	Carbon Monoxide Outlet Air Heater	ppm	0.8	2.7	0.0	0.9	0.9	Algoritmos

Tag	Performance Test Unit Date Time	90% Norgener #2 16 december 2015 12:45 hr. - 14:45 hr.	Unit	Average	Max	Min	Std	Origin
@0012	Condensate Inlet Deaerator Mass Flow	t/h	308.28	319.65	296.57	3.332	AES	
@0021	Condensate Inlet Deaerator Temperature	°C	133.97	134.05	133.84	0.066	AES	
@0040	Mass Flow Feed Water Pump#1	t/h	177.23	180.35	173.73	1.440	AES	
@0041	Mass Flow Feed Water Pump#2	t/h	0.000	0.000	0.000	0.000	AES	
@0042	Mass Flow Feed Water Pump#3	t/h	206.94	210.50	203.29	1.603	AES	
@0050	Extraction Steam Pressure Deaerator	bar(a)	8.187	8.187	8.187	0.000	AES	
@0051	Extraction Steam Temperature Deaerator	°C	367.81	368.65	366.98	0.413	AES	
@0060	Feed Water Temperature Deaerator	°C	169.82	169.86	169.76	0.049	AES	
@0095	Extraction Steam Pressure High Pressure Heater#5	bar(a)	20.240	20.340	20.139	0.015	AES	
@0096	Extraction Steam Temperature High Pressure Heater#5	°C	490.00	490.92	489.07	0.457	AES	
@0300	Cold Primair Air Temperature	°C	27.042	27.559	26.547	0.342	AES	
@0305	Cold Secundair Air Temperature 201	°C	26.101	26.587	25.583	0.334	AES	
@0306	Cold Secundair Air Temperature 202	°C	26.720	27.230	26.222	0.341	AES	
@0310	Hot Primair Air Temperature	°C	335.83	336.70	334.66	0.569	AES	
@0315	Hot Secundair Air Temperature 154	°C	321.76	322.52	320.65	0.539	AES	
@0316	Hot Secundair Air Temperature 155	°C	329.40	330.14	328.37	0.506	AES	
@0320	Airflow Hot Secundair 21	t/h	105.78	112.58	99.82	2.161	AES	
@0321	Airflow Hot Secundair 22	t/h	117.50	121.97	111.91	1.824	AES	
@0325	Mass Flow Coal Feeder A	t/h	9.783	10.107	9.479	0.115	AES	
@0326	Mass Flow Coal Feeder B	t/h	9.856	10.345	9.478	0.135	AES	
@0327	Mass Flow Coal Feeder C	t/h	12.656	13.203	12.122	0.169	AES	
@0328	Mass Flow Coal Feeder D	t/h	12.674	13.126	12.265	0.149	AES	
@0330	Mass Flow Primair Air Mill A	t/h	31.677	32.346	30.823	0.284	AES	
@0331	Mass Flow Primair Air Mill D	t/h	25.380	26.171	24.641	0.231	AES	
@0332	Mass Flow Primair Air Mill C	t/h	28.091	28.672	27.515	0.225	AES	
@0333	Mass Flow Primair Air Mill D	t/h	28.600	29.342	28.130	0.205	AES	
@0340	Oxygen (O2) Inlet Air Heater A	vol %	2.179	2.534	1.923	0.102	AES	
@0341	Oxygen (O2) Inlet Air Heater B	vol %	2.654	2.854	2.433	0.094	AES	
@0350	X Position HP Valves	%	63.732	66.178	61.369	1.909	AES	
@0360	Make-Up Water Mass Flow	t/h	4.156	7.727	0.012	2.833	AES	
@0500	Power Consumption Mill A	kW	299.47	306.17	290.91	2.647	AES	
@0501	Power Consumption Mill B	kW	295.20	306.43	286.18	2.959	AES	
@0502	Power Consumption Mill C	kW	303.70	310.18	295.69	2.455	AES	
@0503	Power Consumption Mill D	kW	299.11	306.84	289.45	3.072	AES	
@0530	Gross Power Generator (kWh)	kW	122472.0	-	-	-	AES	
@0531	Auxiliary Power Consumption (kWh)	kW	9228.1	-	-	-	AES	
@0535	Generator Excitation Current	A	252.52	290.00	211.00	6.987	AES	
@0550	Gross Power Generator	kW	122549.419	123405.457	121891.029	289.753	AES	
@0551	Voltage Generator	kV	13.333	13.453	13.168	0.051	AES	
@0552	Current Generator	KA	5.232	5.350	5.175	0.028	AES	
@0553	Phi Power Factor	-	1.000	1.000	0.999	0.000	AES	
@0554	Frequentie Generator	Hz	50.070	50.281	49.745	0.160	AES	
@0555	Rotor Speed	rpm	3009.79	3023.14	2987.58	9.792	AES	
@0556	Reactive Power Generator	MVar	0.5	4.390625	-4.9960938	1.779081	AES	
@0560	Net Power Unit (kWh)	kW	112467.82	-	-	-	AES	



APPENDIX D4

Measurement Data Test at 80% Load

Tag	Performance Test Unit Date Time	80% Norgener #2 17 december 2015 09:30 hr. - 11:30 hr.	Unit	Average	Max	Min	Std	Origin
@0013	Condensate Inlet Deaerator Differential Pressure	mbar	113.48	124.80	105.11	3.074	DNV GL	
@0020	Condensate Inlet Deaerator Pressure	bar(a)	8.342	8.419	8.293	0.015	DNV GL	
@0021	Condensate Inlet Deaerator Temperature	°C	129.62	129.75	129.48	0.053	DNV GL	
@0050	Extraction Steam Pressure Deaerator	bar(a)	6.928	6.963	6.891	0.012	DNV GL	
@0051	Extraction Steam Temperature Deaerator	°C	353.13	357.52	348.04	2.531	DNV GL	
@0060	Feed Water Inlet Temperature Pump#1	°C	164.46	164.62	164.35	0.052	DNV GL	
@0061	Feed Water Inlet Temperature Pump#2	°C	0.00	0.00	0.00	0.000	DNV GL	
@0062	Feed Water Inlet Temperature Pump#3	°C	164.35	164.50	164.22	0.054	DNV GL	
@0077	Extraction Steam Pressure High Pressure Heater#5	bar(a)	17.23	17.32	17.13	0.037	DNV GL	
@0078	Extraction Steam Temperature High Pressure Heater#5	°C	257.90	258.09	257.58	0.113	DNV GL	
@0080	Barometer Pressure	bar(a)	1.00824	1.00836	1.00813	0.0001	DNV GL	
@0081	Ambient Air Temperature	°C	20.838	21.490	20.440	0.208	DNV GL	
@0082	Relative Humidity Ambient Air	%	61.607	63.146	59.267	1.047	DNV GL	
@0100	HP Feed Water Inlet Boiler Differential Pressure	mbar	277.85	292.76	264.40	6.466	DNV GL	
@0101	HP Feed Water Inlet Boiler Pressure	bar(a)	232.55	237.72	226.86	2.110	DNV GL	
@0102	HP Feed Water Inlet Boiler Temperature	°C	169.97	170.22	169.71	0.099	DNV GL	
@0105	HP Spray Water #1 Boiler Differential Pressure	mbar	0.446	1.800	0.003	0.850	DNV GL	
@0106	HP Spray Water #1 Boiler Pressure	bar(a)	229.65	234.75	223.97	2.125	DNV GL	
@0110	ReHeat Spray Water Boiler Differential Pressure	mbar	0.19	0.75	0.01	0.299	DNV GL	
@0111	ReHeat Spray Water Boiler Pressure	bar(a)	80.406	82.100	78.520	0.70	DNV GL	
@0112	ReHeat Spray Water#1 Boiler Temperature	°C	127.30	165.20	119.22	14.589	DNV GL	
@0113	ReHeat Spray Water#2 Boiler Temperature	°C	0.00	0.00	0.00	0.000	DNV GL	
@0114	ReHeat Spray Water#3 Boiler Temperature	°C	97.81	101.68	96.14	1.425	DNV GL	
@0115	HP Spray Water #2 Boiler Differential Pressure	mbar	8.202	22.580	0.003	6.607	DNV GL	
@0116	HP Spray Water #2Boiler Pressure	bar(a)	229.57	234.69	223.83	2.120	DNV GL	
@0120	Extraction Steam Pressure High Pressure Heater#6	bar(a)	30.825	31.030	30.590	0.080	DNV GL	
@0121	Extraction Steam Temperature High Pressure Heater#6	°C	334.14	336.95	332.66	0.923	DNV GL	
@0123	Feed Water Inlet Temperature High Pressure Heater#6	°C	204.46	204.63	204.26	0.078	DNV GL	
@0124	Feed Water Outlet Pressure High Pressure Heater#6	bar(a)	170.85	172.04	169.89	0.403	DNV GL	
@0125	Feed Water Outlet Temperature High Pressure Heater#6	°C	236.33	236.46	236.18	0.061	DNV GL	
@0126	Drain Temperature High Pressure Heater#6	°C	209.06	209.20	208.85	0.072	DNV GL	
@0127	Drain Temperature High Pressure Heater#5	°C	181.08	181.25	180.91	0.069	DNV GL	
@0130	HP Steam Pressure Outlet Boiler	bar(a)	157.26	158.43	156.07	0.456	DNV GL	
@0131	HP Steam Temperature Outlet Boiler	°C	536.49	541.17	534.16	1.472	DNV GL	
@0133	Cold ReHeat Pressure Inlet Boiler	bar(a)	30.746	30.970	30.510	0.082	DNV GL	
@0134	Cold ReHeat Temperature Inlet Boiler	°C	334.43	337.31	333.00	0.933	DNV GL	
@0135	Hot ReHeat Pressure Outlet Boiler	bar(a)	28.208	28.410	27.990	0.076	DNV GL	
@0136	Hot ReHeat Temperature Outlet Boiler	°C	543.05	546.83	537.27	2.060	DNV GL	
@0140	Feed Water Inlet Temperature Boiler	bar(a)	169.20	170.36	168.18	0.401	DNV GL	
@0141	Feed Water Inlet Pressure Boiler	°C	243.67	243.87	243.44	0.088	DNV GL	
@0150	Cool Water Temperature Inlet Condenser (a)	°C	16.655	16.870	16.360	0.139	DNV GL	
@0151	Cool Water Temperature Inlet Condenser (b)	°C	16.588	16.800	16.300	0.139	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A1	°C	339.24	341.15	336.60	0.989	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A2	°C	340.50	342.63	337.74	1.083	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A3	°C	339.85	342.01	337.17	1.024	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A4	°C	343.12	345.20	340.48	1.039	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A5	°C	343.98	346.09	341.22	1.060	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A6	°C	343.84	346.03	341.12	1.059	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A7	°C	344.64	346.93	341.74	1.107	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A8	°C	345.22	347.27	342.56	1.065	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A9	°C	345.65	347.76	343.01	1.047	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A10	°C	348.20	350.55	345.31	1.113	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A11	°C	349.74	352.05	346.89	1.125	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A12	°C	346.32	348.41	343.64	1.073	DNV GL	

Tag	Performance Test Unit Date Time	80% Norgener #2 17 december 2015 09:30 hr. - 11:30 hr.	Unit	Average	Max	Min	Std	Origin
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A13	°C	346.77	348.77	344.04	1.058	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A14	°C	348.89	351.08	346.02	1.123	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A15	°C	346.81	348.78	344.14	1.064	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A16	°C	344.90	346.71	342.37	0.945	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A17	°C	350.05	352.19	347.01	1.146	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A18	°C	347.14	349.02	344.52	1.052	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A19	°C	335.76	337.89	333.26	1.014	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A20	°C	348.46	350.50	345.55	1.103	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A21	°C	344.88	346.73	342.34	1.015	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A22	°C	333.48	335.28	330.88	0.933	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A23	°C	341.11	343.26	338.29	1.128	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A24	°C	338.27	340.29	335.64	1.057	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A1	°C	127.55	128.71	126.07	0.665	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A2	°C	134.40	135.61	132.91	0.704	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A3	°C	141.38	142.71	139.79	0.711	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A4	°C	126.89	127.99	125.51	0.646	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A5	°C	132.56	133.74	131.16	0.666	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A6	°C	140.35	141.62	138.79	0.706	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A7	°C	125.12	126.17	123.80	0.644	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A8	°C	131.30	132.33	129.94	0.568	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A9	°C	139.63	140.81	138.08	0.667	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A10	°C	124.43	125.50	123.16	0.637	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A11	°C	131.82	132.93	130.44	0.666	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A12	°C	138.61	139.79	137.11	0.663	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A13	°C	123.56	124.68	122.28	0.645	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A14	°C	130.11	131.22	128.71	0.682	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A15	°C	138.19	139.33	136.62	0.703	DNV GL	
@0261	Oxigen (O2) Inlet Air Heater A	vol%	3.58	4.28	3.06	0.32	Algoritmos	
@0262	Oxigen (O2) Inlet Air Heater B	vol%	4.02	4.25	3.82	0.09	Algoritmos	
@0265	Oxigen (O2) Outlet Air Heater	vol%	7.09	7.97	6.10	0.48	Algoritmos	
@0267	Carbon Monoxide Outlet Air Heater	ppm	0.0	0.0	0.0	0.0	Algoritmos	

Tag	Performance Test Unit Date Time	80% Norgener #2 17 december 2015 09:30 hr. - 11:30 hr.	Unit	Average	Max	Min	Std	Origin
@0012	Condensate Inlet Deaerator Mass Flow	t/h	270.88	286.54	259.42	4.257	AES	
@0021	Condensate Inlet Deaerator Temperature	°C	129.91	130.03	129.75	0.048	AES	
@0040	Mass Flow Feed Water Pump#1	t/h	157.00	161.35	151.71	2.078	AES	
@0041	Mass Flow Feed Water Pump#2	t/h	0.000	0.000	0.000	0.000	AES	
@0042	Mass Flow Feed Water Pump#3	t/h	183.01	187.12	178.54	1.971	AES	
@0050	Extraction Steam Pressure Deaerator	bar(a)	7.250	7.250	0.000	0.000	AES	
@0051	Extraction Steam Temperature Deaerator	°C	367.13	369.66	363.10	1.568	AES	
@0060	Feed Water Temperature Deaerator	°C	164.58	164.66	164.56	0.044	AES	
@0095	Extraction Steam Pressure High Pressure Heater#5	bar(a)	17.728	17.846	17.598	0.035	AES	
@0096	Extraction Steam Temperature High Pressure Heater#5	°C	487.73	490.48	483.38	1.736	AES	
@0300	Cold Primair Air Temperature	°C	26.049	26.863	25.637	0.266	AES	
@0305	Cold Secundair Air Temperature 201	°C	25.084	25.885	24.581	0.268	AES	
@0306	Cold Secundair Air Temperature 202	°C	25.703	26.430	25.222	0.255	AES	
@0310	Hot Primair Air Temperature	°C	319.04	320.49	317.23	0.870	AES	
@0315	Hot Secundair Air Temperature 154	°C	305.51	306.97	303.73	0.878	AES	
@0316	Hot Secundair Air Temperature 155	°C	313.58	314.97	311.84	0.863	AES	
@0320	Airflow Hot Secundair 21	t/h	97.62	103.53	92.10	2.179	AES	
@0321	Airflow Hot Secundair 22	t/h	108.66	114.11	104.11	1.953	AES	
@0325	Mass Flow Coal Feeder A	t/h	12.359	12.866	11.719	0.202	AES	
@0326	Mass Flow Coal Feeder B	t/h	12.458	13.004	11.918	0.219	AES	
@0327	Mass Flow Coal Feeder C	t/h	14.040	14.716	13.418	0.253	AES	
@0328	Mass Flow Coal Feeder D	t/h	0.039	0.039	0.039	0.000	AES	
@0330	Mass Flow Primair Air Mill A	t/h	32.961	33.846	32.365	0.231	AES	
@0331	Mass Flow Primair Air Mill D	t/h	27.228	28.098	26.548	0.275	AES	
@0332	Mass Flow Primair Air Mill C	t/h	28.912	29.602	28.148	0.237	AES	
@0333	Mass Flow Primair Air Mill D	t/h	-0.002	-0.002	-0.002	0.000	AES	
@0340	Oxygen (O2) Inlet Air Heater A	vol %	2.839	3.061	2.452	0.107	AES	
@0341	Oxygen (O2) Inlet Air Heater B	vol %	2.630	2.845	2.330	0.101	AES	
@0350	X Position HP Valves	%	61.104	63.602	58.697	1.806	AES	
@0360	Make-Up Water Mass Flow	t/h	5.311	6.040	1.161	0.556	AES	
@0500	Power Consumption Mill A	kW	295.56	302.26	288.00	2.914	AES	
@0501	Power Consumption Mill B	kW	297.23	306.52	287.93	3.494	AES	
@0502	Power Consumption Mill C	kW	301.36	307.52	294.27	2.504	AES	
@0503	Power Consumption Mill D	kW	0.88	0.88	0.88	0.000	AES	
@0530	Gross Power Generator (kWh)	kW	108664.0	-	-	-	AES	
@0531	Auxiliary Power Consumption (kWh)	kW	8551.6	-	-	-	AES	
@0535	Generator Excitation Current	A	207.76	236.00	180.00	7.441	AES	
@0550	Gross Power Generator	kW	108796.346	110128.000	107921.000	338.487	AES	
@0551	Voltage Generator	kV	13.340	13.463	13.171	0.051	AES	
@0552	Current Generator	KA	4.642	4.736	4.608	0.016	AES	
@0553	Phi Power Factor	-	1.000	1.000	0.999	0.000	AES	
@0554	Frequentie Generator	Hz	50.027	50.445	49.611	0.184	AES	
@0555	Rotor Speed	rpm	3005.43	3030.55	2978.57	11.088	AES	
@0556	Reactive Power Generator	MVar	1.1	4.734	-3.203	1.440289	AES	
@0560	Net Power Unit (kWh)	kW	99499.161	-	-	-	AES	



APPENDIX D5

Measurement Data Test at 70% Load

Tag	Performance Test Unit Date Time	70% Norgener #2 17 december 2015 13:00 hr. - 15:00 hr.	Unit	Average	Max	Min	Std	Origin
@0013	Condensate Inlet Deaerator Differential Pressure	mbar	86.77	95.92	81.19	2.749	DNV GL	
@0020	Condensate Inlet Deaerator Pressure	bar(a)	7.445	7.476	7.413	0.013	DNV GL	
@0021	Condensate Inlet Deaerator Temperature	°C	125.52	125.62	125.41	0.035	DNV GL	
@0050	Extraction Steam Pressure Deaerator	bar(a)	6.075	6.099	6.052	0.009	DNV GL	
@0051	Extraction Steam Temperature Deaerator	°C	352.64	356.12	350.34	1.298	DNV GL	
@0060	Feed Water Inlet Temperature Pump#1	°C	159.25	159.38	159.14	0.039	DNV GL	
@0061	Feed Water Inlet Temperature Pump#2	°C	0.00	0.00	0.00	0.000	DNV GL	
@0062	Feed Water Inlet Temperature Pump#3	°C	159.16	159.33	159.04	0.051	DNV GL	
@0077	Extraction Steam Pressure High Pressure Heater#5	bar(a)	15.09	15.17	15.01	0.033	DNV GL	
@0078	Extraction Steam Temperature High Pressure Heater#5	°C	248.92	249.08	248.73	0.072	DNV GL	
@0080	Barometer Pressure	bar(a)	1.00705	1.00768	1.00658	0.0003	DNV GL	
@0081	Ambient Air Temperature	°C	21.368	21.870	20.740	0.301	DNV GL	
@0082	Relative Humidity Ambient Air	%	64.474	68.103	61.055	1.827	DNV GL	
@0100	HP Feed Water Inlet Boiler Differential Pressure	mbar	206.07	225.24	180.15	11.050	DNV GL	
@0101	HP Feed Water Inlet Boiler Pressure	bar(a)	243.01	247.39	238.20	1.715	DNV GL	
@0102	HP Feed Water Inlet Boiler Temperature	°C	165.42	165.62	165.18	0.078	DNV GL	
@0105	HP Spray Water #1 Boiler Differential Pressure	mbar	0.663	3.800	0.006	1.160	DNV GL	
@0106	HP Spray Water #1 Boiler Pressure	bar(a)	240.12	244.46	235.20	1.726	DNV GL	
@0110	ReHeat Spray Water Boiler Differential Pressure	mbar	0.17	0.80	-1.01	0.273	DNV GL	
@0111	ReHeat Spray Water Boiler Pressure	bar(a)	83.115	84.460	81.530	0.56	DNV GL	
@0112	ReHeat Spray Water#1 Boiler Temperature	°C	97.28	104.81	93.15	3.057	DNV GL	
@0113	ReHeat Spray Water#2 Boiler Temperature	°C	0.00	0.00	0.00	0.000	DNV GL	
@0114	ReHeat Spray Water#3 Boiler Temperature	°C	113.97	159.81	110.29	8.045	DNV GL	
@0115	HP Spray Water #2Boiler Differential Pressure	mbar	39.949	57.730	25.330	7.556	DNV GL	
@0116	HP Spray Water #2Boiler Pressure	bar(a)	240.02	244.30	235.11	1.723	DNV GL	
@0120	Extraction Steam Pressure High Pressure Heater#6	bar(a)	26.813	26.930	26.660	0.053	DNV GL	
@0121	Extraction Steam Temperature High Pressure Heater#6	°C	324.67	325.33	324.10	0.252	DNV GL	
@0123	Feed Water Inlet Temperature High Pressure Heater#6	°C	198.33	198.46	198.23	0.045	DNV GL	
@0124	Feed Water Outlet Pressure High Pressure Heater#6	bar(a)	165.32	166.23	164.17	0.378	DNV GL	
@0125	Feed Water Outlet Temperature High Pressure Heater#6	°C	229.03	229.15	228.93	0.038	DNV GL	
@0126	Drain Temperature High Pressure Heater#6	°C	202.01	202.17	201.86	0.058	DNV GL	
@0127	Drain Temperature High Pressure Heater#5	°C	174.76	174.91	174.57	0.063	DNV GL	
@0130	HP Steam Pressure Outlet Boiler	bar(a)	154.44	155.29	153.33	0.387	DNV GL	
@0131	HP Steam Temperature Outlet Boiler	°C	535.79	537.16	534.75	0.579	DNV GL	
@0133	Cold ReHeat Pressure Inlet Boiler	bar(a)	26.728	26.860	26.570	0.054	DNV GL	
@0134	Cold ReHeat Temperature Inlet Boiler	°C	324.97	325.68	324.49	0.266	DNV GL	
@0135	Hot ReHeat Pressure Outlet Boiler	bar(a)	24.519	24.650	24.370	0.051	DNV GL	
@0136	Hot ReHeat Temperature Outlet Boiler	°C	542.88	546.90	540.02	1.688	DNV GL	
@0140	Feed Water Inlet Temperature Boiler	bar(a)	163.99	164.95	162.95	0.376	DNV GL	
@0141	Feed Water Inlet Pressure Boiler	°C	236.26	236.44	236.05	0.062	DNV GL	
@0150	Cool Water Temperature Inlet Condenser (a)	°C	16.844	17.100	16.410	0.163	DNV GL	
@0151	Cool Water Temperature Inlet Condenser (b)	°C	16.777	17.030	16.340	0.163	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A1	°C	331.65	333.43	330.37	0.719	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A2	°C	332.98	335.02	331.39	0.840	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A3	°C	331.96	333.70	330.35	0.797	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A4	°C	335.17	336.85	333.88	0.700	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A5	°C	336.23	338.42	334.63	0.912	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A6	°C	335.92	337.80	334.28	0.859	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A7	°C	336.41	338.11	335.00	0.730	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A8	°C	337.06	339.13	335.52	0.858	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A9	°C	337.41	339.30	335.93	0.825	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A10	°C	338.93	340.29	337.75	0.605	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A11	°C	341.91	344.19	339.93	1.071	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A12	°C	338.67	340.80	336.72	1.044	DNV GL	

Tag	Performance Test Unit Date Time	70% Norgener #2 17 december 2015 13:00 hr. - 15:00 hr.	Unit	Average	Max	Min	Std	Origin
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A13	°C	338.55	340.22	336.94	0.768	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A14	°C	340.63	342.68	338.99	0.866	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A15	°C	338.58	340.41	336.94	0.828	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A16	°C	336.58	338.34	335.25	0.739	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A17	°C	341.32	343.50	339.79	0.895	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A18	°C	338.60	340.63	337.06	0.865	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A19	°C	326.64	328.00	325.56	0.588	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A20	°C	340.10	342.58	338.51	0.952	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A21	°C	336.43	338.60	334.93	0.878	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A22	°C	324.56	325.90	323.38	0.606	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A23	°C	332.61	335.10	331.05	0.938	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A24	°C	329.75	332.16	328.17	0.915	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A1	°C	127.20	127.60	126.62	0.212	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A2	°C	132.78	133.28	132.27	0.242	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A3	°C	138.95	139.58	138.33	0.272	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A4	°C	126.61	126.96	125.97	0.197	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A5	°C	131.30	131.67	130.75	0.204	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A6	°C	138.25	138.79	137.70	0.245	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A7	°C	124.98	125.33	124.41	0.185	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A8	°C	130.00	130.46	129.47	0.225	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A9	°C	137.58	138.10	137.02	0.240	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A10	°C	124.48	124.89	124.00	0.199	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A11	°C	130.67	131.09	130.25	0.204	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A12	°C	136.75	137.28	136.27	0.236	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A13	°C	123.68	124.10	123.20	0.209	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A14	°C	129.31	129.70	128.81	0.197	DNV GL	
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A15	°C	136.35	136.85	135.87	0.217	DNV GL	
@0261	Oxigen (O2) Inlet Air Heater A	vol%	4.40	4.70	4.22	0.09	Algoritmos	
@0262	Oxigen (O2) Inlet Air Heater B	vol%	4.37	4.62	4.15	0.10	Algoritmos	
@0265	Oxigen (O2) Outlet Air Heater	vol%	7.50	8.22	6.68	0.44	Algoritmos	
@0267	Carbon Monoxide Outlet Air Heater	ppm	0.7	1.6	0.0	0.7	Algoritmos	

Tag	Performance Test Unit Date Time	70% Norgener #2 17 december 2015 13:00 hr. - 15:00 hr.	Unit	Average	Max	Min	Std	Origin
@0012	Condensate Inlet Deaerator Mass Flow	t/h	236.59	251.43	228.28	3.706	AES	
@0021	Condensate Inlet Deaerator Temperature	°C	125.73	125.74	125.63	0.026	AES	
@0040	Mass Flow Feed Water Pump#1	t/h	133.09	139.60	123.81	3.863	AES	
@0041	Mass Flow Feed Water Pump#2	t/h	0.000	0.000	0.000	0.000	AES	
@0042	Mass Flow Feed Water Pump#3	t/h	160.48	166.77	152.18	3.615	AES	
@0050	Extraction Steam Pressure Deaerator	bar(a)	6.337	6.337	6.337	0.000	AES	
@0051	Extraction Steam Temperature Deaerator	°C	368.42	370.99	366.00	1.316	AES	
@0060	Feed Water Temperature Deaerator	°C	159.44	159.44	159.44	0.000	AES	
@0095	Extraction Steam Pressure High Pressure Heater#5	bar(a)	15.516	15.545	15.425	0.039	AES	
@0096	Extraction Steam Temperature High Pressure Heater#5	°C	487.92	490.76	485.25	1.443	AES	
@0300	Cold Primair Air Temperature	°C	27.448	27.773	27.160	0.201	AES	
@0305	Cold Secundair Air Temperature 201	°C	26.466	26.793	26.088	0.211	AES	
@0306	Cold Secundair Air Temperature 202	°C	27.109	27.436	26.833	0.198	AES	
@0310	Hot Primair Air Temperature	°C	312.18	313.35	311.12	0.626	AES	
@0315	Hot Secundair Air Temperature 154	°C	299.69	300.87	298.79	0.590	AES	
@0316	Hot Secundair Air Temperature 155	°C	307.39	308.41	306.43	0.554	AES	
@0320	Airflow Hot Secundair 21	t/h	87.47	91.26	82.81	1.897	AES	
@0321	Airflow Hot Secundair 22	t/h	94.73	99.66	90.33	1.701	AES	
@0325	Mass Flow Coal Feeder A	t/h	10.882	11.279	10.468	0.137	AES	
@0326	Mass Flow Coal Feeder B	t/h	10.974	11.398	10.467	0.154	AES	
@0327	Mass Flow Coal Feeder C	t/h	12.383	12.810	11.764	0.174	AES	
@0328	Mass Flow Coal Feeder D	t/h	0.039	0.039	0.039	0.000	AES	
@0330	Mass Flow Primair Air Mill A	t/h	32.351	33.003	31.790	0.224	AES	
@0331	Mass Flow Primair Air Mill D	t/h	26.182	27.047	25.364	0.275	AES	
@0332	Mass Flow Primair Air Mill C	t/h	27.926	28.602	26.889	0.266	AES	
@0333	Mass Flow Primair Air Mill D	t/h	-0.002	-0.002	-0.002	0.000	AES	
@0340	Oxygen (O2) Inlet Air Heater A	vol %	3.272	3.562	3.048	0.088	AES	
@0341	Oxygen (O2) Inlet Air Heater B	vol %	2.967	3.156	2.731	0.092	AES	
@0350	X Position HP Valves	%	52.692	53.512	51.795	0.423	AES	
@0360	Make-Up Water Mass Flow	t/h	5.096	7.611	0.096	1.587	AES	
@0500	Power Consumption Mill A	kW	294.94	300.53	288.32	2.270	AES	
@0501	Power Consumption Mill B	kW	292.97	301.54	286.41	2.761	AES	
@0502	Power Consumption Mill C	kW	300.05	307.31	294.34	2.210	AES	
@0503	Power Consumption Mill D	kW	0.88	0.88	0.88	0.000	AES	
@0530	Gross Power Generator (kWh)	kW	95406.7	-	-	-	AES	
@0531	Auxiliary Power Consumption (kWh)	kW	8082.5	-	-	-	AES	
@0535	Generator Excitation Current	A	177.05	201.00	146.00	5.502	AES	
@0550	Gross Power Generator	kW	95580.433	96282.000	94688.000	269.342	AES	
@0551	Voltage Generator	kV	13.329	13.460	13.181	0.050	AES	
@0552	Current Generator	KA	4.079	4.165	3.992	0.032	AES	
@0553	Phi Power Factor	-	0.998	1.000	0.996	0.001	AES	
@0554	Frequentie Generator	Hz	50.130	50.365	49.829	0.121	AES	
@0555	Rotor Speed	rpm	3010.73	3029.85	2988.78	7.395	AES	
@0556	Reactive Power Generator	MVar	-5.1	-0.965	-8.961	1.434886	AES	
@0560	Net Power Unit (kWh)	kW	86802.95	-	-	-	AES	



APPENDIX D6

Measurement Data Test at 47% Load

Tag	Performance Test Unit Date Time	47% Norgener #2 17 december 2015 17:00 hr. - 19:00 hr.	Unit	Average	Max	Min	Std	Origin
@0013	Condensate Inlet Deaerator Differential Pressure	mbar	45.08	50.28	40.29	2.317	DNV GL	
@0020	Condensate Inlet Deaerator Pressure	bar(a)	5.625	5.682	5.573	0.017	DNV GL	
@0021	Condensate Inlet Deaerator Temperature	°C	114.81	114.90	114.71	0.039	DNV GL	
@0050	Extraction Steam Pressure Deaerator	bar(a)	4.306	4.329	4.280	0.010	DNV GL	
@0051	Extraction Steam Temperature Deaerator	°C	334.51	335.16	334.06	0.242	DNV GL	
@0060	Feed Water Inlet Temperature Pump#1	°C	146.22	146.31	146.10	0.039	DNV GL	
@0061	Feed Water Inlet Temperature Pump#2	°C	0.00	0.00	0.00	0.000	DNV GL	
@0062	Feed Water Inlet Temperature Pump#3	°C	146.14	146.28	146.04	0.051	DNV GL	
@0077	Extraction Steam Pressure High Pressure Heater#5	bar(a)	10.62	10.71	10.53	0.036	DNV GL	
@0078	Extraction Steam Temperature High Pressure Heater#5	°C	224.75	224.89	224.59	0.054	DNV GL	
@0080	Barometer Pressure	bar(a)	1.00513	1.00578	1.00480	0.0003	DNV GL	
@0081	Ambient Air Temperature	°C	20.651	21.090	20.180	0.247	DNV GL	
@0082	Relative Humidity Ambient Air	%	74.842	77.501	70.638	1.909	DNV GL	
@0100	HP Feed Water Inlet Boiler Differential Pressure	mbar	98.96	117.60	76.09	13.331	DNV GL	
@0101	HP Feed Water Inlet Boiler Pressure	bar(a)	246.76	252.68	242.17	2.591	DNV GL	
@0102	HP Feed Water Inlet Boiler Temperature	°C	152.56	152.78	152.28	0.084	DNV GL	
@0105	HP Spray Water #1 Boiler Differential Pressure	mbar	0.907	3.870	0.028	0.947	DNV GL	
@0106	HP Spray Water #1 Boiler Pressure	bar(a)	243.91	249.87	239.30	2.596	DNV GL	
@0110	ReHeat Spray Water Boiler Differential Pressure	mbar	3.90	12.49	0.26	2.373	DNV GL	
@0111	ReHeat Spray Water Boiler Pressure	bar(a)	82.985	84.930	81.410	0.89	DNV GL	
@0112	ReHeat Spray Water#1 Boiler Temperature	°C	130.48	136.80	124.65	3.783	DNV GL	
@0113	ReHeat Spray Water#2 Boiler Temperature	°C	0.00	0.00	0.00	0.000	DNV GL	
@0114	ReHeat Spray Water#3 Boiler Temperature	°C	148.30	148.46	148.15	0.059	DNV GL	
@0115	HP Spray Water #2 Boiler Differential Pressure	mbar	18.156	23.340	12.630	1.992	DNV GL	
@0116	HP Spray Water #2Boiler Pressure	bar(a)	243.83	249.83	239.18	2.590	DNV GL	
@0120	Extraction Steam Pressure High Pressure Heater#6	bar(a)	18.652	18.770	18.490	0.048	DNV GL	
@0121	Extraction Steam Temperature High Pressure Heater#6	°C	296.41	296.78	296.05	0.168	DNV GL	
@0123	Feed Water Inlet Temperature High Pressure Heater#6	°C	182.23	182.39	182.08	0.060	DNV GL	
@0124	Feed Water Outlet Pressure High Pressure Heater#6	bar(a)	160.14	160.76	159.43	0.260	DNV GL	
@0125	Feed Water Outlet Temperature High Pressure Heater#6	°C	210.19	210.31	210.07	0.048	DNV GL	
@0126	Drain Temperature High Pressure Heater#6	°C	184.29	184.39	184.15	0.051	DNV GL	
@0127	Drain Temperature High Pressure Heater#5	°C	159.45	159.70	159.26	0.074	DNV GL	
@0130	HP Steam Pressure Outlet Boiler	bar(a)	153.56	154.13	152.90	0.237	DNV GL	
@0131	HP Steam Temperature Outlet Boiler	°C	525.89	526.78	525.06	0.360	DNV GL	
@0133	Cold ReHeat Pressure Inlet Boiler	bar(a)	18.588	18.710	18.420	0.048	DNV GL	
@0134	Cold ReHeat Temperature Inlet Boiler	°C	296.96	297.37	296.50	0.189	DNV GL	
@0135	Hot ReHeat Pressure Outlet Boiler	bar(a)	17.046	17.170	16.890	0.046	DNV GL	
@0136	Hot ReHeat Temperature Outlet Boiler	°C	511.91	515.26	508.71	1.363	DNV GL	
@0140	Feed Water Inlet Temperature Boiler	bar(a)	159.25	159.88	158.63	0.241	DNV GL	
@0141	Feed Water Inlet Pressure Boiler	°C	216.58	216.80	216.35	0.069	DNV GL	
@0150	Cool Water Temperature Inlet Condenser (a)	°C	16.521	16.770	16.350	0.096	DNV GL	
@0151	Cool Water Temperature Inlet Condenser (b)	°C	16.455	16.710	16.280	0.096	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A1	°C	355.54	357.34	354.10	0.682	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A2	°C	357.67	359.72	355.70	0.937	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A3	°C	356.62	358.50	354.93	0.861	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A4	°C	359.25	361.19	357.64	0.784	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A5	°C	360.08	362.07	358.22	0.908	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A6	°C	360.66	362.54	358.90	0.941	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A7	°C	361.00	363.05	359.36	0.821	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A8	°C	361.61	363.74	359.64	1.042	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A9	°C	362.17	364.15	360.34	1.001	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A10	°C	363.77	365.83	362.32	0.681	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A11	°C	366.95	369.28	364.69	1.276	DNV GL	
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A12	°C	363.62	365.79	361.53	1.193	DNV GL	

Tag	Performance Test Unit Date Time	47% Norgener #2 17 december 2015 17:00 hr. - 19:00 hr.	Unit	Average	Max	Min	Std	Origin
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A13	°C	362.29	364.10	360.72	0.725	0.725	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A14	°C	365.27	367.09	363.55	0.798	0.798	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A15	°C	363.30	364.91	361.94	0.769	0.769	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A16	°C	361.29	363.13	359.85	0.674	0.674	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A17	°C	366.06	368.03	364.35	0.802	0.802	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A18	°C	363.23	364.74	361.95	0.688	0.688	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A19	°C	351.35	353.30	349.68	0.732	0.732	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A20	°C	364.88	367.04	363.29	0.808	0.808	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A21	°C	361.19	362.92	359.90	0.690	0.690	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A22	°C	348.99	350.97	347.41	0.715	0.715	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A23	°C	356.91	358.98	355.47	0.772	0.772	DNV GL
@0201	Exhaust Temperature Inlet Gas Air Heater Heat A24	°C	354.27	356.07	352.98	0.712	0.712	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A1	°C	137.39	138.19	136.67	0.421	0.421	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A2	°C	146.28	147.17	145.55	0.427	0.427	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A3	°C	154.17	155.14	153.30	0.427	0.427	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A4	°C	136.51	137.32	135.80	0.413	0.413	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A5	°C	143.54	144.29	142.88	0.399	0.399	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A6	°C	152.60	153.48	151.83	0.415	0.415	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A7	°C	134.55	135.31	133.91	0.388	0.388	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A8	°C	142.22	142.98	141.39	0.447	0.447	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A9	°C	151.42	152.28	150.66	0.410	0.410	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A10	°C	133.80	134.63	133.20	0.404	0.404	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A11	°C	142.96	143.73	142.31	0.410	0.410	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A12	°C	150.42	151.26	149.69	0.409	0.409	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A13	°C	132.76	133.61	132.19	0.403	0.403	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A14	°C	140.69	141.42	140.06	0.402	0.402	DNV GL
@0203	Exhaust Temperature Outlet Gas Air Heater Heat A15	°C	146.64	147.50	145.66	0.445	0.445	DNV GL
@0261	Oxigen (O2) Inlet Air Heater A	vol%	5.68	5.94	5.49	0.10	0.10	Algoritmos
@0262	Oxigen (O2) Inlet Air Heater B	vol%	5.87	6.16	5.56	0.12	0.12	Algoritmos
@0265	Oxigen (O2) Outlet Air Heater	vol%	8.90	9.46	8.19	0.30	0.30	Algoritmos
@0267	Carbon Monoxide Outlet Air Heater	ppm	10.6	16.2	0.7	4.1	4.1	Algoritmos

Tag	Performance Test Unit Date Time	47% Norgener #2 17 december 2015 17:00 hr. - 19:00 hr.	Unit	Average	Max	Min	Std	Origin
@0012	Condensate Inlet Deaerator Mass Flow	t/h	170.53	179.62	159.84	4.197	AES	
@0021	Condensate Inlet Deaerator Temperature	°C	114.99	115.11	114.89	0.045	AES	
@0040	Mass Flow Feed Water Pump#1	t/h	59.60	69.26	47.77	5.939	AES	
@0041	Mass Flow Feed Water Pump#2	t/h	0.000	0.000	0.000	0.000	AES	
@0042	Mass Flow Feed Water Pump#3	t/h	145.34	154.63	132.64	7.176	AES	
@0050	Extraction Steam Pressure Deaerator	bar(a)	4.602	4.602	4.602	0.000	AES	
@0051	Extraction Steam Temperature Deaerator	°C	347.47	348.09	346.73	0.380	AES	
@0060	Feed Water Temperature Deaerator	°C	146.59	146.69	146.59	0.017	AES	
@0095	Extraction Steam Pressure High Pressure Heater#5	bar(a)	10.865	10.941	10.818	0.048	AES	
@0096	Extraction Steam Temperature High Pressure Heater#5	°C	459.08	459.63	458.14	0.390	AES	
@0300	Cold Primair Air Temperature	°C	26.955	27.363	26.348	0.379	AES	
@0305	Cold Secundair Air Temperature 201	°C	25.955	26.392	25.387	0.394	AES	
@0306	Cold Secundair Air Temperature 202	°C	26.631	27.035	26.032	0.370	AES	
@0310	Hot Primair Air Temperature	°C	289.59	290.23	289.11	0.302	AES	
@0315	Hot Secundair Air Temperature 154	°C	279.62	280.02	279.29	0.187	AES	
@0316	Hot Secundair Air Temperature 155	°C	285.61	286.07	285.24	0.209	AES	
@0320	Airflow Hot Secundair 21	t/h	63.67	68.35	59.58	1.551	AES	
@0321	Airflow Hot Secundair 22	t/h	61.77	67.52	57.18	1.643	AES	
@0325	Mass Flow Coal Feeder A	t/h	7.825	8.150	7.570	0.105	AES	
@0326	Mass Flow Coal Feeder B	t/h	7.876	8.156	7.553	0.109	AES	
@0327	Mass Flow Coal Feeder C	t/h	8.983	9.384	8.610	0.127	AES	
@0328	Mass Flow Coal Feeder D	t/h	0.039	0.039	0.039	0.000	AES	
@0330	Mass Flow Primair Air Mill A	t/h	28.732	29.292	28.071	0.221	AES	
@0331	Mass Flow Primair Air Mill D	t/h	24.028	24.816	23.309	0.274	AES	
@0332	Mass Flow Primair Air Mill C	t/h	25.905	27.114	25.117	0.319	AES	
@0333	Mass Flow Primair Air Mill D	t/h	-0.002	-0.002	-0.002	0.000	AES	
@0340	Oxigen (O2) Inlet Air Heater A	vol %	4.786	5.057	4.498	0.114	AES	
@0341	Oxigen (O2) Inlet Air Heater B	vol %	4.295	4.621	3.992	0.115	AES	
@0350	X Position HP Valves	%	36.322	37.484	35.023	0.797	AES	
@0360	Make-Up Water Mass Flow	t/h	4.320	6.854	0.013	2.242	AES	
@0500	Power Consumption Mill A	kW	295.94	304.06	289.59	2.499	AES	
@0501	Power Consumption Mill B	kW	289.43	296.65	281.53	2.633	AES	
@0502	Power Consumption Mill C	kW	292.71	299.78	286.57	2.435	AES	
@0503	Power Consumption Mill D	kW	0.88	0.88	0.88	0.000	AES	
@0530	Gross Power Generator (kWh)	kW	65945.8	-	-	-	AES	
@0531	Auxiliary Power Consumption (kWh)	kW	7603.7	-	-	-	AES	
@0535	Generator Excitation Current	A	153.13	180.00	128.00	5.313	AES	
@0550	Gross Power Generator	kW	66131.815	66802.887	65220.360	303.658	AES	
@0551	Voltage Generator	kV	13.329	13.465	13.176	0.058	AES	
@0552	Current Generator	kA	2.818	2.892	2.768	0.023	AES	
@0553	Phi Power Factor	-	0.997	1.000	0.989	0.002	AES	
@0554	Frequentie Generator	Hz	49.967	50.271	49.721	0.147	AES	
@0555	Rotor Speed	rpm	3001.83	3021.83	2984.78	9.169	AES	
@0556	Reactive Power Generator	MVar	-4.6	0.2539063	-9.7304688	1.785886	AES	
@0560	Net Power Unit (kWh)	kW	57997.559	-	-	-	AES	







APPENDIX E



Control Panel Screen Dumps


APPENDIX E1



Control Panel Screen Dumps Test at 100% Load





































APPENDIX E2



Control Panel Screen Dumps Test at 95% Load



































APPENDIX E3



Control Panel Screen Dumps Test at 90% Load





































APPENDIX E4



Control Panel Screen Dumps Test at 80% Load



































APPENDIX E5



Control Panel Screen Dumps Test at 70% Load



































APPENDIX E6



Control Panel Screen Dumps Test at 47% Load





























APPENDIX F

Results DNV GL Calculation Program

APPENDIX F1

Measurement Input for DNV GL Calculation Program Balance Condensate

DNV GL - Energy Advisory

DNV·GL

ThermoWare 3.150

User : 9

Date : 1/25/2016

Time : 4:29:54 PM

Page : 1

Norgener Deaerator Mass Balance Check Feed Water Flow

Performance Tests Unit #2

Standards and References used for Property Calculations as needed:

Steam Library : IFC 1997

Flue Gas Library : PTC 4.4 - 2008 (No dissociation included)

Dry Air Composition : PTC 4.4 - 2008

TestNumber		100%-HR	95%-HR	90%-HR	80%-HR	70%-HR	Min%-HR
Load		100%	95%	90%	80%	70%	47%
Date		12/15/2015	12/16/2015	12/16/2015	12/17/2015	12/17/2015	12/17/2015
Start Time		9:00:00 AM	9:00:00 AM	12:45:00 PM	9:30:00 AM	1:00:00 PM	5:00:00 PM
End Time		11:00:00 AM	11:00:00 AM	2:45:00 PM	11:30:00 AM	3:00:00 PM	7:00:00 PM
@012 M Cond.DCS Average	ton/hr	341.6	324.9	308.3	270.9	236.6	170.5
@013 dP Cond.Dearerator In	mbar	180.7	163.9	147.5	113.5	86.77	45.08
@020 P Cond. Daeaerator In	bar(a)	10.21	9.776	9.339	8.342	7.445	5.625
@021 T Cond. Daeaerator In	°C	136.6	135.2	133.6	129.6	125.5	114.8
@040 M FW Pump A	t/h	194.0	186.8	177.2	157.0	133.1	59.6
@041 M FW Pump B	t/h	-0.0	-0.0	-0.0	-0.0	-0.0	-0.0
@042 M FW Pump C	t/h	231.2	219.7	206.9	183.0	160.5	145.3
@050 P ST To Daeaerator	bar(a)	8.710	8.301	7.888	6.928	6.075	4.306
@051 T ST To Daeaerator	°C	356.6	356.6	357.0	353.1	352.6	334.5
@060 T FW Daeaerator	°C	173.8	171.7	169.7	164.4	159.2	146.2
@077 P Steam to HP FWH 1	bar(a)	21.73	20.70	19.66	17.23	15.09	10.62
@078 T Steam to HP FWH 1	°C	273.5	270.1	266.8	257.9	248.9	224.7
@095 P ST HP Sub Heater	bar(a)	22.43	21.36	20.24	17.73	15.52	10.87
@096 T ST HP Sub Heater	°C	490.3	490.0	490.0	487.7	487.9	459.1
@100 dP FW after FW Pumps	mbar	440.9	401.0	357.9	277.8	206.1	98.96
@101 P FW after FW Pumps	bar(a)	213.5	218.8	222.8	232.6	243.0	246.8
@102 T FW after FW Pumps	°C	178.3	176.5	174.7	170.0	165.4	152.6
@105 dP HP Spray Water 1	mbar	0	0	0	0	0	0
@106 P HP Spray Water 1	bar(a)	168.7	215.8	219.9	229.7	240.1	243.9
@110 dP RH Spray Water	mbar	78.06	30.91	19.83	0	0	3.899
@111 P RH Spray Water	bar(a)	73.86	75.95	77.22	80.41	83.11	82.98
@112 T RH Spray Water A	°C	175.7	173.7	171.7	127.3	114.0	148.3
@113 T RH Spray Water B	°C	0	0	0	0	0	0
@114 T RH Spray Water C	°C	175.5	173.4	171.1	127.3	114.0	148.3
@115 dP HP Spray Water 2	mbar	0	18.85	63.47	8.202	39.95	18.16
@116 P HP Spray Water 2	bar(a)	168.7	215.7	219.7	229.6	240.0	243.8
@120 P ST To HP FWH 2	bar(a)	39.15	37.21	35.25	30.83	26.81	18.65
@121 T ST To HP FWH 2	°C	351.0	345.3	342.9	334.1	324.7	296.4
@123 T FW HP FWH 2 In	°C	215.6	213.3	210.9	204.5	198.3	182.2
@124 P FW HP FWH 2 Out	bar(a)	184.7	179.8	176.6	170.9	165.3	160.1
@125 T FW HP FWH 2 Out	°C	249.1	246.4	243.7	236.3	229.0	210.2
@126 T Drain HP FWH 2	°C	221.1	218.6	215.9	209.1	202.0	184.3
@127 T Drain HP FWH 1	°C	192.2	189.8	186.9	181.1	174.8	159.5
@140 P FW Inlet Boiler	bar(a)	182.3	177.7	174.6	169.2	164.0	159.3
@141 T FW Inlet Boiler	°C	256.6	253.9	251.1	243.7	236.3	216.6



APPENDIX F2

Results DNV GL Calculation Program Balance Condensate

DNV GL - Energy Advisory

Process Technology & Measurements

Long Results Report

AnalysisBase : C:\Projects\AES_Norgener\TW-AES_Gener_Norgener_Balans_Condensate_Unit#2

DNV·GL

ThermoWare 3.150

User : 9
Date : 1/13/2016
Time : 12:41:24 PM

Page : 1

Norgener Deaerator Mass Balance Check Feed Water Flow

Performance Tests Unit #2

Standards and References used for Property Calculations as needed:

Steam Library : IFC 1997

Flue Gas Library : PTC 4.4 - 2008 (No dissociation included)

Dry Air Composition : PTC 4.4 - 2008

TestNumber	100%-HR	95%-HR	90%-HR	80%-HR	70%-HR	Min%-HR
Load	100%	95%	90%	80%	70%	47%
Date	12/15/2015	12/16/2015	12/16/2015	12/17/2015	12/17/2015	12/17/2015
Start Time	9:00:00 AM	9:00:00 AM	12:45:00 PM	9:30:00 AM	1:00:00 PM	5:00:00 PM
End Time	11:00:00 AM	11:00:00 AM	2:45:00 PM	11:30:00 AM	3:00:00 PM	7:00:00 PM

REM Average

@1802=Average(@0112,@0114)

@0112 T RH Spray Water A	°C	175.7	173.7	171.7	127.3	114.0	148.3
@0114 T RH Spray Water C	°C	175.5	173.4	171.1	127.3	114.0	148.3
@1802 T RH Spray Boiler	°C	175.6	173.5	171.4	127.3	114.0	148.3

REM Flows

FLOW CALCULATION ACCORDING ISO 5167-2003

Fluid type	Water					
Element type	ISO 5167 Long Radius Nozzle					
Pipe diameter	mm	203.6				
Orifice diameter	mm	136.59				
Pipe Material	-	VDI 2040 - Steel I; 1.0425; H II;				
Orifice Material	-	VDI 2040 - Steel V; 1.4401; X5CrNiMo 17 12 2;				
Corr factor pipe roughness	-	1				
Corr factor edge sharpness	-	1				
Flow Factor	-	0				
ASME Extrapolation	-	No				
@1601 P Condensate Flow	bar(a)	10.21	9.776	9.339	8.342	7.445
@1602 T Condensate Flow	°C	136.6	135.2	133.6	129.6	125.5
@0013 dP Cond.Dearerator In	mbar	180.7	163.9	147.5	113.5	86.77
Density	kg/m³	929.51	930.73	932.08	935.47	938.87
Dynamic Viscosity	uPas	202.0	204.3	206.9	213.8	221.3
Corrected Pipe Diameter	mm	203.91	203.91	203.90	203.89	203.88
Corrected Orifice Diameter	mm	136.87	136.86	136.86	136.85	136.84
Diameter Ratio	-	0.67121	0.67121	0.67120	0.67119	0.67118
Reynolds Number D	-	2932975	2763654	2590265	2202298	1862799
Reynolds Number d	-	4369662	4117425	3859127	3281168	2775402
Discharge Coefficient	-	0.99338	0.99328	0.99318	0.99290	0.99258
Velocity of Approach Factor	-	1.12012	1.12012	1.12011	1.12010	1.12009
Flow Coefficient	-	1.11270	1.11259	1.11247	1.11214	1.11178
Validity	-	VALID	VALID	VALID	VALID	VALID
@1600 M Condensate Flow	kg/s	94.88	90.41	85.82	75.38	66.00
						47.72

FLOW CALCULATION ACCORDING ISO 5167-2003

Fluid type	Water						
Element type	ISO 5167	Long Radius Nozzle					
Pipe diameter	mm	211.8					
Orifice diameter	mm	125.61					
Pipe Material	-	VDI 2040 - Steel I; 1.0425; H II;					
Orifice Material	-	VDI 2040 - Steel V; 1.4401; X5CrNiMo 17 12 2;					
Corr factor pipe roughness	-	1					
Corr factor edge sharpness	-	1					
Flow Factor	-	0					
ASME Extrapolation	-	No					
@1751 P FW after FW Pumps	bar(a)	213.5	218.8	222.8	232.6	243.0	246.8
@1752 T FW after FW Pumps	°C	178.3	176.5	174.7	170.0	165.4	152.6
@0100 dP FW after FW Pumps	mbar	440.9	401.0	357.9	277.8	206.1	98.96
Density	kg/m3	901.65	903.77	905.78	910.92	915.89	927.83
Dynamic Viscosity	uPas	156.6	158.4	160.2	165.0	170.1	185.1
Corrected Pipe Diameter	mm	212.25	212.24	212.23	212.22	212.21	212.17
Corrected Orifice Diameter	mm	125.96	125.96	125.95	125.94	125.93	125.90
Diameter Ratio	-	0.59346	0.59346	0.59346	0.59344	0.59343	0.59340
Reynolds Number D	-	4520840	4267381	3990417	3421067	2866202	1834571
Reynolds Number d	-	7617712	7190683	6724039	5764773	4829874	3091628
Discharge Coefficient	-	0.99413	0.99406	0.99398	0.99378	0.99353	0.99279
Velocity of Approach Factor	-	1.06846	1.06846	1.06846	1.06845	1.06845	1.06843
Flow Coefficient	-	1.06219	1.06212	1.06203	1.06181	1.06153	1.06072
Validity	-	VALID	VALID	VALID	VALID	VALID	VALID
@1750 M FW after FW Pumps	kg/s	118.02	112.67	106.55	94.10	81.24	56.59
@0900=(@1750-@2310)/@2310*100							
@1750 M FW after FW Pumps	kg/s	118.02	112.67	106.55	94.10	81.24	56.59
@2310 M FW Boiler Total	kg/s	114.88	109.69	103.79	91.53	79.18	55.53
@0900 X Dev. FW Meas->Balance	%	2.73	2.72	2.66	2.81	2.60	1.90

FLOW CALCULATION ACCORDING ISO 5167-2003

Fluid type	Water						
Element type	ISO 5167 Long Radius Nozzle						
Pipe diameter	mm 61.4						
Orifice diameter	mm 37.4						
Pipe Material	- VDI 2040 - Steel I; 1.0425; H II;						
Orifice Material	- PTC Carbon Steel (<3 Cr);						
Corr factor pipe roughness	- 1						
Corr factor edge sharpness	- 1						
Flow Factor	- 0						
ASME Extrapolation	- No						
@1761 P HP Spray 1 Boiler	bar(a) 168.7	215.8	219.9	229.7	240.1	243.9	
@1762 T HP Spray 1 Boiler	°C 178.3	176.5	174.7	170.0	165.4	152.6	
@0105 dP HP Spray Water 1	mbar 0	0	0	0	0	0	
Density	kg/m3 898.94	903.59	905.61	910.76	915.73	927.67	
Dynamic Viscosity	uPas 155.5	158.3	160.1	165.0	170.0	185.0	
Corrected Pipe Diameter	mm 61.53	61.53	61.53	61.52	61.52	61.51	
Corrected Orifice Diameter	mm 37.47	37.47	37.47	37.47	37.47	37.46	
Diameter Ratio	- 0.60901	0.60901	0.60901	0.60901	0.60901	0.60902	
Reynolds Number D	- 0	0	0	0	0	0	
Reynolds Number d	- 0	0	0	0	0	0	
Discharge Coefficient	- 0	0	0	0	0	0	
Velocity of Approach Factor	- 1.07680	1.07680	1.07680	1.07680	1.07680	1.07681	
Flow Coefficient	- 0	0	0	0	0	0	
Validity	- VALID	VALID	VALID	VALID	VALID	VALID	
@1760 M HP Spray 1 Boiler	kg/s 0	0	0	0	0	0	

FLOW CALCULATION ACCORDING ISO 5167-2003

Fluid type	Water						
Element type	ISO 5167 Long Radius Nozzle						
Pipe diameter	mm 40.2						
Orifice diameter	mm 26.76						
Pipe Material	- VDI 2040 - Steel I; 1.0425; H II;						
Orifice Material	- PTC Carbon Steel (<3 Cr);						
Corr factor pipe roughness	- 1						
Corr factor edge sharpness	- 1						
Flow Factor	- 0						
ASME Extrapolation	- No						
@1771 P HP Spray 2 Boiler	bar(a) 168.7	215.7	219.7	229.6	240.0	243.8	
@1772 T HP Spray 2 Boiler	°C 178.3	176.5	174.7	170.0	165.4	152.6	
@0115 dP HP Spray Water 2	mbar 0	18.85	63.47	8.202	39.95	18.16	
Density	kg/m3 898.94	903.58	905.60	910.75	915.72	927.67	
Dynamic Viscosity	uPas 155.5	158.3	160.1	165.0	170.0	185.0	
Corrected Pipe Diameter	mm 40.28	40.28	40.28	40.28	40.28	40.27	
Corrected Orifice Diameter	mm 26.81	26.81	26.81	26.81	26.81	26.80	
Diameter Ratio	- 0.66555	0.66555	0.66555	0.66555	0.66556	0.66556	
Reynolds Number D	- 0	228630	416508	144887	312531	194307	
Reynolds Number d	- 0	343519	625809	217694	469579	291945	
Discharge Coefficient	- 0	0.98536	0.98825	0.98250	0.98697	0.98441	
Velocity of Approach Factor	- 1.11540	1.11540	1.11540	1.11540	1.11540	1.11541	
Flow Coefficient	- 0	1.09906	1.10229	1.09588	1.10087	1.09802	
Validity	- D<	D<	D<	D<	D<	D<	
@1770 M HP Spray 2 Boiler	kg/s 0	1.145	2.110	0.756	1.681	1.137	

FLOW CALCULATION ACCORDING ISO 5167-2003

Fluid type	Water					
Element type	ISO 5167 Long Radius Nozzle					
Pipe diameter	mm 44.5					
Orifice diameter	mm 27.24					
Pipe Material	- PTC Carbon Steel (<3 Cr);					
Orifice Material	- PTC Austenitic Stainless Steel;					
Corr factor pipe roughness	- 1					
Corr factor edge sharpness	- 1					
Flow Factor	- 0					
ASME Extrapolation	- No					
@1801 P RH Spray Boiler	bar(a)	73.86	75.95	77.22	80.41	83.11
@1802 T RH Spray Boiler	°C	175.6	173.5	171.4	127.3	114.0
@0110 dP RH Spray Water	mbar	78.06	30.91	19.83	0	0
Density	kg/m³	895.82	898.09	900.34	941.06	951.83
Dynamic Viscosity	uPas	155.7	157.8	159.9	219.8	247.4
Corrected Pipe Diameter	mm	44.58	44.58	44.58	44.56	44.55
Corrected Orifice Diameter	mm	27.31	27.31	27.31	27.29	27.28
Diameter Ratio	-	0.61262	0.61261	0.61260	0.61248	0.61244
Reynolds Number D	-	428566	265980	210220	0	0
Reynolds Number d	-	699567	434175	343158	0	0
Discharge Coefficient	-	0.98869	0.98659	0.98535	0	0
Velocity of Approach Factor	-	1.07886	1.07886	1.07885	1.07878	1.07876
Flow Coefficient	-	1.06666	1.06439	1.06305	0	0
Validity	-	D<	D<	D<	D<	D<
@1800 M RH Spray Boiler	kg/s	2.337	1.469	1.177	0	0
 @2000=@1600						
@1600 M Condensate Flow	kg/s	94.88	90.41	85.82	75.38	66.00
@2000 M Cond. Deaerator	kg/s	94.88	90.41	85.82	75.38	66.00
 @2100=@2400=@1800=@1760=@1770						
@2400 M FW Deaer. out	kg/s	117.2	111.2	105.0	91.53	79.18
@1800 M RH Spray Boiler	kg/s	2.337	1.469	1.177	0	0
@1760 M HP Spray 1 Boiler	kg/s	0	0	0	0	0
@1770 M HP Spray 2 Boiler	kg/s	0	1.145	2.110	0.756	1.681
@2100 M FW HP FWH I	kg/s	114.9	108.5	101.7	90.77	77.50
 REM Deaerator In: Steam						
@2400=@2000+@1300+@1400						
@2000 M Cond. Deaerator	kg/s	94.88	90.41	85.82	75.38	66.00
@1300 M Drain HP FWH I	kg/s	16.58	15.38	14.10	11.90	9.587
@1400 M ST Deaerator	kg/s	5.756	5.372	5.046	4.245	3.590
@2400 M FW Deaer. out	kg/s	117.2	111.2	105.0	91.53	79.18
 @1403=HPT(@1401,@1402,1)						
@1401 P ST Deaerator	bar(a)	8.710	8.301	7.888	6.928	6.075
@1402 T ST Deaerator	°C	356.6	356.6	357.0	353.1	352.6
@1403 H ST Deaerator	kJ/kg	3175	3175	3177	3171	3137
 @2003=HPT(@2001,@2002,0)						
@2001 P Cond. Deaerator	bar(a)	10.21	9.776	9.339	8.342	7.445
@2002 T Cond. Deaerator	°C	136.6	135.2	133.6	129.6	125.5
@2003 H Cond. Deaerator	kJ/kg	575.1	569.0	562.2	545.1	527.5

@2403=HPT(@2401,@2402,0)

@2401 P FW Deae out	bar(a)	8.710	8.301	7.888	6.928	6.075	4.306
@2402 T FW Deae out	°C	173.8	171.7	169.7	164.4	159.2	146.2
@2403 H FW Deae out	kJ/kg	735.9	726.7	717.9	694.7	672.1	615.9

@1400=1.01*(@2000*(@2403-@2003)+@1300*(@2403-@1303))/(@1403-@2403)

@2000 M Cond. Daeaerator	kg/s	94.88	90.41	85.82	75.38	66.00	47.72
@2403 H FW Deae out	kJ/kg	735.9	726.7	717.9	694.7	672.1	615.9
@2003 H Cond. Daeaerator	kJ/kg	575.1	569.0	562.2	545.1	527.5	482.0
@1300 M Drain HP FWH I	kg/s	16.58	15.38	14.10	11.90	9.587	5.911
@1303 H Drain HP FWH I	kJ/kg	817.8	807.1	794.1	768.4	740.6	673.5
@1403 H ST Daeaerator	kJ/kg	3175	3175	3177	3171	3171	3137
@1400 M ST Daeaerator	kg/s	5.756	5.372	5.046	4.245	3.590	2.423

REM HP FWH I

Preheater(\$12,\$21,\$22,\$13,\$11,@1310,@1311,@1312,@1313,@1314,Actual)

@2100 M FW HP FWH I	kg/s	114.9	108.5	101.7	90.77	77.50	54.40
@2101 P FW HP FWH I	bar(a)	213.5	218.8	222.8	232.6	243.0	246.8
@2102 T FW HP FWH I	°C	178.3	176.5	174.7	170.0	165.4	152.6
@2103 H FW HP FWH I	kJ/kg	766.5	759.1	751.5	731.9	712.8	658.6
@2200 M FW HP FWH II	kg/s	114.9	108.5	101.7	90.77	77.50	54.40
@2201 P FW HP FWH II	bar(a)	184.7	179.8	176.6	170.9	165.3	160.1
@2202 T FW HP FWH II	°C	215.6	213.3	210.9	204.5	198.3	182.2
@2203 H FW HP FWH II	kJ/kg	928.9	918.6	907.6	879.0	851.3	780.6
@1200 M ST HP FWH I	kg/s	8.306	7.688	7.016	5.875	4.699	2.884
@1201 P ST HP FWH I	bar(a)	21.73	20.70	19.66	17.23	15.09	10.62
@1202 T ST HP FWH I	°C	273.5	270.1	266.8	257.9	248.9	224.7
@1203 H ST HP FWH I	kJ/kg	2955	2951	2947	2934	2921	2884
@1300 M Drain HP FWH I	kg/s	16.58	15.38	14.10	11.90	9.587	5.911
@1301 P Drain HP FWH I	bar(a)	21.73	20.70	19.66	17.23	15.09	10.62
@1302 T Drain HP FWH I	°C	192.2	189.8	186.9	181.1	174.8	159.5
@1303 H Drain HP FWH I	kJ/kg	817.8	807.1	794.1	768.4	740.6	673.5
@1100 M Drain HP FWH II	kg/s	8.275	7.692	7.087	6.028	4.888	3.028
@1101 P Drain HP FWH II	bar(a)	39.15	37.21	35.25	30.83	26.81	18.65
@1102 T Drain HP FWH II	°C	221.1	218.6	215.9	209.1	202.0	184.3
@1103 H Drain HP FWH II	kJ/kg	949.1	937.6	925.2	894.0	861.8	782.6
@1313 Q Heat Transfer HP FWH I	kW	18656	17312	15871	13348	10731	6637
@1314 Q Heat Loss HP FWH I	kW	186.6	173.1	158.7	133.5	107.3	66.37
@1310 Ka Con. HP FWH I	kW/K	1135	1101	1059	974.8	867.3	633.6
@1311 Ka Sub. Cool. HP FWH I	kW/K	88.71	84.17	81.62	70.81	61.41	42.07
@1312 P. Loss Factor HP FWH I	-	1.968	2.991	4.049	6.821	11.85	27.17

REM HP FWH II

Preheater(\$10,\$22,\$35,\$11,\$00,@1110,@1111,@1112,@1113,@1114,Actual)

@2200 M FW HP FWH II	kg/s	114.9	108.5	101.7	90.77	77.50	54.40
@2201 P FW HP FWH II	bar(a)	184.7	179.8	176.6	170.9	165.3	160.1
@2202 T FW HP FWH II	°C	215.6	213.3	210.9	204.5	198.3	182.2
@2203 H FW HP FWH II	kJ/kg	928.9	918.6	907.6	879.0	851.3	780.6
@3500 M FW HP Sub Heater	kg/s	114.9	108.5	101.7	90.77	77.50	54.40
@3501 P FW HP Sub Heater	bar(a)	184.7	179.8	176.6	170.9	165.3	160.1
@3502 T FW HP Sub Heater	°C	249.1	246.4	243.7	236.3	229.0	210.2
@3503 H FW HP Sub Heater	kJ/kg	1082	1069	1057	1022	988.8	903.9
@1000 M ST HP FWH II	kg/s	8.275	7.692	7.087	6.028	4.888	3.028
@1001 P ST HP FWH II	bar(a)	39.15	37.21	35.25	30.83	26.81	18.65
@1002 T ST HP FWH II	°C	351.0	345.3	342.9	334.1	324.7	296.4
@1003 H ST HP FWH II	kJ/kg	3098	3088	3087	3076	3064	3020
@1100 M Drain HP FWH II	kg/s	8.275	7.692	7.087	6.028	4.888	3.028
@1101 P Drain HP FWH II	bar(a)	39.15	37.21	35.25	30.83	26.81	18.65
@1102 T Drain HP FWH II	°C	221.1	218.6	215.9	209.1	202.0	184.3
@1103 H Drain HP FWH II	kJ/kg	949.1	937.6	925.2	894.0	861.8	782.6
@1113 Q Heat Transf.HP FWH II	kW	17604	16380	15169	13025	10658	6707
@1114 Q Heat Loss HP FWH II	kW	176.0	163.8	151.7	130.2	106.6	67.07
@1110 KA Con. HP FWH II	kW/K	1011	1000	987.7	925.2	859.7	681.1
@1111 KA Sub. Cool. HP FWH II	kW/K	73.58	68.79	64.16	55.20	48.20	35.77
@1112 P Loss Factor HP FWH II	-	0	0	0	0	0	0

REM Total Feed Water to Boiler (including HP Spray Waters)

@2310=@2400-@1800							
@2400 M FW Deae out	kg/s	117.2	111.2	105.0	91.53	79.18	56.06
@1800 M RH Spray Boiler	kg/s	2.337	1.469	1.177	0	0	0.524
@2310 M FW Boiler Total	kg/s	114.88	109.69	103.79	91.53	79.18	55.53
 @2311=@2310*3.6							
@2310 M FW Boiler Total	kg/s	114.88	109.69	103.79	91.53	79.18	55.53
@2311 M FW Boiler Total	t/h	413.6	394.9	373.6	329.5	285.0	199.9

REM

APPENDIX F3

Measurement Input for DNV GL Main Calculation Program

Performance Test Norgener Unit#1 and Unit#2 conducted in 2015

AES Gener Norgener, Chile

Standards and References used for Property Calculations as needed:

Steam Library : IFC 1997

Flue Gas Library : PTC 4.4 - 2008 (No dissociation included)

Dry Air Composition : PTC 4.4 - 2008

TestNumber		100%-HR	95%-HR	90%-HR	80%-HR	70%-HR	Min%-HR
Load		136 MW	129 MW	122 MW	109 MW	95 MW	65 MW
Date		12/15/2015	12/16/2015	12/16/2015	12/17/2015	12/17/2015	12/17/2015
Start Time		9:00:00 AM	9:00:00 AM	12:45:00 PM	9:30:00 AM	1:00:00 PM	5:00:00 PM
End Time		11:00:00 PM	11:00:00 AM	2:45:00 PM	11:30:00 AM	3:00:00 PM	7:00:00 PM
@010 F Unit#1 in Operation	1/0	0	0	0	0	0	0
@020 F Unit#2 in Operation	1/0	1	1	1	1	1	1
@030 F Appl.Fuel Corrections	1/0	0	0	0	0	0	0
@035 F Max.Power Test	1/0	0	0	0	0	0	0
@040 F FW Boiler Meas.Method	1/0	0	0	0	0	0	0
@050 F FW Boiler Cond.Method	1/0	1.000	1.000	1.000	1.000	1.000	1.000
@080 P Barometer	bar(a)	1.00959	1.00947	1.00821	1.00824	1.00705	1.00513
@081 T Ambient Temp.	°C	20.81	21.49	21.23	20.84	21.37	20.65
@082 X Rel.Humidity	%	64.82	68.98	63.98	61.61	64.47	74.84
@100 dP HP FW after FW Pumps	mbar	440.88	401.04	357.92	277.85	206.07	98.96
@101 P HP FW after FW Pumps	bar(a)	213.53	218.77	222.82	232.55	243.01	246.76
@102 T HP FW after FW Pumps	°C	178.29	176.47	174.69	169.97	165.42	152.56
@105 dP HP Spray 1 W.Boiler	mbar	0	0	0	0	0	0
@106 P HP Spray 1 W.Boiler	bar(a)	168.69	215.81	219.87	229.65	240.12	243.91
@110 dP RH Spray W.Boiler	mbar	78.06	30.91	19.83	0	0	3.90
@111 P RH Spray W.Boiler	bar(a)	73.86	75.95	77.22	80.41	83.11	82.98
@112 T RH Spray 1 at FW Pump	°C	175.75	173.74	171.70	127.30	97.28	130.48
@113 T RH Spray 2 at FW Pump	°C	0	0	0	0	0	0
@114 T RH Spray 3 at FW Pump	°C	175.46	173.35	171.14	97.81	113.97	148.30
@115 dP HP Spray 2 W.Boiler	mbar	0	18.85	63.47	8.20	39.95	18.16
@116 P HP Spray 2 W.Boiler	bar(a)	168.69	215.71	219.74	229.57	240.02	243.83
@120 P Extraction HPH#2	bar(a)	39.15	37.21	35.25	30.83	26.81	18.65
@121 T Extraction HPH#2	°C	351.01	345.34	342.94	334.14	324.67	296.41
@123 T FW Inlet HPH#2	°C	215.59	213.32	210.91	204.46	198.33	182.23
@124 P FW Outlet HPH#2	bar(a)	184.71	179.83	176.58	170.85	165.32	160.14
@125 T FW Outlet HPH#2	°C	249.14	246.40	243.67	236.33	229.03	210.19
@126 T Drain HPH#2	°C	221.09	218.58	215.87	209.06	202.01	184.29
@127 T Drain HPH#1	°C	192.25	189.81	186.95	181.08	174.76	159.45
@130 P HP Steam Outl.Boiler	bar(a)	165.59	162.09	160.40	157.26	154.44	153.56
@131 T HP Steam Outl.Boiler	°C	540.37	535.12	535.20	536.49	535.79	525.89
@133 P Cold RH Inl.Boiler	bar(a)	39.08	37.14	35.17	30.75	26.73	18.59
@134 T Cold RH Inl.Boiler	°C	351.26	345.64	343.07	334.43	324.97	296.96
@135 P Hot RH Outl.Boiler	bar(a)	35.93	34.12	32.30	28.21	24.52	17.05
@136 T Hot RH Outl.Boiler	°C	545.61	544.95	545.02	543.05	542.88	511.91
@140 P FW Inlet Boiler	bar(a)	182.30	177.65	174.60	169.20	163.99	159.25
@141 T FW Inlet Boiler	°C	256.62	253.90	251.10	243.67	236.26	216.58
@150 T CW Inlet Cond.(a)	°C	16.45	16.64	17.64	16.65	16.84	16.52
@151 T CW Inlet Cond.(b)	°C	16.38	16.58	17.58	16.59	16.78	16.45
@201 T Exh.Inl.Air Heat.Aver.	°C	368.21	363.53	360.33	344.03	335.78	308.49
@203 T Exh.Outl.Air Heat.Aver	°C	143.52	139.71	143.06	132.39	131.26	127.16
@261 O2 Oxigen Inl.Air Heat.A	vol%,dry	3.11	3.73	3.03	3.58	4.40	5.68
@262 O2 Oxigen Inl.Air Heat.B	vol%,dry	2.96	3.09	4.04	4.02	4.37	5.87
@265 O2 Oxy.Outl.Air Heat.Aver	vol%,dry	6.55	6.69	6.73	7.09	7.50	8.90
@267 CO Outl.Air Heat.Aver.	ppm	0	0	1	0	1	11
@280 C Content Coal (Ultim.)	%	59.08	59.26	59.24	59.79	59.01	59.11
@281 H Content Coal (Ultim.)	%	3.70	3.71	3.71	3.74	3.70	3.67
@282 S Content Coal (Ultim.)	%	0.41	0.42	0.46	0.44	0.43	0.43
@283 N Content Coal (Ultim.)	%	0.94	0.95	0.94	1.12	1.18	1.18
@284 O Content Coal (Ultim.)	%	11.48	11.02	10.98	11.08	11.04	10.98
@285 W H2O in Coal (Proxim.)	%	18.62	18.98	18.97	18.24	19.08	18.99

@286 A Ash in Coal (Proxim.)	%	5.770	5.660	5.700	5.590	5.550	5.620
@287 V Volatile Coal(Proxim.)	%	32.96	33.00	32.82	33.22	33.41	33.50
@288 C Fixed Carbon (Proxim.)	%	42.64	42.36	42.51	42.94	41.95	41.88
@290 Ub Unburn.Bottom Ash	%	4.07	4.83	4.41	10.09	7.29	10.26
@291 Ub Unburn.Fly-Ash	%	2.58	3.49	2.30	2.15	0.55	0.46
@295 HHV Value of Coal	kJ/kg	23580	23614	23542	23777	23542	23505
@300 T Cold Prim.Air	°C	26.13	23.77	27.04	26.05	27.45	26.95
@305 T Cold Sec.Air A	°C	25.18	22.84	26.10	25.08	26.47	25.95
@306 T Cold Sec.Air B	°C	25.79	23.49	26.72	25.70	27.11	26.63
@310 T Hot Prim.Air	°C	342.35	337.33	335.83	319.04	312.18	289.59
@315 T Hot Sec.Air A	°C	327.02	322.25	321.76	305.51	299.69	279.62
@316 T Hot Sec.Air B	°C	334.78	330.25	329.40	313.58	307.39	285.61
@320 M Hot Sec.Airflow A	t/h	120.3	112.2	105.8	97.6	87.5	63.7
@321 M Hot Sec.Airflow B	t/h	131.5	124.8	117.5	108.7	94.7	61.8
@325 M Coal Feeder A	t/h	10.51	10.34	9.78	12.36	10.88	7.83
@326 M Coal Feeder B	t/h	10.62	10.45	9.86	12.46	10.97	7.88
@327 M Coal Feeder C	t/h	14.38	13.39	12.66	14.04	12.38	8.98
@328 M Coal Feeder D	t/h	14.42	13.41	12.67	0	0	0
@330 M Prim.Air Mill A	t/h	32.23	32.14	31.68	32.96	32.35	28.73
@331 M Prim.Air Mill B	t/h	25.93	25.82	25.38	27.23	26.18	24.03
@332 M Prim.Air Mill C	t/h	29.14	28.53	28.09	28.91	27.93	25.90
@333 M Prim.Air Mill D	t/h	29.65	29.05	28.60	0	0	0
@340 O2 Inl.Air Heat.A DCS	vol %	2.02	2.02	2.18	2.84	3.27	4.79
@341 O2 Inl.Air Heat.B DCS	vol %	2.62	2.58	2.65	2.63	2.97	4.29
@350 X Position HP Valves	%	82.3	65.4	63.7	61.1	52.7	36.3
@360 M Make-Up Water Flow	t/h	4.37	4.91	4.16	5.31	5.10	4.32
@480 D Pipe Diam.FW-Nozzle	mm	211.80	211.80	211.80	211.80	211.80	211.80
@481 d Nozzle Diam.FW-Nozzle	mm	125.61	125.61	125.61	125.61	125.61	125.61
@490 M Eject.Steam Design	kg/s	0.18	0.18	0.18	0.18	0.18	0.18
@500 Pe Power Mill A	kW	295	298	299	296	295	296
@501 Pe Power Mill B	kW	294	295	295	297	293	289
@502 Pe Power Mill C	kW	304	302	304	301	300	293
@503 Pe Power Mill D	kW	296	298	299	0	0	0
@505 Pe Power Recirc.Fan	kW	0	0	0	0	0	0
@510 M Unacc. System Leak	kg/s	0.670	0.670	0.670	0.670	0.670	0.670
@511 HHV Coal Standard	kCal/kg	6000.0	6000.0	6000.0	6000.0	6000.0	6000.0
@520 Ym Fuel Eff.Boiler Meas.	%	87.71	87.76	87.75	88.10	88.11	87.84
@525 M Coal Flow Calc.ASME	kg/h	54946	52331	49808	44012	38804	27973
@530 Pe Gross Pow.Gen (kWh)	kW	136252	129267	122472	108664	95407	65946
@531 Pe Aux. Power (kWh)	kW	9868	9553	9228	8552	8082	7604
@535 A Aux. Power FGD Ext.	Amp	307	277	253	208	177	153
@540 Pe Ligthing Unit 1	kW	152	152	152	152	152	152
@541 Pe Ligthing Unit 2	kW	152	152	152	152	152	152
@544 Pe Common Users Unit#1	kW	106	106	106	106	106	106
@545 Pe Common Users Unit#2	kW	57	57	57	57	57	57
@550 Pe Gross Power Gen.	kW	136342	129321	122549	108796	95580	66132
@551 U Voltage Generator	kV	13.260	13.330	13.333	13.340	13.329	13.329
@552 I Current Generator	KA	5.870	5.518	5.232	4.642	4.079	2.818
@553 Phi Power Factor	-	0.999	1.000	1.000	1.000	0.998	0.997
@554 Hz Freq.Generator	Hz	50.13	50.16	50.07	50.03	50.13	49.97
@555 S Rotor Speed	rot/min	3013.6	3015.5	3009.8	3005.4	3010.7	3001.8
@556 MVar Reactive Power Gen.	MVar	-4.038	-0.172	0.501	1.138	-5.090	-4.613
@560 Pe Net Power Unit (kWh)	kW	125479	118877	112468	99499	86803	57998
@600 M FW Boiler Cond.Method	kg/s	114.88	109.69	103.79	91.53	79.18	55.53



APPENDIX F4

Results DNV GL Main Calculation Program

Performance Test Norgener Unit#1 and Unit#2 conducted in 2015

AES Gener Norgener, Chile

Standards and References used for Property Calculations as needed:

Steam Library : IFC 1997

Flue Gas Library : PTC 4.4 - 2008 (No dissociation included)

Dry Air Composition : PTC 4.4 - 2008

TestNumber	100%-HR	95%-HR	90%-HR	80%-HR	70%-HR	Min%-HR
Load	136 MW	129 MW	122 MW	109 MW	95 MW	65 MW
Date	12/15/2015	12/16/2015	12/16/2015	12/17/2015	12/17/2015	12/17/2015
Start Time	9:00:00 AM	9:00:00 AM	12:45:00 PM	9:30:00 AM	1:00:00 PM	5:00:00 PM
End Time	11:00:00 AM	11:00:00 AM	2:45:00 PM	11:30:00 AM	3:00:00 PM	7:00:00 PM

REM Average Calculations

@1152=Average(@0150,@0151)

@0150 T CW Inlet Cond.(a)	°C	16.45	16.64	17.64	16.65	16.84	16.52
@0151 T CW Inlet Cond.(b)	°C	16.38	16.58	17.58	16.59	16.78	16.45
@1152 T CW Inlet Condenser	°C	16.42	16.61	17.61	16.62	16.81	16.49

@0905=(@0325+@0326+@0327+@0328)/3.6

@0325 M Coal Feeder A	t/h	10.51	10.34	9.78	12.36	10.88	7.83
@0326 M Coal Feeder B	t/h	10.62	10.45	9.86	12.46	10.97	7.88
@0327 M Coal Feeder C	t/h	14.38	13.39	12.66	14.04	12.38	8.98
@0328 M Coal Feeder D	t/h	14.42	13.41	12.67	0	0	0
@0905 M Flow Coal Total (DCS)	kg/s	13.87	13.22	12.49	10.79	9.51	6.86

@0911=Average(@0305,@0306)

@0305 T Cold Sec.Air A	°C	25.18	22.84	26.10	25.08	26.47	25.95
@0306 T Cold Sec.Air B	°C	25.79	23.49	26.72	25.70	27.11	26.63
@0911 T Cold Sec.Air Aver.	°C	25.48	23.16	26.41	25.39	26.79	26.29

@0913=Average(@0315,@0316)

@0315 T Hot Sec.Air A	°C	327.02	322.25	321.76	305.51	299.69	279.62
@0316 T Hot Sec.Air B	°C	334.78	330.25	329.40	313.58	307.39	285.61
@0913 T Hot Sec.Air Aver.	°C	330.90	326.25	325.58	309.55	303.54	282.62

@0919=Average(@0261,@0262)

@0261 O2 Oxigen Inl.Air Heat.A	vol%,dry	3.11	3.73	3.03	3.58	4.40	5.68
@0262 O2 Oxigen Inl.Air Heat.B	vol%,dry	2.96	3.09	4.04	4.02	4.37	5.87
@0919 O2 Oxig.Inl.Air Heat.Aver	vol%,dry	3.04	3.41	3.54	3.80	4.39	5.78

@1802=Average(@0112,@0114)

@0112 T RH Spray 1 at FW Pump	°C	175.75	173.74	171.70	127.30	97.28	130.48
@0114 T RH Spray 3 at FW Pump	°C	175.46	173.35	171.14	97.81	113.97	148.30
@1802 T RH Spray Boiler	°C	175.61	173.55	171.42	112.56	105.63	139.39

REM Primairy Air and Secundairy Air

@3020=Sum(@0320,@0321)

@0320 M Hot Sec.Airflow A	t/h	120.3	112.2	105.8	97.6	87.5	63.7
@0321 M Hot Sec.Airflow B	t/h	131.5	124.8	117.5	108.7	94.7	61.8
@3020 M Secundairy Air	t/h	251.8	237.0	223.3	206.3	182.2	125.5

@3010=Sum(@0330,@0331,@0332,@0333)

@0330 M Prim.Air Mill A	t/h	32.23	32.14	31.68	32.96	32.35	28.73
@0331 M Prim.Air Mill B	t/h	25.93	25.82	25.38	27.23	26.18	24.03
@0332 M Prim.Air Mill C	t/h	29.14	28.53	28.09	28.91	27.93	25.90
@0333 M Prim.Air Mill D	t/h	29.65	29.05	28.60	0	0	0
@3010 M Primairy Air	t/h	116.9	115.5	113.7	89.10	86.46	78.66

REM Estimated Shaft Power within System Boundary

DNV GL - Energy Advisory

Process Technology & Measurements

Long Results Report

AnalysisBase : C:\Projects\AES_Norgener\TW-AES_Gener_Norgener

DNV·GL

ThermoWare 3.150

User : 9

Date : 2/12/2016

Time : 8:20:33 AM

Page : 2

@0930=(@0500+@0501+@0502+@0503)*0.95

@0500 Pe Power Mill A	kW	295	298	299	296	295	296
@0501 Pe Power Mill B	kW	294	295	295	297	293	289
@0502 Pe Power Mill C	kW	304	302	304	301	300	293
@0503 Pe Power Mill D	kW	296	298	299	0	0	0
@0930 Pe Power System Boundary	kW	1130	1133	1138	849	844	835

REM Step Up Transformer Losses

@0651=((@0530-@0531)-@0560)/@0530*100

@0530 Pe Gross Pow.Gen (kWh)	kW	136252	129267	122472	108664	95407	65946
@0531 Pe Aux. Power (kWh)	kW	9868	9553	9228	8552	8082	7604
@0560 Pe Net Power Unit (kWh)	kW	125479	118877	112468	99499	86803	57998
@0651 X Step Up Losses	%	0.7	0.6	0.6	0.6	0.5	0.5

REM Composition Ambient Air

#20=AirComp(@3001,@3002,@0082)

@3001 P Ambient Air	bar(a)	1.0096	1.0095	1.0082	1.0082	1.0071	1.0051
@3002 T Ambient Air	°C	20.81	21.49	21.23	20.84	21.37	20.65
@0082 X Rel.Humidity	%	64.82	68.98	63.98	61.61	64.47	74.84
@3050 Ar Ambient Air	mol%	0.922	0.920	0.922	0.922	0.921	0.920
@3051 CO2 Ambient Air	mol%	0.0314	0.0313	0.0314	0.0314	0.0314	0.0313
@3052 N2 Ambient Air	mol%	76.85	76.72	76.83	76.91	76.81	76.67
@3053 O2 Ambient Air	mol%	20.62	20.58	20.61	20.63	20.61	20.57
@3054 H2O Ambient Air	mol%	1.579	1.752	1.601	1.506	1.629	1.813

@3004=AbsoluteHumidity(@3001,@3002,@0082)

@3001 P Ambient Air	bar(a)	1.0096	1.0095	1.0082	1.0082	1.0071	1.0051
@3002 T Ambient Air	°C	20.81	21.49	21.23	20.84	21.37	20.65
@0082 X Rel.Humidity	%	64.82	68.98	63.98	61.61	64.47	74.84
@3004 X Abs.Humidity Air	kg/kg	0.00998	0.01109	0.01012	0.00951	0.01030	0.01149

@3005=WetBulb(@3002,@0082,@3001)

@3002 T Ambient Air	°C	20.81	21.49	21.23	20.84	21.37	20.65
@0082 X Rel.Humidity	%	64.82	68.98	63.98	61.61	64.47	74.84
@3001 P Ambient Air	bar(a)	1.0096	1.0095	1.0082	1.0082	1.0071	1.0051
@3005 T Wet Bulb Temp.	°C	16.50	17.65	16.75	16.09	16.94	17.64

REM Flow Calculations

FLOW CALCULATION ACCORDING ISO 5167-2003

Fluid type	Water						
Element type	ISO 5167 Long Radius Nozzle						
@0480 D Pipe Diam.FW-Nozzle	mm	211.80	211.80	211.80	211.80	211.80	211.80
@0481 d Nozzle Diam.FW-Nozzle	mm	125.61	125.61	125.61	125.61	125.61	125.61
Pipe Material	-	VDI 2040 - Steel I; 1.0425; H II;					
Orifice Material	-	VDI 2040 - Steel V; 1.4401; X5CrNiMo 17 12 2;					
Corr factor pipe roughness	-	1					
Corr factor edge sharpness	-	1					
Flow Factor	-	0					
ASME Extrapolation	-	No					
@1751 P FW after FW Pumps	bar(a)	213.5	218.8	222.8	232.6	243.0	246.8
@1752 T FW after FW Pumps	°C	178.3	176.5	174.7	170.0	165.4	152.6
@0100 dP HP FW after FW Pumps	mbar	440.88	401.04	357.92	277.85	206.07	98.96
Density	kg/m³	901.67	903.79	905.79	910.95	915.87	927.86
Dynamic Viscosity	uPas	156.6	158.4	160.2	165.1	170.0	185.2
Corrected Pipe Diameter	mm	212.25	212.24	212.23	212.22	212.21	212.17
Corrected Orifice Diameter	mm	125.96	125.96	125.95	125.94	125.93	125.90
Diameter Ratio	-	0.59346	0.59346	0.59346	0.59344	0.59343	0.59340
Reynolds Number D	-	4520482	4266923	3990302	3420817	2866326	1834106
Reynolds Number d	-	7617109	7189912	6723847	5764353	4830084	3090845
Discharge Coefficient	-	0.99413	0.99406	0.99398	0.99378	0.99353	0.99279
Velocity of Approach Factor	-	1.06846	1.06846	1.06846	1.06845	1.06845	1.06843
Flow Coefficient	-	1.06219	1.06212	1.06203	1.06181	1.06153	1.06072
Validity	-	VALID	VALID	VALID	VALID	VALID	VALID
@1755 M FW Boiler Meas.Method	kg/s	118.02	112.68	106.55	94.11	81.23	56.59
@1750=(@0040*@1755+@0050*@1756)/(@0040+@0050)							
@0040 F FW Boiler Meas.Method	1/0	0	0	0	0	0	0
@1755 M FW Boiler Meas.Method	kg/s	118.02	112.68	106.55	94.11	81.23	56.59
@0050 F FW Boiler Cond.Method	1/0	1.000	1.000	1.000	1.000	1.000	1.000
@1756 M FW Boiler Cond.Method	kg/s	114.88	109.69	103.79	91.53	79.18	55.53
@1750 M FW after FW Pumps	kg/s	114.88	109.69	103.79	91.53	79.18	55.53

FLOW CALCULATION ACCORDING ISO 5167-2003

Fluid type	Water						
Element type	ISO 5167 Long Radius Nozzle						
Pipe diameter	mm 61.4						
Orifice diameter	mm 37.4						
Pipe Material	- VDI 2040 - Steel I; 1.0425; H II;						
Orifice Material	- PTC Carbon Steel (<3 Cr);						
Corr factor pipe roughness	- 1						
Corr factor edge sharpness	- 1						
Flow Factor	- 0						
ASME Extrapolation	- No						
@1761 P HP Spray 1 Boiler	bar(a)	168.7	215.8	219.9	229.7	240.1	243.9
@1762 T HP Spray 1 Boiler	°C	178.3	176.5	174.7	170.0	165.4	152.6
@0105 dP HP Spray 1 W.Boiler	mbar	0	0	0	0	0	0
Density	kg/m3	898.95	903.62	905.62	910.78	915.71	927.71
Dynamic Viscosity	uPas	155.6	158.4	160.1	165.0	170.0	185.1
Corrected Pipe Diameter	mm	61.53	61.53	61.53	61.52	61.52	61.51
Corrected Orifice Diameter	mm	37.47	37.47	37.47	37.47	37.47	37.46
Diameter Ratio	-	0.60901	0.60901	0.60901	0.60901	0.60901	0.60902
Reynolds Number D	-	0	0	0	0	0	0
Reynolds Number d	-	0	0	0	0	0	0
Discharge Coefficient	-	0	0	0	0	0	0
Velocity of Approach Factor	-	1.07680	1.07680	1.07680	1.07680	1.07680	1.07681
Flow Coefficient	-	0	0	0	0	0	0
Validity	-	VALID	VALID	VALID	VALID	VALID	VALID
@1760 M HP Spray 1 Boiler	kg/s	0	0	0	0	0	0

FLOW CALCULATION ACCORDING ISO 5167-2003

Fluid type	Water						
Element type	ISO 5167 Long Radius Nozzle						
Pipe diameter	mm 40.2						
Orifice diameter	mm 26.76						
Pipe Material	- VDI 2040 - Steel I; 1.0425; H II;						
Orifice Material	- PTC Carbon Steel (<3 Cr);						
Corr factor pipe roughness	- 1						
Corr factor edge sharpness	- 1						
Flow Factor	- 0						
ASME Extrapolation	- No						
@1771 P HP Spray 2 Boiler	bar(a)	168.7	215.7	219.7	229.6	240.0	243.8
@1772 T HP Spray 2 Boiler	°C	178.3	176.5	174.7	170.0	165.4	152.6
@0115 dP HP Spray 2 W.Boiler	mbar	0	18.85	63.47	8.20	39.95	18.16
Density	kg/m3	898.95	903.61	905.61	910.78	915.70	927.71
Dynamic Viscosity	uPas	155.6	158.3	160.1	165.0	170.0	185.1
Corrected Pipe Diameter	mm	40.28	40.28	40.28	40.28	40.28	40.27
Corrected Orifice Diameter	mm	26.81	26.81	26.81	26.81	26.81	26.80
Diameter Ratio	-	0.66555	0.66555	0.66555	0.66555	0.66556	0.66556
Reynolds Number D	-	0	228592	416483	144845	312567	194257
Reynolds Number d	-	0	343464	625772	217631	469633	291868
Discharge Coefficient	-	0	0.98536	0.98825	0.98250	0.98697	0.98441
Velocity of Approach Factor	-	1.11540	1.11540	1.11540	1.11540	1.11540	1.11541
Flow Coefficient	-	0	1.09906	1.10229	1.09588	1.10087	1.09802
Validity	-	D<	D<	D<	D<	D<	D<
@1770 M HP Spray 2 Boiler	kg/s	0	1.15	2.11	0.76	1.68	1.14

FLOW CALCULATION ACCORDING ISO 5167-2003

Fluid type	Water						
Element type	ISO 5167 Long Radius Nozzle						
Pipe diameter	mm 44.5						
Orifice diameter	mm 27.24						
Pipe Material	- VDI 2040 - Steel I; 1.0425; H II;						
Orifice Material	- PTC Carbon Steel (<3 Cr);						
Corr factor pipe roughness	- 1						
Corr factor edge sharpness	- 1						
Flow Factor	- 0						
ASME Extrapolation	- No						
@1801 P RH Spray Boiler	bar(a)	73.86	75.95	77.22	80.41	83.11	82.98
@1802 T RH Spray Boiler	°C	175.61	173.55	171.42	112.56	105.63	139.39
@0110 dP RH Spray W.Boiler	mbar	78.06	30.91	19.83	0	0	3.90
Density	kg/m3	895.81	898.07	900.32	952.78	958.10	930.91
Dynamic Viscosity	uPas	155.7	157.7	159.9	250.6	268.1	199.5
Corrected Pipe Diameter	mm	44.59	44.59	44.59	44.55	44.55	44.57
Corrected Orifice Diameter	mm	27.29	27.29	27.29	27.27	27.27	27.28
Diameter Ratio	-	0.61202	0.61202	0.61203	0.61206	0.61206	0.61204
Reynolds Number D	-	427689	265464	209818	0	0	75212
Reynolds Number d	-	698811	433748	342825	0	0	122886
Discharge Coefficient	-	0.98869	0.98658	0.98535	0	0	0.97787
Velocity of Approach Factor	-	1.07852	1.07852	1.07852	1.07854	1.07854	1.07853
Flow Coefficient	-	1.06632	1.06405	1.06272	0	0	1.05466
Validity	-	D<	D<	D<	D<	D<	D<
@1800 M RH Spray Boiler	kg/s	2.33	1.47	1.17	0	0	0.53

REM HP Heater 6

@1700=@1750=@1760=@1770							
@1750 M FW after FW Pumps	kg/s	114.88	109.69	103.79	91.53	79.18	55.53
@1760 M HP Spray 1 Boiler	kg/s	0	0	0	0	0	0
@1770 M HP Spray 2 Boiler	kg/s	0	1.15	2.11	0.76	1.68	1.14
@1700 M FW Inlet HPH#6	kg/s	114.9	108.5	101.7	90.8	77.5	54.4

Preheater(\$102,\$170,\$171,\$172,\$00,@0800,@0801,@0802,@0803,@0804,Actual)

@1700 M FW Inlet HPH#6	kg/s	114.9	108.5	101.7	90.8	77.5	54.4
@1701 P FW Inlet HPH#6	bar(a)	184.7	179.8	176.6	170.9	165.3	160.1
@1702 T FW Inlet HPH#6	°C	215.6	213.3	210.9	204.5	198.3	182.2
@1703 H FW Inlet HPH#6	kJ/kg	928.9	918.6	907.7	878.8	851.4	780.7
@1710 M FW Outlet HPH#6	kg/s	114.88	108.54	101.68	90.77	77.50	54.39
@1711 P FW Outlet HPH#6	bar(a)	184.7	179.8	176.6	170.9	165.3	160.1
@1712 T FW Outlet HPH#6	°C	249.1	246.4	243.7	236.3	229.0	210.2
@1713 H FW Outlet HPH#6	kJ/kg	1082.4	1069.5	1056.7	1022.6	989.0	903.8
@1020 M Extraction HPH#6	kg/s	8.246	7.654	7.043	6.011	4.865	3.008
@1021 P Extraction HPH#6	bar(a)	39.15	37.21	35.25	30.83	26.81	18.65
@1022 T Extraction HPH#6	°C	351.0	345.3	342.9	334.1	324.7	296.4
@1023 H Extraction HPH#6	kJ/kg	3097.8	3088.3	3087.1	3076.4	3063.8	3019.8
@1720 M Drain HPH#6	kg/s	8.246	7.654	7.043	6.011	4.865	3.008
@1721 P Drain HPH#6	bar(a)	39.15	37.21	35.25	30.83	26.81	18.65
@1722 T Drain HPH#6	°C	221.1	218.6	215.9	209.1	202.0	184.3
@1723 H Drain HPH#6	kJ/kg	949.1	937.5	925.0	893.9	861.9	782.5
@0803 Q Heat Transfer HP6	kW	17630	16380	15151	13053	10658	6697
@0804 Q Loss HP6	kW	88.15	81.90	75.75	65.27	53.29	33.48
@0800 KA Preheater HP6	kW/K	1018	1003	987.1	931.5	866.8	682.1
@0801 KA Subcooler HP6	kW/K	73.33	68.57	64.01	55.07	48.07	35.79
@0802 CF Friction Coef HP6	-	0	0	0	0	0	0

REM HP Steam Flow Outlet Boiler and Hot Reheat Steam Flow Outlet Boiler

DNV GL - Energy Advisory

Process Technology & Measurements

Long Results Report

AnalysisBase : C:\Projects\AES_Norgener\TW-AES_Gener_Norgener

DNV·GL

ThermoWare 3.150

User : 9

Date : 2/12/2016

Time : 8:20:33 AM

Page : 6

@1000=@1750-@0901-@0902

@1750 M FW after FW Pumps	kg/s	114.88	109.69	103.79	91.53	79.18	55.53
@0901 M Leakage Boiler	kg/s	0.268	0.268	0.268	0.268	0.268	0.268
@0902 M Blow Down Boiler	kg/s	0	0	0	0	0	0
@1000 M HP Outlet Boiler	kg/s	114.61	109.42	103.52	91.26	78.91	55.26

@1005=@1000*3.6

@1000 M HP Outlet Boiler	kg/s	114.61	109.42	103.52	91.26	78.91	55.26
@1005 M HP Outlet Boiler	t/h	412.6	393.9	372.7	328.5	284.1	198.9

@1035=@1000-@1020-@0900-@0490

@1000 M HP Outlet Boiler	kg/s	114.61	109.42	103.52	91.26	78.91	55.26
@1020 M Extraction HPH#6	kg/s	8.246	7.654	7.043	6.011	4.865	3.008
@0900 M Leak HP Turb+Gland St.	kg/s	2.534	2.436	2.323	2.088	1.851	1.393
@0490 M Eject.Steam Design	kg/s	0.18	0.18	0.18	0.18	0.18	0.18
@1035 M CRH Inlet Boiler	kg/s	103.65	99.15	93.98	82.98	72.02	50.68

@1040=@1035+@1800

@1035 M CRH Inlet Boiler	kg/s	103.65	99.15	93.98	82.98	72.02	50.68
@1800 M RH Spray Boiler	kg/s	2.33	1.47	1.17	0	0	0.53
@1040 M RRH Outlet Boiler	kg/s	105.99	100.62	95.15	82.98	72.02	51.21

REM Heat Production Boiler

@0830=@1000*@1003-@1650*@1653+@1040*@1043-@1035*@1033-@1760*@1763-@1770*@1773-@1800*@1803

@1000 M HP Outlet Boiler	kg/s	114.61	109.42	103.52	91.26	78.91	55.26
@1003 H HP Outlet Boiler	kJ/kg	3406.9	3396.1	3398.2	3405.4	3406.7	3380.0
@1650 M FW Inlet Boiler	kg/s	114.88	108.54	101.68	90.77	77.50	54.39
@1653 H FW Inlet Boiler	kJ/kg	1117.7	1104.7	1091.5	1056.6	1022.1	932.4
@1040 M RRH Outlet Boiler	kg/s	105.99	100.62	95.15	82.98	72.02	51.21
@1043 H RRH Outlet Boiler	kJ/kg	3554.1	3554.3	3556.2	3555.6	3558.8	3497.5
@1035 M CRH Inlet Boiler	kg/s	103.65	99.15	93.98	82.98	72.02	50.68
@1033 H Cold RH Inl.Boiler	kJ/kg	3098.6	3089.2	3087.6	3077.3	3064.7	3021.3
@1760 M HP Spray 1 Boiler	kg/s	0	0	0	0	0	0
@1763 H HP Spray 1 Boiler	kJ/kg	764.0	758.8	751.3	731.6	712.7	658.2
@1770 M HP Spray 2 Boiler	kg/s	0	1.15	2.11	0.76	1.68	1.14
@1773 H HP Spray 2 Boiler	kJ/kg	764.0	758.8	751.3	731.6	712.7	658.2
@1800 M RH Spray Boiler	kg/s	2.33	1.47	1.17	0	0	0.53
@1803 H RH Spray Boiler	kJ/kg	747.2	738.4	729.2	477.9	448.9	591.8
@0830 Q Boiler Heat Prod.	kJ/s	315833	301067	286586	254021	223998	160985

REM Fuel Efficiency Boiler Corrected

@0950=@0520*(100+(@0952+@0953+@0954+@0955+@0956))/100

@0520 Ym Fuel Eff.Boiler Meas.	%	87.90	87.82	87.86	88.27	88.33	88.04
@0952 Xc Amb.Temp.Corr.Ym	%	-0.035	-0.048	-0.043	-0.036	-0.045	-0.032
@0953 Xc Humidity Corr.Ym	%	-0.002	0.009	-0.001	-0.007	0.001	0.014
@0954 Xc Hydrogen Corr.Ym	%	0.000	0.000	0.000	0.000	0.000	0.000
@0955 Xc Moisture Corr.Ym	%	0.000	0.000	0.000	0.000	0.000	0.000
@0956 Xc Theor.Dry Air	%	0.000	0.000	0.000	0.000	0.000	0.000
@0950 Yc Fuel Eff.Boiler Corr.	%	87.87	87.79	87.82	88.24	88.29	88.03

REM Fuel Consumption Boiler Corrected

@0960=@0830/@0950*100

@0830 Q Boiler Heat Prod.	kJ/s	315833	301067	286586	254021	223998	160985
@0950 Yc Fuel Eff.Boiler Corr.	%	87.87	87.79	87.82	88.24	88.29	88.03
@0960 Qc Fuel Cons.Corr.Plan	kJ/s	359445	342946	326338	287887	253696	182883

REM Correction as per CDEC-SING Definition

@0561=@0010*((@0544-(@0544+@0545)/2)+@0540)+@0020*((@0545-(@0545+@0544)/2)+@0541)

@0010 F Unit#1 in Operation	1/0	0	0	0	0	0	0
@0544 Pe Common Users Unit#1	kW	106	106	106	106	106	106
@0545 Pe Common Users Unit#2	kW	57	57	57	57	57	57
@0540 Pe Ligthing Unit 1	kW	152	152	152	152	152	152
@0020 F Unit#2 in Operation	1/0	1	1	1	1	1	1
@0541 Pe Ligthing Unit 2	kW	152	152	152	152	152	152
@0561 Pe Aux.Power CEDC-SING	kW	128	128	128	128	128	128

REM Gross Power Plant Corrected and Heat Rate and Efficiency Steam Turbine

@0966=@0530+@0957+@0958

@0530 Pe Gross Pow.Gen (kWh)	kW	136252	129267	122472	108664	95407	65946
@0957 Pe Add.Corr.Pow.Factor	kW	-361	-327	-295	-238	-184	-90
@0958 Pe Add.Corr.CW Temp.	kW	-191	-197	-65	-246	-235	-295
@0966 Pe Gross Power Unit Corr.	kW	135700	128743	122112	108180	94988	65560

@0831=@0830/@0966*3600

@0830 Q Boiler Heat Prod.	kJ/s	315833	301067	286586	254021	223998	160985
@0966 Pe Gross Power Unit Corr.	kW	135700	128743	122112	108180	94988	65560
@0831 HR Gross ST System	kJ/kWh	8378.8	8418.7	8448.9	8453.3	8489.4	8839.9

@0832=360000/@0831

@0831 HR Gross ST System	kJ/kWh	8378.8	8418.7	8448.9	8453.3	8489.4	8839.9
@0832 Y Eff. Gross ST System	%	42.97	42.76	42.61	42.59	42.41	40.72

@0965=@0560+@0561+@0957+@0958

@0560 Pe Net Power Unit (kWh)	kW	125479	118877	112468	99499	86803	57998
@0561 Pe Aux.Power CEDC-SING	kW	128	128	128	128	128	128
@0957 Pe Add.Corr.Pow.Factor	kW	-361	-327	-295	-238	-184	-90
@0958 Pe Add.Corr.CW Temp.	kW	-191	-197	-65	-246	-235	-295
@0965 Pe Net Power Unit Corr.	kW	125055	118480	112236	99143	86512	57740

@0833=@0830/@0965*3600

@0830 Q Boiler Heat Prod.	kJ/s	315833	301067	286586	254021	223998	160985
@0965 Pe Net Power Unit Corr.	kW	125055	118480	112236	99143	86512	57740
@0833 HR Net ST System	kJ/kWh	9092.0	9147.9	9192.3	9223.8	9321.2	10037.2

@0834=360000/@0833

@0833 HR Net ST System	kJ/kWh	9092.0	9147.9	9192.3	9223.8	9321.2	10037.2
@0834 Y Eff. Net ST System	%	39.60	39.35	39.16	39.03	38.62	35.87

REM Net Heat Rate of the Plant Corrected

@0970=@0960/@0965*3600

@0960 Qc Fuel Cons.Corr.Plan	kJ/s	359445	342946	326338	287887	253696	182883
@0965 Pe Net Power Unit Corr.	kW	125055	118480	112236	99143	86512	57740
@0970 HR Net HR Plant Corr.	kJ/kWh	10347	10420	10467	10454	10557	11402

@0971=360000/@0970

@0970 HR Net HR Plant Corr.	kJ/kWh	10347	10420	10467	10454	10557	11402
@0971 Y Net Eff.Plan Corr.	%	34.79	34.55	34.39	34.44	34.10	31.57

REM Mass Flow of Coal based on HHV as Fired

@0975=@0960/@0295

@0960 Qc Fuel Cons.Corr.Plan	kJ/s	359445	342946	326338	287887	253696	182883
@0295 HHV Value of Coal	kJ/kg	23580	23614	23542	23777	23542	23505
@0975 M Coal Corr.HHV (Fired)	kg/s	15.24	14.52	13.86	12.11	10.78	7.78

DNV GL - Energy Advisory

Process Technology & Measurements

Long Results Report

AnalysisBase : C:\Projects\AES_Norgener\TW-AES_Gener_Norgener

DNV·GL

ThermoWare 3.150

User : 9

Date : 2/12/2016

Time : 8:20:33 AM

Page : 8

@0650=(@0975-@0905)/@0975*100

@0975 M Coal Corr.HHV (Fired)	kg/s	15.24	14.52	13.86	12.11	10.78	7.78
@0905 M Flow Coal Total (DCS)	kg/s	13.87	13.22	12.49	10.79	9.51	6.86
@0650 X Dev.Coal Calc->DCS	%	9.0	9.0	9.9	10.8	11.8	11.9

REM Mass Flow of Coal based on Standard HHV (6000 kCal/kg)

@0976=@0975*@0295/4.1868/@0511

@0975 M Coal Corr.HHV (Fired)	kg/s	15.24	14.52	13.86	12.11	10.78	7.78
@0295 HHV Value of Coal	kJ/kg	23580	23614	23542	23777	23542	23505
@0511 HHV Coal Standard	kCal/kg	6000.0	6000.0	6000.0	6000.0	6000.0	6000.0
@0976 M Coal Corr.HHV (6000)	kg/s	14.31	13.65	12.99	11.46	10.10	7.28

REM Net Heat Rate of Plant Corrected to Standard HHV (6000 kCal/kg)

@0980=@0976/@0965*3.6*10^6

@0976 M Coal Corr.HHV (6000)	kg/s	14.31	13.65	12.99	11.46	10.10	7.28
@0965 Pe Net Power Unit Corr.	kW	125055	118480	112236	99143	86512	57740
@0980 HR Net Plant Corr.(6000)	g/kWh	411.9	414.8	416.7	416.1	420.2	453.9

REM HP Steam Turbine Isentropic Efficiency

SteamTurbine(\$100,\$00,\$103,\$00,\$00,@0810,@0811,@0812,@0813,Actual,Pi)

Actual Calculation, Internal Power is unknown

@1000 M HP Outlet Boiler	kg/s	114.61	109.42	103.52	91.26	78.91	55.26
@1001 P HP Outlet Boiler	bar(a)	165.6	162.1	160.4	157.3	154.4	153.6
@1002 T HP Outlet Boiler	°C	540.4	535.1	535.2	536.5	535.8	525.9
@1003 H HP Outlet Boiler	kJ/kg	3406.9	3396.1	3398.2	3405.4	3406.7	3380.0
@1030 M Cold RH Inl.Boiler	kg/s	114.6	109.4	103.5	91.26	78.91	55.26
@1031 P Cold RH Inl.Boiler	bar(a)	39.08	37.14	35.17	30.75	26.73	18.59
@1032 T Cold RH Inl.Boiler	°C	351.3	345.6	343.1	334.4	325.0	297.0
@1033 H Cold RH Inl.Boiler	kJ/kg	3098.6	3089.2	3087.6	3077.3	3064.7	3021.3
@0813 Pi Power HP	kW	35336	33577	32161	29947	26985	19826
@0812 Q Loss HP	kW	0	0	0	0	0	0
@0811 CT Flow Factor HP	-	1.302	1.263	1.206	1.081	0.948	0.657
@0810 Ys Efficiency HP	%	74.61	73.52	72.50	71.70	70.34	64.78

REM End of Program

APPENDIX G

Results ASME PTC 4 Heat Balance Method

APPENDIX G1

Results ASME PTC 4 Heat Balance Method Test at 100% Load

Form CMBSTNa Combustion Calculations

DATA REQUIRED					
1	HHV - Higher Heating value of Fuel, kJ/kg as fired, from Input Data Sheet [1]				23580
2	UBC - Unburned Carbon, kg/ 100 kg fuel from RES [11] or SRBb FORM				0.166
3	Fuel Flow, kg/hr [4b]				54856
4	a. Measured Fuel Flow				49932.0
4	b. Calculated Fuel Flow $100,000 \times [5] / [6] / [1]$				54856.4
5	Output, MJ/hr from Output Item [37]				1136999
6	Fuel Efficiency, % (estimate initially), from Input Data Sheet [6]				87.90
7	Moisture in air, kg/kg Dry Air				0.00998
8	Barometric Pressure, mbar, from Input Data Sheet [8]				1009.6
9	Dry Bulb Temperature, °C, from Input Data Sheet [9]				20.8
10	Wet Bulb Temperature, °C, from Input Data Sheet [10]				16.5
11	Relative Humidity, %, from Input Data Sheet [11]				64.8
	Additional Moisture (Measured)	kg/hr			
	Atomizing Steam	from Output Item [14]	kg/hr		0.0
	Sootblowing Steam	from Output Item [11]	kg/hr		0.0
	Other		kg/hr		0.0
12	Summation Addition Moisture				0.0
13	Additional Moisture.kg/ 100 kg Fuel $100 \times [12] / [3]$				0.0
14	Additional Moisture, kg/100 kJ $[13] / ([1] / 100)$				0.0
	If Air Heater (Excl Stm/ Wtr Coil) Enter following				
15	Gas Temp Lvg AH, °C, from Input Data Sheet [15]	Primairy / Secundairy or Main		15A	143.5
16	Air Temp Ent AH, °C, from Input Data Sheet [16]	Primairy / Secundairy or Main	16B	25.5	16A 26.1
17	O2 in FG Ent Air Heater, %, from Input Data Sheet [17]	Primairy / Secundairy or Main		17A	3.04
18	O2 in FG Lvg Air Heater, %, from Input Data Sheet [18]	Primairy / Secundairy or Main		18A	6.55
18a	Mass Flow Fraction, %, from Input Data Sheet [18a]	Primairy / Secundairy or Main	18C	68.29	18D 31.71
19	Mass Ash, kg/100 kJ $100 \times [30j] / [1]$				0.024
	If mass of ash (item [19]) exceeds 0.065 kg/100 kJ or Sorbent utilized, Enter Mass Fraction of Refuse in Col [79] for each location				
	SORBENT DATA (Enter 0 if Sorbent not Used)				0
20	Sorbent Rate, kg/hr				0.000
21	CO2 from Sorbent, kg/ 100 kg Sorbent	from SRBa item [25I]			0.000
22	H2O from Sorbent, kg/ 100 kg Sorbent	from SRBa item [26I]			0.000
23	Sulfur Capture, kg/kg Sulfer	from SRBb item [45]			0.000
24	Spent Sorbent, kg/ 100 kg fuel	from SRBb item [48]			0.000
25	Sorb/Fuel Ratio, kg Sorb / kg Fuel	[20]/[3]			0.000
	HOT AIR QUALITY CONTROL EQUIPMENT DATA				
26	O2 in FG Ent HAQC Flue Gas Temperatures				N/A
	See Form EFFa for HAQC Flue Gas Temperatures				
PLANT NAME : NORGNER ASME PTC 4 MASTER FORM			UNIT NO.	2	
TEST NO :	1	DATE :	15-Dec-15	LOAD	100%
TIME START :	9:00	TIME END :	11:00	CALC BY	R. Tim
REMARKS :				DATE	11-Feb-16
				SHEET 1 of 3	

Form CMBSTNb Combustion Calculations

COMBUSTION PRODUCTS											
30	from Input Data Sheet		31	Theo Air Flow kg/100kg Fuel [30] x K	32	Dry Prod Flow Mol/100 kg Fuel [30] / K	33	Wet Prod Flow Mol/100 kg Fuel [30] / K	34	H2O Fuel kg/100 kJ [30] x K / ([1]) / 100	
	Ultimate Analysis % Mass										
A	C	59.08									
B	UBC		0.166								
C	Cb	58.91		11.51	678.10	12.0110	4.905				
D	S	0.41			4.31	1.77	32.0640	0.013			
E	H ₂	3.70			34.29	126.87			2.0159	1.835	
F	H ₂ O	18.62							18.0153	1.034	
G	H ₂ Ov	0.00							18.0153	0.000	
H	N ₂	0.94				28.0134	0.034				
I	O ₂	11.48			-4.32	-49.59					
J	ASH	5.77									
K	VM	32.96									
L	FC	42.64									
M	TOTAL	100.00		31	757.14	32	4.951	33	2.869	34	0.219
35	Total Theo Air Fuel Check, kg/100 kJ	([31M] + [30B] x 11.51) / ([1] / 100)								3.219	
CORRECTIONS FOR SORBENT REACTIONS AND SULFUR CAPTURE											
40	CO ₂ from Sorb, kg/100 kg fuel	[21] x [25]								0.000	
41	H ₂ O from Sorb, kg/100 kg fuel	[22] x [25]								0.000	
42	SO ₂ Reduction, Mol/100 kg fuel	[32D] x [23]								0.000	
43	Dry Prod Comb, Mol/100 kg fuel	[32M] + [40] / 44.01 - [42]								4.951	
44	Wet Prod Comb, Mol/100 kg fuel	[33M] + [41] / 18.0153 + [43]								7.820	
46	Theo Air Corr, kg/100 kg fuel	[31M] + 2.16 x [30D] x [23]								757.14	
47	Theo Air Corr, Mol/100 kg fuel	[46] / 28.9625								26.142	
48	Theo Air Corr, kg/100 kJ	[46] / ([1] / 100)								3.211	
49	Wet Gas from Fuel, kg/100 kJ	(100 - [30J] - [30B] - [30D] x [23]) / ([1] / 100)								0.399	
LOCATION										AH In	AH Out
50	Flue Gas Temperature Entering Air heater °C									368.2	143.5
51	Air Temperature Leaving Air Heater, °C									25.69	334.5
52	Flue Gas Oxygen Content, %									3.040	6.550
FLUE GAS ANALYSIS, Mol/100 kg Fuel											
53	Moisture in Air	0		[7] x 1.608				0.00		0.00	
54	Dry/Wet Products Comb	[43]		[44]				4.951		4.951	
55	Additional Moisture	0		[13] / 18.0153				0.00		0.00	
56	[47] x (0.7905 + [53])									20.67	20.67
57	Summation	[54] + [55] + [56]								25.62	25.62
58	20.95 - [52] x (1 + [53])									17.91	14.40
60	Excess Air, %	100 x [52] x [57] / [47] / [58]								16.63	44.57
PLANT NAME : NORGENER ASME PTC 4 MASTER FORM											
TEST NO :	1	DATE :	15-Dec-15		UNIT NO.		2		LOAD	100%	
TIME START :	9:00	TIME END :	11:00		CALC BY		R. Tim		DATE	11-Feb-16	
REMARKS :									SHEET 2 of 3		

Form CMBSTNc Combustion Calculations

LOCATION						AH In	AH Out
60 Excess Air, %						16.63	44.57
02, CO2, SO2, WHEN EXCESS AIR KNOWN							
61							
62 Dry	[47] x (0.7905 + ([60] / 100))					25.01	32.32
63 Wet	[47] x (0.7905 + [53] + (1 + [53]) x [60] / 100)					25.01	32.32
64 Dry Gas, Mol/100 kg Fuel	[43] + [62]					29.96	37.27
65 Wet Gas, Mol/100 kg Fuel	[44] + [63] + [13] / 18.015					32.83	40.14
		Dry	Wet				
66 O2, %	[60] x [47] x 0.2095 / [65]	[64]	[65]			2.77	6.08
67 CO2,%	([30c]/0.1201+[40]/0.4401)/[65]	[64]	[65]			14.94	12.22
68 SO2,ppm	(1-[23]) x [30D] / 0.32064 / [65]	[64]	[65]			389.4	318.6
FLUE GAS PRODUCTS, kg/100 kJ							
69 Dry Air	(1 + [60] / 100) x [48]					3.745	4.642
70 Wet Gas from Fuel	[49]					0.399	0.399
71 CO2 from Sorbent	[40] / ([1] / 100)					0.000	0.000
72 Moisture in Air	[7] x [69]					0.037	0.046
73 Water from Sorbent	[41] / ([1] / 100)					0.000	0.000
74 Additional Moisture	[14]					0.000	0.000
75 Total Wet Gas	[69] + [70] + [71] + [72] + [73] + [74]					4.181	5.087
76 H2O in Wet Gas	[34M] + [72] + [73] + [74]					0.257	0.266
77 Dry Gas	[75] - [76]					3.925	4.822
78 H2O in Wet Gas, % Mass	100 x [76] / [75]					6.14	5.22
79 Residue, kg/kg Total Refuse at each location						0.00	0.00
80 Residue, kg/100 kJ	([30J] + [2] + [24]) / ([1] / 100)					0.0252	0.0252
81 Residue in Wet Gas, kg/kg	[79] x [80] / [75] Wet Gas					0.000	0.000
82 Leakage, % Gas Entering	100 x ([75L] - [75E]) / [75E]						21.67
GAS TEMPERATURE CORRECTION FOR AH LEAKAGE							
83 Gas Temp Lvg (INCL LKG), °C	[15]					368.21	143.52
84 Average AH Air Leakage Temp, °C	([16B] x [18B] + [16A] x [18D]) / 100					25.69	334.53
85 H Air Lvg, kJ/kg	T=[83], H2O=[7]						120.61
86 H Air Ent, kJ/kg	T=[84], H2O=[7]					0.695	
87 Cpg, kJ/kg°C	T=[83], H2O=[78E], RES=[81E]						1.061
88 AH Gas Outlet Temperature Excluding Leakage, °C	[83] + ([82] / 100 x ([85] - [86]) / [87])						168.02
AIR, GAS, FUEL & RESIDUE MASS FLOW RATES, kg/hr							
90 Input from Fuel, MJ/hr	[5] / [6] x 100						1293514
91 Fuel Rate, kg/hr	1000 x [90] / [1]						54856
92 Residue Rate, kg/hr	[80] x [90] / 10						3257
93 Wet Flue Gas, kg/hr	[75] x [90] / 10					540857	638058
95 Excess Air Lvg Blr, %	[60]						44.57
96 Total Air to Blr, kg/hr	(1 + [95] / 100) x (1 + [7]) x [48] x [90] / 10						606458
PLANT NAME : NORGENER ASME PTC 4 MASTER FORM				UNIT NO.	2		
TEST NO :	1	DATE :	15-Dec-15	LOAD	100%		
TIME START :	9:00	TIME END :	11:00	CALC BY	R. Tim		
REMARKS :				DATE	11-Feb-16		
				SHEET 3 of 3			

Form RES Unburned Carbon and Residue Calculation

DATA REQUIRED FOR RESIDUE SPLIT												
1	Ash in Fuel, %	from Form CMBSTNb [30J]			5.77	2	HHV Fuel, kJ/kg 'as fired'			23580		
3	Fuel Mass Flow Rate, kg/hr	from Form CMBSTNa [4b]			54856	4b	from Form CMBSTNa [1]					
a)	Item [3] - Use measured or estimated value initially. (See CMBSTNa) Recalculate after boiler efficiency has been calculated until estimated value is within 1% of calculated value.											
b)	Residue splits estimated. Enter value in Col [8] and calculate Col [5]. Residue rate measured. Enter measured mass flow rates in Col [5]. When residue is not measured at all locations, estimate split and flow for measured locations. Reiterate until estimated total residue is within 2% of calculated.											
c)	Enter the % free carbon in Col [6] (total carbon corrector for CO2). Units with sorbent: Enter the % CO2 in Col [7].											
Location	5	Residue Mass Flow	6	C in Residue %	7	CO2 in Residue %	8	Residue Split %	9	10		
	Input kg/hr	Calculated kg/hr					Input	Calculated 100 x [5]/[5F]	C Wtd Ave % [6] x [8]/100	CO2 Wtd Ave % [7] x [8]/100		
A Bottom Ash	0.00	0.00	4.07	5.00		15.00	0.00	0.611		0.750		
B Fly Ash	0.00	0.00	2.58	2.00		85.00	0.00	2.193		1.700		
C Economizer	0.00	0.00	0.00	0.00		0.00	0.00	0.000		0.000		
D	0.00	0.00	0.00	0.00		0.00	0.00	0.000		0.000		
E	0.00	0.00	0.00	0.00		0.00	0.00	0.000		0.000		
F TOTAL	5	0.00	0.00			8	100.0	0.00	9	2.804	10	2.450
UNITS WITHOUT SORBENT												
11	Unburned Carbon, kg/ 100 kg Fuel				[1] x [9F] / (100 - [9F])					0.166		
20	Total Residue, kg/ 100kg Fuel				[1] + [11]					5.94		
UNITS WITH SORBENT												
d)	Enter average C and CO2 in residue, [9F] and [10F] above or SRBa (Items [4] and [5]) and complete Sorbent Calculation Forms.											
11	Unburned Carbon, kg/ 100 kg Fuel				from Form SRBb Item [49]					0.196		
20	Total Residue, kg/ 100 Fuel				from Form SRBb Item [50]					6.99		
TOTAL RESIDUE												
21	Total Residue, kg/hr				[20] x [3] /100					3257		
e)	When all residue collection locations are measured, the measured residue split is used for calculations. If a portion of the residue mass is estimated, repeat calculation above until Col [5F] and Item [21] agree within 2%.											
22	Total Residue, kg/100 J				100 x [20] / [2]					0.025		
23	SENSIBLE HEAT RESIDUE LOSS, %											
Location	24	Temp Residue (°C)	[8]	x	[22]	Residue	x	H Residue	/ 10,000	Loss %		
			%		kg/ 100 kJ		kJ/kg					
A Furnace	1100		15.00	x	0.025	x	1205.2	/ 10,000		0.046		
B Fly Ash	120		85.00	x	0.025	x	76.7	/ 10,000		0.016		
C Economizer	0		0.00	x	0.025	x	-30.1	/ 10,000		0.000		
D	0									0.000		
E	0									0.000		
								Total	25	0.062		
H Residue = 0.16 x T + 1.09E-4 x T^2 - 2.843E-8 x T^3 - 12.95												
PLANT NAME : NORGENER ASME PTC 4 MASTER FORM					UNIT NO.			2				
TEST NO :	1	DATE:	15-Dec-15			LOAD	100%					
TIME START :	9:00	TIME END :	11:00			CALC BY	R. Tim					
REMARKS :						DATE	11-Feb-16					
						SHEET 1 of 1						

**Form EFFa Efficiency Calculations
Data**

TEMPERATURES, °C																									
1	Reference Temperature, °C	25.0	1A	Enthalpy Water (0°C Ref), kJ/kg	104.57																				
2	Average Entering Air Temp, from CMBSTNa Item [84]: ([16B]x[18B]+[16A]x[18D])/100	25.69	2A	Enthalpy Dry Air, kJ/kg	0.69																				
3	Average Exit Gas T (Excl Lkg) from CMBSTNa [88]	168.0	3A	Enthalpy Dry Gas, kJ/kg	143.30																				
			3B	Enthalpy Steam @ 1 psia, kJ/kg	2814.9																				
			3C	Enthalpy Water Vapor, kJ/kg	270.37																				
4	Fuel Temperature	20.8	4A	Enthalpy Fuel, kJ/kg	-5.75																				
HOT AIR QUALITY CONTROL EQUIPMENT																									
5	Entering Gas Temperature	0.0	5A	Enthalpy Wet Gas	0.00																				
6	Leaving Gas Temperature	0.0	6A	Enthalpy of Wet Gas	0.00																				
			6B	Enthalpy of Wet Air	0.00																				
			6C	Enthalpy of Wet Air @ T = [3]	0.00																				
RESULTS FROM COMBUSTION CALCULATION FORM CMBSTN																									
10	Dry Gas Weight, kg/100 kJ [77]	3.925	18	Unburned Carbon, % [2]	0.166																				
11	Dry Air Weight [69]	3.745	19	HHV kJ/kg 'as-fired' [1]	23580.0																				
12	Water from H ₂ Fuel [34E]	0.140	HOT AQC EQUIPMENT																						
13	Water from H ₂ O Fuel [34F]	0.079	20	Wet Gas Entering [75E]	0.00																				
14	Water from H ₂ Ov Fuel [34G]	0.000	21	H ₂ O in Wet Gas, % [78E]	0.00																				
15	Moisture in Air kg/kg DA [7]	0.00998	22	Wet Gas Leaving [75L]	0.00																				
16	Moisture in Air kg/100 kJ [72]	0.037	23	Residue in Wet Gas, % [81E]	0.00																				
17	Fuel Rate Est. kg/hr [3]	54856	25	Excess Air, % [95]	44.57																				
MISCELLANEOUS																									
30	Unit Output, MJ/hr	1136999	31	Aux Equip Power, MJ/hr	4068																				
32	Loss Due to Surface Radiation and Convection, %				0.25																				
<table border="1"> <tr> <td>PLANT NAME :</td> <td>ASME PTC 4 MASTER FORM</td> <td>UNIT NO.</td> <td>2</td> </tr> <tr> <td>TEST NO :</td> <td>DATE :</td> <td>LOAD</td> <td>100%</td> </tr> <tr> <td>TIME START :</td> <td>TIME END :</td> <td>CALC BY</td> <td>R. Tim</td> </tr> <tr> <td>REMARKS :</td> <td></td> <td>DATE</td> <td>11-Feb-16</td> </tr> <tr> <td colspan="4">SHEET 1 of 3</td> </tr> </table>						PLANT NAME :	ASME PTC 4 MASTER FORM	UNIT NO.	2	TEST NO :	DATE :	LOAD	100%	TIME START :	TIME END :	CALC BY	R. Tim	REMARKS :		DATE	11-Feb-16	SHEET 1 of 3			
PLANT NAME :	ASME PTC 4 MASTER FORM	UNIT NO.	2																						
TEST NO :	DATE :	LOAD	100%																						
TIME START :	TIME END :	CALC BY	R. Tim																						
REMARKS :		DATE	11-Feb-16																						
SHEET 1 of 3																									

Form EFFb Efficiency Calculations

LOSSES, % Enter Calculated Result in % Column [B]			A	MKB	B	%
60 Dry Gas	[10] x [3A] x /100					5.624
61 Water from H2 Fuel	[12] x ([3B] - [1A]) / 100 x - 104.57) / 100					3.801
62 Water from H2O Fuel	[13] x ([3B] - [1A]) / 100 x - 104.57) / 100					2.140
63 Water from H2O Fuel	[14] x ([3C]) / 100 x / 100					0.000
64 Moisture in Air	[16] x [3C] / 100 x / 100					0.101
65 Unburned Carbon in Ref [18] x 33700 / [19] =	x 33700/					0.238
66 Sensible Heat of Refuse from Form RES						0.062
67 Hot AQC Equip ((20) x ([5A] - [6A]) - ([22] - [20]) x ([6C] - [6B])) / 100 (-) - (-) x (-)) / 100						0.000
68 Other Losses, % Basis from Form EFFc Item [110]						0.450
69 Summation of Losses, % Basis						12.416
LOSSES, MJ/hr Enter in MKB Column [A]						
75 Surface Radiation and Convection from Form EFFa Item [32]					0.000	
76 Sorbent Calcination / Dehydration from Form SRBc Item [77]					0.000	
77 Water from Sorbent from Form SRBc Item [65]					0.000	
80 Other Losses, MJ/hr Basis from Form EFFc Item [111]					0.000	
81 Summation of Losses, MJ/hr Basis					0.000	
CREDITS, % Enter Calculation Result in % Column [B]						
85 Entering Dry Air	[11] x [2A] /100 x /100					0.026
86 Moisture in Air	[16] x [2B] /100 x /100					0.000
87 Sensible Heat in Fuel	100 x [4A] / [19] 100 x /					-0.024
88 Sulfation from Form SRBc Item [80]						0.000
89 Other Credits, % Basis from Form EFFc Item [112]						0.000
90 Summation of Credits, % Basis						0.002
CREDITS, MJ/hr Enter Calculated Result in MKB Column [A]						
95 Auxiliary Equipment Power [31]				4068.0		
96 Sensible Heat from Sorbent from Form SRBc Item [85]				0.000		
97 Other Credits, MJ/hr Basis from Form EFFc Item [113B]				0.000		
98 Summation of Credits, MJ/hr Basis				4068.0		
100 Fuel Eff, % (100 - [69] + [90]) x [30] / ([30] + [81] - [98]) (100 - +) x / (+ -)						87.90
101 Input from Fuel, MJ/hr 100 x [30] / [100] = 100 x /				1293508		
102 Fuel Rate, kg/hr 1.000 x [101] / [19] = 1.000 x /						54856
PLANT NAME : NORGENER	ASME PTC 4 MASTER FORM	UNIT NO.	2			
TEST NO : 1	DATE : 15-Dec-15	LOAD	100%			
TIME START : 9:00	TIME END : 11:00	CALC BY	R. Tim			
REMARKS :		DATE	11-Feb-16			
		SHEET 2 of 3				

Form EFFc Efficiency Calculations
Other Losses and Credits

The losses and credits listed on this sheet are not universally applicable to all fossil fired steam generators and are usually minor. Losses/credits that have not been specifically identified by this Code but are applicable in accordance with the intent of the Code should also be recorded on this sheet.

Parties to the test may agree to estimate the losses or credits in lieu of testing. Enter a 'T' for tested or 'E' for estimate in the second column, and result in the appropriate column.

Enter the sum of each group on Form EFFb.

Refer to the text of PTC 4 for the calculation method.

Item	T or E	LOSSES, % Enter Calculated Result in % Column [B]	A	MKB	B	%
110A		CO in Flue Gas				0.000
110B		Formation of NOx				0.000
110C		Pulverizer Rejects				0.000
110D		Air Infiltration				0.000
110E		Unburned Hydrocarbons in Flue Gas				0.000
110F		Unburned Hydrogen in Refuse				0.000
110G	E	Unmeasured Loss, as per agreement				0.200
110H	E	Surface Radiation Loss, as per agreement				0.250
110		Summation of Other Losses, % Basis				0.450
<hr/>						
LOSSES, MJ/hr Enter in MKB Column [A]						
111A		Wet Ash Pit				0.000
111B		Sensible Heat in Recycle Streams, Solid				0.000
111C		Sensible Heat in Recycle Streams, Gas				0.000
111D		Additional Moisture				0.000
111E		Cooling Water				0.000
111F		Air Preheater Coil (supplied by Unit)				0.000
111G		Other				0.000
111		Summation of other Losses, MJ/hr Basis				0.000
<hr/>						
CREDITS, % Enter Calculation Result in % Column [B]						
112A		Other				0.000
112		Summation of Credits, % Basis				0.000
<hr/>						
CREDITS, MJ/hr Enter Result in MKB Column [A]						
113A		Heat in Additional Moisture (external to envelope)				0.000
113B		Other				0.000
113C		Heat by Auxiliary Equipment Power				4068.0
113		Summation of Credits, MJ/hr Basis				4068.0
<hr/> <hr/> <hr/> <hr/> <hr/> <hr/>						
PLANT NAME : NORGENER		ASME PTC 4 MASTER FORM	UNIT NO.		2	
TEST NO :	1	DATE : 15-Dec-15	LOAD		100%	
TIME START :	9:00	TIME END : 11:00	CALC BY		R. Tim	
REMARKS :			DATE		11-Feb-16	
					SHEET 3 of 3	

APPENDIX G2

Results ASME PTC 4 Heat Balance Method Test at 95% Load

Form CMBSTNa Combustion Calculations

DATA REQUIRED						
1	HHV - Higher Heating value of Fuel, kJ/kg as fired, from Input Data Sheet [1]				23614	
2	UBC - Unburned Carbon, kg/ 100 kg fuel from RES [11] or SRBb FORM				0.217	
3	Fuel Flow, kg/hr [4b]				52263	
4	a. Measured Fuel Flow			47592.0		
4	b. Calculated Fuel Flow 100,000 x [5] / [6] / [1]			52262.8		
5	Output, MJ/hr from Output Item [37]			1083841		
6	Fuel Efficiency, % (estimate initially), from Input Data Sheet [6]			87.82		
7	Moisture in air, kg/kg Dry Air			0.01109		
8	Barometric Pressure, mbar, from Input Data Sheet [8]			1009.5		
9	Dry Bulb Temperature, °C, from Input Data Sheet [9]			21.5		
10	Wet Bulb Temperature, °C, from Input Data Sheet [10]			17.7		
11	Relative Humidity, %, from Input Data Sheet [11]			69.0		
	Additional Moisture (Measured) kg/hr					
	Atomizing Steam from Output Item [14] kg/hr			0.0		
	Sootblowing Steam from Output Item [11] kg/hr			0.0		
	Other kg/hr			0.0		
12	Summation Addition Moisture			0.0		
13	Additional Moisture.kg/ 100 kg Fuel 100 x [12] / [3]			0.0		
14	Additional Moisture, kg/100 kJ [13] / ([1] / 100)			0.0		
	If Air Heater (Excl Stm/ Wtr Coil) Enter following					
15	Gas Temp Lvg AH, °C, from Input Data Sheet [15]	Primairy / Secundairy or Main		15A	139.7	
16	Air Temp Ent AH, °C, from Input Data Sheet [16]	Primairy / Secundairy or Main	16B	23.2	16A 23.8	
17	O2 in FG Ent Air Heater, %, from Input Data Sheet [17]	Primairy / Secundairy or Main		17A	3.41	
18	O2 in FG Lvg Air Heater, %, from Input Data Sheet [18]	Primairy / Secundairy or Main		18A	6.69	
18a	Mass Flow Fraction, %, from Input Data Sheet [18a]	Primairy / Secundairy or Main	18C	67.23	18D 32.77	
19	Mass Ash, kg/100 kJ 100 x [30j] / [1]			0.024		
	If mass of ash (item [19]) exceeds 0.065 kg/100 kJ or Sorbent utilized, Enter Mass Fraction of Refuse in Col [79] for each location					
	SORBENT DATA (Enter 0 if Sorbent not Used)					0
20	Sorbent Rate, kg/hr			0.000		
21	CO2 from Sorbent, kg/ 100 kg Sorbent	from SRBa item [25I]			0.000	
22	H2O from Sorbent, kg/ 100 kg Sorbent	from SRBa item [26I]			0.000	
23	Sulfur Capture, kg/kg Sulfer	from SRBb item [45]			0.000	
24	Spent Sorbent, kg/ 100 kg fuel	from SRBb item [48]			0.000	
25	Sorb/Fuel Ratio, kg Sorb / kg Fuel	[20]/[3]			0.000	
	HOT AIR QUALITY CONTROL EQUIPMENT DATA					
26	O2 in FG Ent HAQC Flue Gas Temperatures			N/A		
	See Form EFFa for HAQC Flue Gas Temperatures					
PLANT NAME : NORGNER ASME PTC 4 MASTER FORM			UNIT NO.	2		
TEST NO :	2	DATE :	16-Dec-15	LOAD	95%	
TIME START :	9:00	TIME END :	11:00	CALC BY	R. Tim	
REMARKS :			DATE	11-Feb-16		
			SHEET	1 of 3		

Form CMBSTNb Combustion Calculations

COMBUSTION PRODUCTS												
30	from Input Data Sheet		31	Theo Air Flow kg/100kg Fuel [30] x K	32	Dry Prod Flow Mol/100 kg Fuel [30] / K	33	Wet Prod Flow Mol/100 kg Fuel [30] / K	34	H2O Fuel kg/100 kJ [30] x K / ([1]) / 100		
	Ultimate Analysis % Mass											
	A	C										
A	C	59.26										
B	UBC		0.217									
C	Cb	59.04		11.51	679.59	12.0110	4.916					
D	S	0.42			4.31	1.81	32.0640	0.013				
E	H ₂	3.71			34.29	127.22			2.0159	1.840		
F	H ₂ O	18.98							18.0153	1.054		
G	H ₂ Ov	0.00							18.0153	0.000		
H	N ₂	0.95				28.0134	0.034					
I	O ₂	11.02			-4.32	-47.61						
J	ASH	5.66										
K	VM	33.00										
L	FC	42.36										
M	TOTAL	100.00	31	761.01	32		4.963	33	2.894	34	0.221	
35	Total Theo Air Fuel Check, kg/100 kJ	([31M] + [30B] x 11.51) / ([1] / 100)								3.233		
CORRECTIONS FOR SORBENT REACTIONS AND SULFUR CAPTURE												
40	CO ₂ from Sorb, kg/100 kg fuel	[21] x [25]								0.000		
41	H ₂ O from Sorb, kg/100 kg fuel	[22] x [25]								0.000		
42	SO ₂ Reduction, Mol/100 kg fuel	[32D] x [23]								0.000		
43	Dry Prod Comb, Mol/100 kg fuel	[32M] + [40] / 44.01 - [42]								4.963		
44	Wet Prod Comb, Mol/100 kg fuel	[33M] + [41] / 18.0153 + [43]								7.857		
46	Theo Air Corr, kg/100 kg fuel	[31M] + 2.16 x [30D] x [23]								761.01		
47	Theo Air Corr, Mol/100 kg fuel	[46] / 28.9625								26.276		
48	Theo Air Corr, kg/100 kJ	[46] / ([1] / 100)								3.223		
49	Wet Gas from Fuel, kg/100 kJ	(100 - [30J] - [30B] - [30D] x [23]) / ([1] / 100)								0.399		
LOCATION										AH In	AH Out	
50	Flue Gas Temperature Entering Air heater °C									363.5	139.7	
51	Air Temperature Leaving Air Heater, °C									23.36	329.9	
52	Flue Gas Oxygen Content, %									3.410	6.690	
FLUE GAS ANALYSIS, Mol/100 kg Fuel												
53	Moisture in Air	0		[7] x 1.608				0.00		0.00		
54	Dry/Wet Products Comb	[43]		[44]				4.963		4.963		
55	Additional Moisture	0		[13] / 18.0153				0.00		0.00		
56	[47] x (0.7905 + [53])									20.77	20.77	
57	Summation	[54] + [55] + [56]								25.73	25.73	
58	20.95 - [52] x (1 + [53])									17.54	14.26	
60	Excess Air, %	100 x [52] x [57] / [47] / [58]								19.04	45.95	
PLANT NAME : NORGENER ASME PTC 4 MASTER FORM											UNIT NO.	2
TEST NO :	2	DATE :	16-Dec-15		LOAD		95%					
TIME START :	9:00	TIME END :	11:00		CALC BY		R. Tim					
REMARKS :					DATE		11-Feb-16					
SHEET 2 of 3												

Form CMBSTNc Combustion Calculations

LOCATION						AH In	AH Out
60 Excess Air, %						19.04	45.95
02, CO2, SO2, WHEN EXCESS AIR KNOWN							
61							
62 Dry	[47] x (0.7905 + ([60] / 100))					25.77	32.84
63 Wet	[47] x (0.7905 + [53] + (1 + [53]) x [60] / 100)					25.77	32.84
64 Dry Gas, Mol/100 kg Fuel	[43] + [62]					30.74	37.81
65 Wet Gas, Mol/100 kg Fuel	[44] + [63] + [13] / 18.015					33.63	40.70
		Dry	Wet				
66 O2, %	[60] x [47] x 0.2095 / [65]	[64]	[65]			3.12	6.21
67 CO2,%	([30c]/0.1201+[40]/0.4401)/[65]	[64]	[65]			14.62	12.08
68 SO2,ppm	(1-[23]) x [30D] / 0.32064 / [65]	[64]	[65]			389.5	321.8
FLUE GAS PRODUCTS, kg/100 kJ							
69 Dry Air	(1 + [60] / 100) x [48]					3.836	4.703
70 Wet Gas from Fuel	[49]					0.399	0.399
71 CO2 from Sorbent	[40] / ([1] / 100)					0.000	0.000
72 Moisture in Air	[7] x [69]					0.043	0.052
73 Water from Sorbent	[41] / ([1] / 100)					0.000	0.000
74 Additional Moisture	[14]					0.000	0.000
75 Total Wet Gas	[69] + [70] + [71] + [72] + [73] + [74]					4.277	5.154
76 H2O in Wet Gas	[34M] + [72] + [73] + [74]					0.263	0.273
77 Dry Gas	[75] - [76]					4.014	4.881
78 H2O in Wet Gas, % Mass	100 x [76] / [75]					6.16	5.30
79 Residue, kg/kg Total Refuse at each location						0.00	0.00
80 Residue, kg/100 kJ	([30J] + [2] + [24]) / ([1] / 100)					0.0249	0.0249
81 Residue in Wet Gas, kg/kg	[79] x [80] / [75] Wet Gas					0.000	0.000
82 Leakage, % Gas Entering	100 x ([75L] - [75E]) / [75E]						20.50
GAS TEMPERATURE CORRECTION FOR AH LEAKAGE							
83 Gas Temp Lvg (INCL LKG), °C	[15]					363.53	139.71
84 Average AH Air Leakage Temp, °C	([16B] x [18B] + [16A] x [18D]) / 100					23.36	329.88
85 H Air Lvg, kJ/kg	T=[83], H2O=[7]						116.82
86 H Air Ent, kJ/kg	T=[84], H2O=[7]					-1.663	
87 Cpg, kJ/kg°C	T=[83], H2O=[78E], RES=[81E]						1.060
88 AH Gas Outlet Temperature Excluding Leakage, °C	[83] + ([82] / 100 x ([85] - [86]) / [87])						162.61
AIR, GAS, FUEL & RESIDUE MASS FLOW RATES, kg/hr							
90 Input from Fuel, MJ/hr	[5] / [6] x 100						1234134
91 Fuel Rate, kg/hr	1000 x [90] / [1]						52263
92 Residue Rate, kg/hr	[80] x [90] / 10						3071
93 Wet Flue Gas, kg/hr	[75] x [90] / 10					527892	636092
95 Excess Air Lvg Blr, %	[60]						45.95
96 Total Air to Blr, kg/hr	(1 + [95] / 100) x (1 + [7]) x [48] x [90] / 10						586901
PLANT NAME : NORGENER ASME PTC 4 MASTER FORM				UNIT NO.	2		
TEST NO :	2	DATE :	16-Dec-15	LOAD	95%		
TIME START :	9:00	TIME END :	11:00	CALC BY	R. Tim		
REMARKS :				DATE	11-Feb-16		
				SHEET 3 of 3			

Form RES Unburned Carbon and Residue Calculation

DATA REQUIRED FOR RESIDUE SPLIT												
1	Ash in Fuel, %		from Form CMBSTNb [30J]		5.66	2	HHV Fuel, kJ/kg 'as fired'			23614		
3	Fuel Mass Flow Rate, kg/hr		from Form CMBSTNa [4b]		52263	4b	from Form CMBSTNa [1]					
a)	Item [3] - Use measured or estimated value initially. (See CMBSTNa) Recalculate after boiler efficiency has been calculated until estimated value is within 1% of calculated value.											
b)	Residue splits estimated. Enter value in Col [8] and calculate Col [5]. Residue rate measured. Enter measured mass flow rates in Col [5]. When residue is not measured at all locations, estimate split and flow for measured locations. Reiterate until estimated total residue is within 2% of calculated.											
c)	Enter the % free carbon in Col [6] (total carbon corrector for CO2). Units with sorbent: Enter the % CO2 in Col [7].											
Location	5	Residue Mass Flow	6	C in Residue %	7	CO2 in Residue %	8	Residue Split %	9	10		
	Input kg/hr	Calculated kg/hr					Input	Calculated 100 x [5]/[5F]	C Wtd Ave % [6] x [8]/100	CO2 Wtd Ave % [7] x [8]/100		
A Bottom Ash	0.00	0.00	4.83	5.00		15.00	0.00	0.725		0.750		
B Fly Ash	0.00	0.00	3.49	2.00		85.00	0.00	2.967		1.700		
C Economizer	0.00	0.00	0.00	0.00		0.00	0.00	0.000		0.000		
D	0.00	0.00	0.00	0.00		0.00	0.00	0.000		0.000		
E	0.00	0.00	0.00	0.00		0.00	0.00	0.000		0.000		
F TOTAL	5	0.00	0.00			8	100.0	0.00	9	3.691	10	2.450
UNITS WITHOUT SORBENT												
11	Unburned Carbon, kg/ 100 kg Fuel				[1] x [9F] / (100 - [9F])					0.217		
20	Total Residue, kg/ 100kg Fuel				[1] + [11]					5.88		
UNITS WITH SORBENT												
d)	Enter average C and CO2 in residue, [9F] and [10F] above or SRBa (Items [4] and [5]) and complete Sorbent Calculation Forms.											
11	Unburned Carbon, kg/ 100 kg Fuel				from Form SRBb Item [49]					0.257		
20	Total Residue, kg/ 100 Fuel				from Form SRBb Item [50]					6.97		
TOTAL RESIDUE												
21	Total Residue, kg/hr				[20] x [3] /100					3071		
e)	When all residue collection locations are measured, the measured residue split is used for calculations. If a portion of the residue mass is estimated, repeat calculation above until Col [5F] and Item [21] agree within 2%.											
22	Total Residue, kg/100 J				100 x [20] / [2]					0.025		
23	SENSIBLE HEAT RESIDUE LOSS, %											
Location	24	Temp Residue (°C)	[8] %	x	[22] Residue kg/100 kJ	x	H Residue kJ/kg	/ 10,000	Loss %			
A Furnace		1100		x	0.025	x	1205.2	/ 10,000	0.045			
B Fly Ash		120		x	0.025	x	76.7	/ 10,000	0.016			
C Economizer		0		x	0.025	x	-30.1	/ 10,000	0.000			
D		0							0.000			
E		0							0.000			
								Total	25	0.061		
H Residue = 0.16 x T + 1.09E-4 x T^2 - 2.843E-8 x T^3 - 12.95												
PLANT NAME : NORGENER ASME PTC 4 MASTER FORM					UNIT NO.			2				
TEST NO :	2	DATE:	16-Dec-15		LOAD			95%				
TIME START :	9:00	TIME END :	11:00		CALC BY			R. Tim				
REMARKS :					DATE			11-Feb-16				
					SHEET 1 of 1							

**Form EFFa Efficiency Calculations
Data**

TEMPERATURES, °C																									
1	Reference Temperature, °C	25.0	1A	Enthalpy Water (0°C Ref), kJ/kg	104.57																				
2	Average Entering Air Temp, from CMBSTNa Item [84]: $([16B]x[18B]+[16A]x[18D])/100$	23.36	2A	Enthalpy Dry Air, kJ/kg	-1.65																				
3	Average Exit Gas T (Excl Lkg) from CMBSTNa [88]	162.6	3A	Enthalpy Dry Gas, kJ/kg	137.79																				
			3B	Enthalpy Steam @ 1 psia, kJ/kg	2804.6																				
			3C	Enthalpy Water Vapor, kJ/kg	259.98																				
4	Fuel Temperature	21.5	4A	Enthalpy Fuel, kJ/kg	-4.81																				
HOT AIR QUALITY CONTROL EQUIPMENT																									
5	Entering Gas Temperature	0.0	5A	Enthalpy Wet Gas	0.00																				
6	Leaving Gas Temperature	0.0	6A	Enthalpy of Wet Gas	0.00																				
			6B	Enthalpy of Wet Air	0.00																				
			6C	Enthalpy of Wet Air @ T = [3]	0.00																				
RESULTS FROM COMBUSTION CALCULATION FORM CMBSTN																									
10	Dry Gas Weight, kg/100 kJ [77]	4.014	18	Unburned Carbon, % [2]	0.217																				
11	Dry Air Weight [69]	3.836	19	HHV kJ/kg 'as-fired' [1]	23614.0																				
12	Water from H ₂ Fuel [34E]	0.140	HOT AQC EQUIPMENT																						
13	Water from H ₂ O Fuel [34F]	0.080	20	Wet Gas Entering [75E]	0.00																				
14	Water from H ₂ Ov Fuel [34G]	0.000	21	H ₂ O in Wet Gas, % [78E]	0.00																				
15	Moisture in Air kg/kg DA [7]	0.01109	22	Wet Gas Leaving [75L]	0.00																				
16	Moisture in Air kg/100 kJ [72]	0.043	23	Residue in Wet Gas, % [81E]	0.00																				
17	Fuel Rate Est. kg/hr [3]	52263	25	Excess Air, % [95]	45.95																				
MISCELLANEOUS																									
30	Unit Output, MJ/hr	1083841	31	Aux Equip Power, MJ/hr	4079																				
32	Loss Due to Surface Radiation and Convection, %				0.25																				
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>PLANT NAME :</td> <td>ASME PTC 4 MASTER FORM</td> <td>UNIT NO.</td> <td>2</td> </tr> <tr> <td>TEST NO :</td> <td>DATE :</td> <td>LOAD</td> <td>95%</td> </tr> <tr> <td>TIME START :</td> <td>TIME END :</td> <td>CALC BY</td> <td>R. Tim</td> </tr> <tr> <td>REMARKS :</td> <td></td> <td>DATE</td> <td>11-Feb-16</td> </tr> <tr> <td></td> <td></td> <td colspan="2">SHEET 1 of 3</td> </tr> </table>						PLANT NAME :	ASME PTC 4 MASTER FORM	UNIT NO.	2	TEST NO :	DATE :	LOAD	95%	TIME START :	TIME END :	CALC BY	R. Tim	REMARKS :		DATE	11-Feb-16			SHEET 1 of 3	
PLANT NAME :	ASME PTC 4 MASTER FORM	UNIT NO.	2																						
TEST NO :	DATE :	LOAD	95%																						
TIME START :	TIME END :	CALC BY	R. Tim																						
REMARKS :		DATE	11-Feb-16																						
		SHEET 1 of 3																							

Form EFFb Efficiency Calculations

LOSSES, % Enter Calculated Result in % Column [B]			A	MKB	B	%
60 Dry Gas	[10] x [3A] x /100					5.531
61 Water from H2 Fuel	[12] x ([3B] - [1A]) / 100 x - 104.57) / 100					3.791
62 Water from H2O Fuel	[13] x ([3B] - [1A]) / 100 x - 104.57) / 100					2.170
63 Water from H2O Fuel	[14] x ([3C]) / 100 x / 100					0.000
64 Moisture in Air	[16] x [3C] / 100 x / 100					0.111
65 Unburned Carbon in Ref [18] x 33700 / [19] =	x 33700/					0.310
66 Sensible Heat of Refuse from Form RES						0.061
67 Hot AQC Equip ([20] x ([5A] - [6A]) - ([22] - [20]) x ([6C] - [6B])) / 100 (-) - (-) x (-)) / 100						0.000
68 Other Losses, % Basis from Form EFFc Item [110]						0.450
69 Summation of Losses, % Basis						12.424
LOSSES, MJ/hr Enter in MKB Column [A]						
75 Surface Radiation and Convection from Form EFFa Item [32]					0.000	
76 Sorbent Calcination / Dehydration from Form SRBc Item [77]					0.000	
77 Water from Sorbent from Form SRBc Item [65]					0.000	
80 Other Losses, MJ/hr Basis from Form EFFc Item [111]					0.000	
81 Summation of Losses, MJ/hr Basis					0.000	
CREDITS, % Enter Calculation Result in % Column [B]						
85 Entering Dry Air	[11] x [2A] /100 x /100					-0.063
86 Moisture in Air	[16] x [2B] /100 x /100					-0.001
87 Sensible Heat in Fuel	100 x [4A] / [19] 100 x /					-0.020
88 Sulfation from Form SRBc Item [80]						0.000
89 Other Credits, % Basis from Form EFFc Item [112]						0.000
90 Summation of Credits, % Basis						-0.085
CREDITS, MJ/hr Enter Calculated Result in MKB Column [A]						
95 Auxiliary Equipment Power [31]				4078.8		
96 Sensible Heat from Sorbent from Form SRBc Item [85]				0.000		
97 Other Credits, MJ/hr Basis from Form EFFc Item [113B]				0.000		
98 Summation of Credits, MJ/hr Basis				4078.8		
100 Fuel Eff, % (100 - [69] + [90]) x [30] / ([30] + [81] - [98]) (100 - +) x / (+ -)						87.82
101 Input from Fuel, MJ/hr 100 x [30] / [100] = 100 x /				1234133		
102 Fuel Rate, kg/hr 1.000 x [101] / [19] = 1.000 x /						52263
PLANT NAME : NORGENER	ASME PTC 4 MASTER FORM	UNIT NO.	2			
TEST NO : 2	DATE : 16-Dec-15	LOAD	95%			
TIME START : 9:00	TIME END : 11:00	CALC BY	R. Tim			
REMARKS :		DATE	11-Feb-16			
		SHEET 2 of 3				

Form EFFc Efficiency Calculations
Other Losses and Credits

The losses and credits listed on this sheet are not universally applicable to all fossil fired steam generators and are usually minor. Losses/credits that have not been specifically identified by this Code but are applicable in accordance with the intent of the Code should also be recorded on this sheet.

Parties to the test may agree to estimate the losses or credits in lieu of testing. Enter a 'T' for tested or 'E' for estimate in the second column, and result in the appropriate column.

Enter the sum of each group on Form EFFb.

Refer to the text of PTC 4 for the calculation method.

Item	T or E	LOSSES, % Enter Calculated Result in % Column [B]	A	MKB	B	%
110A		CO in Flue Gas				0.000
110B		Formation of NOx				0.000
110C		Pulverizer Rejects				0.000
110D		Air Infiltration				0.000
110E		Unburned Hydrocarbons in Flue Gas				0.000
110F		Unburned Hydrogen in Refuse				0.000
110G	E	Unmeasured Loss, as per agreement				0.200
110H	E	Surface Radiation Loss, as per agreement				0.250
110		Summation of Other Losses, % Basis				0.450
LOSSES, MJ/hr Enter in MKB Column [A]						
111A		Wet Ash Pit				0.000
111B		Sensible Heat in Recycle Streams, Solid				0.000
111C		Sensible Heat in Recycle Streams, Gas				0.000
111D		Additional Moisture				0.000
111E		Cooling Water				0.000
111F		Air Preheater Coil (supplied by Unit)				0.000
111G		Other				0.000
111		Summation of other Losses, MJ/hr Basis				0.000
CREDITS, % Enter Calculation Result in % Column [B]						
112A		Other				0.000
112		Summation of Credits, % Basis				0.000
CREDITS, MJ/hr Enter Result in MKB Column [A]						
113A		Heat in Additional Moisture (external to envelope)				0.000
113B		Other				0.000
113C		Heat by Auxiliary Equipment Power				4078.8
113		Summation of Credits, MJ/hr Basis				4078.8
PLANT NAME : NORGENER ASME PTC 4 MASTER FORM UNIT NO. 2						
TEST NO :	2	DATE :	16-Dec-15	LOAD	95%	
TIME START :	9:00	TIME END :	11:00	CALC BY	R. Tim	
REMARKS :				DATE	11-Feb-16	
SHEET 3 of 3						

APPENDIX G3

Results ASME PTC 4 Heat Balance Method Test at 90% Load

Form CMBSTNa Combustion Calculations

DATA REQUIRED					
1	HHV - Higher Heating value of Fuel, kJ/kg as fired, from Input Data Sheet [1]				23542
2	UBC - Unburned Carbon, kg/ 100 kg fuel from RES [11] or SRBb FORM				0.153
3	Fuel Flow, kg/hr [4b]				49881
4	a. Measured Fuel Flow				44964.0
4	b. Calculated Fuel Flow $100,000 \times [5] / [6] / [1]$				49881.3
5	Output, MJ/hr from Output Item [37]				1031710
6	Fuel Efficiency, % (estimate initially), from Input Data Sheet [6]				87.86
7	Moisture in air, kg/kg Dry Air				0.01012
8	Barometric Pressure, mbar, from Input Data Sheet [8]				1008.2
9	Dry Bulb Temperature, °C, from Input Data Sheet [9]				21.2
10	Wet Bulb Temperature, °C, from Input Data Sheet [10]				16.8
11	Relative Humidity, %, from Input Data Sheet [11]				64.0
	Additional Moisture (Measured)	kg/hr			
	Atomizing Steam	from Output Item [14]	kg/hr		0.0
	Sootblowing Steam	from Output Item [11]	kg/hr		0.0
	Other		kg/hr		0.0
12	Summation Addition Moisture				0.0
13	Additional Moisture.kg/ 100 kg Fuel $100 \times [12] / [3]$				0.0
14	Additional Moisture, kg/100 kJ $[13] / ([1] / 100)$				0.0
	If Air Heater (Excl Stm/ Wtr Coil) Enter following				
15	Gas Temp Lvg AH, °C, from Input Data Sheet [15]	Primairy / Secundairy or Main		15A	143.1
16	Air Temp Ent AH, °C, from Input Data Sheet [16]	Primairy / Secundairy or Main	16B	26.4	16A 27.0
17	O2 in FG Ent Air Heater, %, from Input Data Sheet [17]	Primairy / Secundairy or Main		17A	3.54
18	O2 in FG Lvg Air Heater, %, from Input Data Sheet [18]	Primairy / Secundairy or Main		18A	6.73
18a	Mass Flow Fraction, %, from Input Data Sheet [18a]	Primairy / Secundairy or Main	18C	66.26	18D 33.74
19	Mass Ash, kg/100 kJ $100 \times [30j] / [1]$				0.024
	If mass of ash (item [19]) exceeds 0.065 kg/100 kJ or Sorbent utilized, Enter Mass Fraction of Refuse in Col [79] for each location				
	SORBENT DATA (Enter 0 if Sorbent not Used)				0
20	Sorbent Rate, kg/hr				0.000
21	CO2 from Sorbent, kg/ 100 kg Sorbent	from SRBa item [25I]			0.000
22	H2O from Sorbent, kg/ 100 kg Sorbent	from SRBa item [26I]			0.000
23	Sulfur Capture, kg/kg Sulfer	from SRBb item [45]			0.000
24	Spent Sorbent, kg/ 100 kg fuel	from SRBb item [48]			0.000
25	Sorb/Fuel Ratio, kg Sorb / kg Fuel	[20]/[3]			0.000
	HOT AIR QUALITY CONTROL EQUIPMENT DATA				
26	O2 in FG Ent HAQC Flue Gas Temperatures				N/A
	See Form EFFa for HAQC Flue Gas Temperatures				
PLANT NAME : NORGNER ASME PTC 4 MASTER FORM			UNIT NO.	2	
TEST NO :	3	DATE :	16-Dec-15	LOAD	90%
TIME START :	12:45	TIME END :	14:45	CALC BY	R. Tim
REMARKS :				DATE	11-Feb-16
				SHEET 1 of 3	

Form CMBSTNb Combustion Calculations

COMBUSTION PRODUCTS																
30	from Input Data Sheet		31	Theo Air Flow kg/100kg Fuel [30] x K	32	Dry Prod Flow Mol/100 kg Fuel [30] / K	33	Wet Prod Flow Mol/100 kg Fuel [30] / K	34	H2O Fuel kg/100 kJ [30] x K / ([1]) / 100						
	Ultimate Analysis															
	% Mass															
A	C	59.24														
B	UBC		0.153													
C	Cb	59.09		11.51	680.09	12.0110	4.919									
D	S	0.46			4.31	1.98	32.0640	0.014								
E	H2	3.71			34.29	127.22			2.0159							
F	H2O	18.97							18.0153							
G	H2Ov	0.00							1.053							
H	N2	0.94				28.0134	0.034		8.937							
I	O2	10.98			-4.32	-47.43			0.141							
J	ASH	5.70							1.0							
K	VM	32.82							0.081							
L	FC	42.51							0.000							
M	TOTAL	100.00		31	761.85	32	4.967	33	2.893							
								34	0.221							
35	Total Theo Air Fuel Check, kg/100 kJ		([31M] + [30B] x 11.51) / ([1] / 100)						3.244							
CORRECTIONS FOR SORBENT REACTIONS AND SULFUR CAPTURE																
40	CO2 from Sorb, kg/100 kg fuel		[21] x [25]						0.000							
41	H2O from Sorb, kg/100 kg fuel		[22] x [25]						0.000							
42	SO2 Reduction, Mol/100 kg fuel		[32D] x [23]						0.000							
43	Dry Prod Comb, Mol/100 kg fuel		[32M] + [40] / 44.01 - [42]						4.967							
44	Wet Prod Comb, Mol/100 kg fuel		[33M] + [41] / 18.0153 + [43]						7.861							
46	Theo Air Corr, kg/100 kg fuel		[31M] + 2.16 x [30D] x [23]						761.85							
47	Theo Air Corr, Mol/100 kg fuel		[46] / 28.9625						26.305							
48	Theo Air Corr, kg/100 kJ		[46] / ([1] / 100)						3.236							
49	Wet Gas from Fuel, kg/100 kJ		(100 - [30J] - [30B] - [30D] x [23]) / ([1] / 100)						0.400							
LOCATION																
50	Flue Gas Temperature Entering Air heater °C								360.3							
51	Air Temperature Leaving Air Heater, °C								26.62							
52	Flue Gas Oxygen Content, %								3.540							
FLUE GAS ANALYSIS, Mol/100 kg Fuel																
53	Moisture in Air		Dry		Wet											
			0		[7] x 1.608			0.00	0.00							
54	Dry/Wet Products Comb		[43]		[44]				4.967							
55	Additional Moisture		0		[13] / 18.0153				4.967							
56			[47] x (0.7905 + [53])						20.79							
57	Summation		[54] + [55] + [56]						25.76							
58			20.95 - [52] x (1 + [53])						17.41							
60	Excess Air, %		100 x [52] x [57] / [47] / [58]						14.22							
								19.91	46.35							
PLANT NAME : NORGENER ASME PTC 4 MASTER FORM																
TEST NO :	3	DATE :	16-Dec-15						UNIT NO.							
									2							
TIME START :	12:45	TIME END :	14:45						LOAD							
									90%							
REMARKS :							CALC BY	R. Tim								
								DATE	11-Feb-16							
									SHEET 2 of 3							

Form CMBSTNc Combustion Calculations

LOCATION						AH In	AH Out
60 Excess Air, %						19.91	46.35
02, CO2, SO2, WHEN EXCESS AIR KNOWN							
61							
62 Dry	[47] x (0.7905 + ([60] / 100))					26.03	32.99
63 Wet	[47] x (0.7905 + [53] + (1 + [53]) x [60] / 100)					26.03	32.99
64 Dry Gas, Mol/100 kg Fuel	[43] + [62]					31.00	37.95
65 Wet Gas, Mol/100 kg Fuel	[44] + [63] + [13] / 18.015					33.89	40.85
		Dry	Wet				
66 O2, %	[60] x [47] x 0.2095 / [65]	[64]	[65]			3.24	6.25
67 CO2,%	([30c]/0.1201+[40]/0.4401)/[65]	[64]	[65]			14.52	12.04
68 SO2,ppm	(1-[23]) x [30D] / 0.32064 / [65]	[64]	[65]			423.3	351.2
FLUE GAS PRODUCTS, kg/100 kJ							
69 Dry Air	(1 + [60] / 100) x [48]					3.881	4.736
70 Wet Gas from Fuel	[49]					0.400	0.400
71 CO2 from Sorbent	[40] / ([1] / 100)					0.000	0.000
72 Moisture in Air	[7] x [69]					0.039	0.048
73 Water from Sorbent	[41] / ([1] / 100)					0.000	0.000
74 Additional Moisture	[14]					0.000	0.000
75 Total Wet Gas	[69] + [70] + [71] + [72] + [73] + [74]					4.320	5.184
76 H2O in Wet Gas	[34M] + [72] + [73] + [74]					0.261	0.269
77 Dry Gas	[75] - [76]					4.059	4.915
78 H2O in Wet Gas, % Mass	100 x [76] / [75]					6.03	5.20
79 Residue, kg/kg Total Refuse at each location						0.00	0.00
80 Residue, kg/100 kJ	([30J] + [2] + [24]) / ([1] / 100)					0.0249	0.0249
81 Residue in Wet Gas, kg/kg	[79] x [80] / [75] Wet Gas					0.000	0.000
82 Leakage, % Gas Entering	100 x ([75L] - [75E]) / [75E]						20.01
GAS TEMPERATURE CORRECTION FOR AH LEAKAGE							
83 Gas Temp Lvg (INCL LKG), °C	[15]					360.33	143.06
84 Average AH Air Leakage Temp, °C	([16B] x [18B] + [16A] x [18D]) / 100					26.62	329.04
85 H Air Lvg, kJ/kg	T=[83], H2O=[7]						120.15
86 H Air Ent, kJ/kg	T=[84], H2O=[7]					1.644	
87 Cpg, kJ/kg°C	T=[83], H2O=[78E], RES=[81E]						1.060
88 AH Gas Outlet Temperature Excluding Leakage, °C	[83] + ([82] / 100 x ([85] - [86]) / [87])						165.42
AIR, GAS, FUEL & RESIDUE MASS FLOW RATES, kg/hr							
90 Input from Fuel, MJ/hr	[5] / [6] x 100						1174306
91 Fuel Rate, kg/hr	1000 x [90] / [1]						49881
92 Residue Rate, kg/hr	[80] x [90] / 10						2920
93 Wet Flue Gas, kg/hr	[75] x [90] / 10					507270	608753
95 Excess Air Lvg Blr, %	[60]						46.35
96 Total Air to Blr, kg/hr	(1 + [95] / 100) x (1 + [7]) x [48] x [90] / 10						561791
PLANT NAME : NORGENER ASME PTC 4 MASTER FORM				UNIT NO.	2		
TEST NO :	3	DATE :	16-Dec-15	LOAD	90%		
TIME START :	12:45	TIME END :	14:45	CALC BY	R. Tim		
REMARKS :				DATE	11-Feb-16		
				SHEET 3 of 3			

Form RES Unburned Carbon and Residue Calculation

DATA REQUIRED FOR RESIDUE SPLIT												
1	Ash in Fuel, %	from Form CMBSTNb [30J]			5.70	2	HHV Fuel, kJ/kg 'as fired'			23542		
3	Fuel Mass Flow Rate, kg/hr	from Form CMBSTNa [4b]			49881	4b	from Form CMBSTNa [1]					
a)	Item [3] - Use measured or estimated value initially. (See CMBSTNa) Recalculate after boiler efficiency has been calculated until estimated value is within 1% of calculated value.											
b)	Residue splits estimated. Enter value in Col [8] and calculate Col [5]. Residue rate measured. Enter measured mass flow rates in Col [5]. When residue is not measured at all locations, estimate split and flow for measured locations. Reiterate until estimated total residue is within 2% of calculated.											
c)	Enter the % free carbon in Col [6] (total carbon corrector for CO2). Units with sorbent: Enter the % CO2 in Col [7].											
Location	5	Residue Mass Flow	6	C in Residue %	7	CO2 in Residue %	8	Residue Split %	9	10		
	Input kg/hr	Calculated kg/hr					Input	Calculated 100 x [5]/[5F]	C Wtd Ave % [6] x [8]/100	CO2 Wtd Ave % [7] x [8]/100		
A Bottom Ash	0.00	0.00	4.41	5.00		15.00	0.00	0.662		0.750		
B Fly Ash	0.00	0.00	2.30	2.00		85.00	0.00	1.955		1.700		
C Economizer	0.00	0.00	0.00	0.00		0.00	0.00	0.000		0.000		
D	0.00	0.00	0.00	0.00		0.00	0.00	0.000		0.000		
E	0.00	0.00	0.00	0.00		0.00	0.00	0.000		0.000		
F TOTAL	5	0.00	0.00			8	100.0	0.00	9	2.617	10	2.450
UNITS WITHOUT SORBENT												
11	Unburned Carbon, kg/ 100 kg Fuel				[1] x [9F] / (100 - [9F])					0.153		
20	Total Residue, kg/ 100kg Fuel				[1] + [11]					5.85		
UNITS WITH SORBENT												
d)	Enter average C and CO2 in residue, [9F] and [10F] above or SRBa (Items [4] and [5]) and complete Sorbent Calculation Forms.											
11	Unburned Carbon, kg/ 100 kg Fuel				from Form SRBb Item [49]					0.184		
20	Total Residue, kg/ 100 Fuel				from Form SRBb Item [50]					7.03		
TOTAL RESIDUE												
21	Total Residue, kg/hr				[20] x [3] /100					2920		
e)	When all residue collection locations are measured, the measured residue split is used for calculations. If a portion of the residue mass is estimated, repeat calculation above until Col [5F] and Item [21] agree within 2%.											
22	Total Residue, kg/100 J				100 x [20] / [2]					0.025		
23	SENSIBLE HEAT RESIDUE LOSS, %											
Location	24	Temp Residue (°C)	[8] %	x	[22] Residue kg/100 kJ	x	H Residue kJ/kg	/ 10,000	Loss %			
	A Furnace	1100			15.00	x	0.025	x	1205.2	/ 10,000	0.045	
B Fly Ash	120			85.00	x	0.025	x	76.7	/ 10,000	0.016		
C Economizer	0			0.00	x	0.025	x	-30.1	/ 10,000	0.000		
D	0									0.000		
E	0									0.000		
								Total	25	0.061		
H Residue = 0.16 x T + 1.09E-4 x T^2 - 2.843E-8 x T^3 - 12.95												
PLANT NAME : NORGENER ASME PTC 4 MASTER FORM					UNIT NO.			2				
TEST NO :	3	DATE:	16-Dec-15			LOAD	90%					
TIME START :	12:45	TIME END :	14:45			CALC BY	R. Tim					
REMARKS :						DATE	11-Feb-16					
						SHEET 1 of 1						

**Form EFFa Efficiency Calculations
Data**

TEMPERATURES, °C																									
1	Reference Temperature, °C	25.0	1A	Enthalpy Water (0°C Ref), kJ/kg	104.57																				
2	Average Entering Air Temp, from CMBSTNa Item [84]: $([16B]x[18B]+[16A]x[18D])/100$	26.62	2A	Enthalpy Dry Air, kJ/kg	1.63																				
3	Average Exit Gas T (Excl Lkg) from CMBSTNa [88]	165.4	3A	Enthalpy Dry Gas, kJ/kg	140.65																				
			3B	Enthalpy Steam @ 1 psia, kJ/kg	2809.9																				
			3C	Enthalpy Water Vapor, kJ/kg	265.38																				
4	Fuel Temperature	21.2	4A	Enthalpy Fuel, kJ/kg	-5.16																				
HOT AIR QUALITY CONTROL EQUIPMENT																									
5	Entering Gas Temperature	0.0	5A	Enthalpy Wet Gas	0.00																				
6	Leaving Gas Temperature	0.0	6A	Enthalpy of Wet Gas	0.00																				
			6B	Enthalpy of Wet Air	0.00																				
			6C	Enthalpy of Wet Air @ T = [3]	0.00																				
RESULTS FROM COMBUSTION CALCULATION FORM CMBSTN																									
10	Dry Gas Weight, kg/100 kJ [77]	4.059	18	Unburned Carbon, % [2]	0.153																				
11	Dry Air Weight [69]	3.881	19	HHV kJ/kg 'as-fired' [1]	23542.0																				
12	Water from H ₂ Fuel [34E]	0.141	HOT AQC EQUIPMENT																						
13	Water from H ₂ O Fuel [34F]	0.081	20	Wet Gas Entering [75E]	0.00																				
14	Water from H ₂ Ov Fuel [34G]	0.000	21	H ₂ O in Wet Gas, % [78E]	0.00																				
15	Moisture in Air kg/kg DA [7]	0.01012	22	Wet Gas Leaving [75L]	0.00																				
16	Moisture in Air kg/100 kJ [72]	0.039	23	Residue in Wet Gas, % [81E]	0.00																				
17	Fuel Rate Est. kg/hr [3]	49881	25	Excess Air, % [95]	46.35																				
MISCELLANEOUS																									
30	Unit Output, MJ/hr	1031710	31	Aux Equip Power, MJ/hr	4097																				
32	Loss Due to Surface Radiation and Convection, %				0.25																				
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>PLANT NAME :</td> <td>ASME PTC 4 MASTER FORM</td> <td>UNIT NO.</td> <td>2</td> </tr> <tr> <td>TEST NO :</td> <td>DATE :</td> <td>LOAD</td> <td>90%</td> </tr> <tr> <td>TIME START :</td> <td>TIME END :</td> <td>CALC BY</td> <td>R. Tim</td> </tr> <tr> <td>REMARKS :</td> <td></td> <td>DATE</td> <td>11-Feb-16</td> </tr> <tr> <td></td> <td></td> <td colspan="2">SHEET 1 of 3</td> </tr> </table>						PLANT NAME :	ASME PTC 4 MASTER FORM	UNIT NO.	2	TEST NO :	DATE :	LOAD	90%	TIME START :	TIME END :	CALC BY	R. Tim	REMARKS :		DATE	11-Feb-16			SHEET 1 of 3	
PLANT NAME :	ASME PTC 4 MASTER FORM	UNIT NO.	2																						
TEST NO :	DATE :	LOAD	90%																						
TIME START :	TIME END :	CALC BY	R. Tim																						
REMARKS :		DATE	11-Feb-16																						
		SHEET 1 of 3																							

Form EFFb Efficiency Calculations

LOSSES, % Enter Calculated Result in % Column [B]			A	MKB	B	%
60 Dry Gas	[10] x [3A] x /100					5.709
61 Water from H2 Fuel	[12] x ([3B] - [1A]) / 100 x - 104.57) / 100					3.810
62 Water from H2O Fuel	[13] x ([3B] - [1A]) / 100 x - 104.57) / 100					2.180
63 Water from H2O Fuel	[14] x ([3C]) / 100 x / 100					0.000
64 Moisture in Air	[16] x [3C] / 100 x / 100					0.104
65 Unburned Carbon in Ref [18] x 33700 / [19] =	x 33700/					0.219
66 Sensible Heat of Refuse from Form RES						0.061
67 Hot AQC Equip ((20) x ([5A] - [6A]) - ([22] - [20]) x ([6C] - [6B])) / 100 (-) - (-) x (-)) / 100						0.000
68 Other Losses, % Basis from Form EFFc Item [110]						0.450
69 Summation of Losses, % Basis						12.534
LOSSES, MJ/hr Enter in MKB Column [A]						
75 Surface Radiation and Convection from Form EFFa Item [32]					0.000	
76 Sorbent Calcination / Dehydration from Form SRBc Item [77]					0.000	
77 Water from Sorbent from Form SRBc Item [65]					0.000	
80 Other Losses, MJ/hr Basis from Form EFFc Item [111]					0.000	
81 Summation of Losses, MJ/hr Basis					0.000	
CREDITS, % Enter Calculation Result in % Column [B]						
85 Entering Dry Air	[11] x [2A] /100 x /100					0.063
86 Moisture in Air	[16] x [2B] /100 x /100					0.001
87 Sensible Heat in Fuel	100 x [4A] / [19] 100 x /					-0.022
88 Sulfation from Form SRBc Item [80]						0.000
89 Other Credits, % Basis from Form EFFc Item [112]						0.000
90 Summation of Credits, % Basis						0.043
CREDITS, MJ/hr Enter Calculated Result in MKB Column [A]						
95 Auxiliary Equipment Power [31]				4096.8		
96 Sensible Heat from Sorbent from Form SRBc Item [85]				0.000		
97 Other Credits, MJ/hr Basis from Form EFFc Item [113B]				0.000		
98 Summation of Credits, MJ/hr Basis				4096.8		
100 Fuel Eff, % (100 - [69] + [90]) x [30] / ([30] + [81] - [98]) (100 - +) x / (+ -)						87.86
101 Input from Fuel, MJ/hr 100 x [30] / [100] = 100 x /				1174303		
102 Fuel Rate, kg/hr 1.000 x [101] / [19] = 1.000 x /						49881
PLANT NAME : NORGENER	ASME PTC 4 MASTER FORM	UNIT NO.	2			
TEST NO : 3	DATE : 16-Dec-15	LOAD	90%			
TIME START : 12:45	TIME END : 14:45	CALC BY	R. Tim			
REMARKS :		DATE	11-Feb-16			
		SHEET 2 of 3				

Form EFFc Efficiency Calculations
Other Losses and Credits

The losses and credits listed on this sheet are not universally applicable to all fossil fired steam generators and are usually minor. Losses/credits that have not been specifically identified by this Code but are applicable in accordance with the intent of the Code should also be recorded on this sheet.

Parties to the test may agree to estimate the losses or credits in lieu of testing. Enter a 'T' for tested or 'E' for estimate in the second column, and result in the appropriate column.

Enter the sum of each group on Form EFFb.

Refer to the text of PTC 4 for the calculation method.

Item	T or E	LOSSES, % Enter Calculated Result in % Column [B]	A	MKB	B	%
110A		CO in Flue Gas				0.000
110B		Formation of NOx				0.000
110C		Pulverizer Rejects				0.000
110D		Air Infiltration				0.000
110E		Unburned Hydrocarbons in Flue Gas				0.000
110F		Unburned Hydrogen in Refuse				0.000
110G	E	Unmeasured Loss, as per agreement				0.200
110H	E	Surface Radiation Loss, as per agreement				0.250
110		Summation of Other Losses, % Basis				0.450
<hr/>						
LOSSES, MJ/hr Enter in MKB Column [A]						
111A		Wet Ash Pit				0.000
111B		Sensible Heat in Recycle Streams, Solid				0.000
111C		Sensible Heat in Recycle Streams, Gas				0.000
111D		Additional Moisture				0.000
111E		Cooling Water				0.000
111F		Air Preheater Coil (supplied by Unit)				0.000
111G		Other				0.000
111		Summation of other Losses, MJ/hr Basis				0.000
<hr/>						
CREDITS, % Enter Calculation Result in % Column [B]						
112A		Other				0.000
112		Summation of Credits, % Basis				0.000
<hr/>						
CREDITS, MJ/hr Enter Result in MKB Column [A]						
113A		Heat in Additional Moisture (external to envelope)				0.000
113B		Other				0.000
113C		Heat by Auxiliary Equipment Power				4096.8
113		Summation of Credits, MJ/hr Basis				4096.8
<hr/> <hr/> <hr/> <hr/> <hr/> <hr/>						
PLANT NAME : NORGENER		ASME PTC 4 MASTER FORM	UNIT NO.		2	
TEST NO :	3	DATE : 16-Dec-15	LOAD		90%	
TIME START :	12:45	TIME END : 14:45	CALC BY		R. Tim	
REMARKS :			DATE		11-Feb-16	
					SHEET 3 of 3	

APPENDIX G4

Results ASME PTC 4 Heat Balance Method Test at 80% Load

Form CMBSTNa Combustion Calculations

DATA REQUIRED					
1	HHV - Higher Heating value of Fuel, kJ/kg as fired, from Input Data Sheet [1]				23777
2	UBC - Unburned Carbon, kg/ 100 kg fuel from RES [11] or SRBb FORM				0.193
3	Fuel Flow, kg/hr [4b]				43569
4	a. Measured Fuel Flow				38844.0
4	b. Calculated Fuel Flow 100,000 x [5] / [6] / [1]				43569.5
5	Output, MJ/hr from Output Item [37]				914476
6	Fuel Efficiency, % (estimate initially), from Input Data Sheet [6]				88.27
7	Moisture in air, kg/kg Dry Air				0.00951
8	Barometric Pressure, mbar, from Input Data Sheet [8]				1008.2
9	Dry Bulb Temperature, °C, from Input Data Sheet [9]				20.8
10	Wet Bulb Temperature, °C, from Input Data Sheet [10]				16.1
11	Relative Humidity, %, from Input Data Sheet [11]				61.6
	Additional Moisture (Measured)	kg/hr			
	Atomizing Steam	from Output Item [14]	kg/hr		0.0
	Sootblowing Steam	from Output Item [11]	kg/hr		0.0
	Other		kg/hr		0.0
12	Summation Addition Moisture				0.0
13	Additional Moisture.kg/ 100 kg Fuel 100 x [12] / [3]				0.0
14	Additional Moisture, kg/100 kJ [13] / ([1] / 100)				0.0
	If Air Heater (Excl Stm/ Wtr Coil) Enter following				
15	Gas Temp Lvg AH, °C, from Input Data Sheet [15]	Primairy / Secundairy or Main		15A	132.4
16	Air Temp Ent AH, °C, from Input Data Sheet [16]	Primairy / Secundairy or Main	16B	25.4	16A 26.1
17	O2 in FG Ent Air Heater, %, from Input Data Sheet [17]	Primairy / Secundairy or Main		17A	3.80
18	O2 in FG Lvg Air Heater, %, from Input Data Sheet [18]	Primairy / Secundairy or Main		18A	7.09
18a	Mass Flow Fraction, %, from Input Data Sheet [18a]	Primairy / Secundairy or Main	18C	69.84	18D 30.16
19	Mass Ash, kg/100 kJ 100 x [30j] / [1]				0.024
	If mass of ash (item [19]) exceeds 0.065 kg/100 kJ or Sorbent utilized, Enter Mass Fraction of Refuse in Col [79] for each location				
	SORBENT DATA (Enter 0 if Sorbent not Used)				0
20	Sorbent Rate, kg/hr				0.000
21	CO2 from Sorbent, kg/ 100 kg Sorbent	from SRBa item [25I]			0.000
22	H2O from Sorbent, kg/ 100 kg Sorbent	from SRBa item [26I]			0.000
23	Sulfur Capture, kg/kg Sulfer	from SRBb item [45]			0.000
24	Spent Sorbent, kg/ 100 kg fuel	from SRBb item [48]			0.000
25	Sorb/Fuel Ratio, kg Sorb / kg Fuel	[20]/[3]			0.000
	HOT AIR QUALITY CONTROL EQUIPMENT DATA				
26	O2 in FG Ent HAQC Flue Gas Temperatures				N/A
	See Form EFFa for HAQC Flue Gas Temperatures				
PLANT NAME : NORGNER ASME PTC 4 MASTER FORM			UNIT NO.	2	
TEST NO :	4	DATE :	17-Dec-15	LOAD	80%
TIME START :	9:30	TIME END :	11:30	CALC BY	R. Tim
REMARKS :				DATE	11-Feb-16
				SHEET 1 of 3	

Form CMBSTNb Combustion Calculations

COMBUSTION PRODUCTS											
30	from Input Data Sheet		31	Theo Air Flow kg/100kg Fuel [30] x K	32	Dry Prod Flow Mol/100 kg Fuel [30] / K	33	Wet Prod Flow Mol/100 kg Fuel [30] / K	34	H2O Fuel kg/100 kJ [30] x K / ([1]) / 100	
	Ultimate Analysis % Mass										
	A	C									
A	C	59.79									
B	UBC		0.193								
C	Cb	59.60		11.51	685.96	12.0110	4.962				
D	S	0.44			4.31	1.90	32.0640	0.014			
E	H ₂	3.74			34.29	128.24			2.0159		
F	H ₂ O	18.24							18.0153		
G	H ₂ Ov	0.00							18.0153		
H	N ₂	1.12				28.0134	0.040				
I	O ₂	11.08		-4.32	-47.87						
J	ASH	5.59									
K	VM	33.22									
L	FC	42.94									
M	TOTAL	100.00	31	768.23	32	5.016	33	2.868	34	0.217	
35	Total Theo Air Fuel Check, kg/100 kJ	([31M] + [30B] x 11.51) / ([1] / 100)								3.240	
CORRECTIONS FOR SORBENT REACTIONS AND SULFUR CAPTURE											
40	CO ₂ from Sorb, kg/100 kg fuel	[21] x [25]								0.000	
41	H ₂ O from Sorb, kg/100 kg fuel	[22] x [25]								0.000	
42	SO ₂ Reduction, Mol/100 kg fuel	[32D] x [23]								0.000	
43	Dry Prod Comb, Mol/100 kg fuel	[32M] + [40] / 44.01 - [42]								5.016	
44	Wet Prod Comb, Mol/100 kg fuel	[33M] + [41] / 18.0153 + [43]								7.883	
46	Theo Air Corr, kg/100 kg fuel	[31M] + 2.16 x [30D] x [23]								768.23	
47	Theo Air Corr, Mol/100 kg fuel	[46] / 28.9625								26.525	
48	Theo Air Corr, kg/100 kJ	[46] / ([1] / 100)								3.231	
49	Wet Gas from Fuel, kg/100 kJ	(100 - [30J] - [30B] - [30D] x [23]) / ([1] / 100)								0.396	
LOCATION										AH In	AH Out
50	Flue Gas Temperature Entering Air heater °C									344.0	132.4
51	Air Temperature Leaving Air Heater, °C									25.59	312.4
52	Flue Gas Oxygen Content, %									3.800	7.090
FLUE GAS ANALYSIS, Mol/100 kg Fuel											
53	Moisture in Air	0		[7] x 1.608					0.00	0.00	
54	Dry/Wet Products Comb	[43]		[44]					5.016	5.016	
55	Additional Moisture	0		[13] / 18.0153					0.00	0.00	
56		[47] x (0.7905 + [53])								20.97	20.97
57	Summation	[54] + [55] + [56]								25.98	25.98
58		20.95 - [52] x (1 + [53])								17.15	13.86
60	Excess Air, %	100 x [52] x [57] / [47] / [58]								21.71	50.11
PLANT NAME : NORGENER ASME PTC 4 MASTER FORM											
TEST NO :	4	DATE :	17-Dec-15		UNIT NO.		2				
TIME START :	9:30	TIME END :	11:30		LOAD		80%				
REMARKS :					CALC BY		R. Tim				
					DATE		11-Feb-16				
					SHEET 2 of 3						

Form CMBSTNc Combustion Calculations

LOCATION						AH In	AH Out
60 Excess Air, %						21.71	50.11
02, CO2, SO2, WHEN EXCESS AIR KNOWN							
61							
62 Dry	[47] x (0.7905 + ([60] / 100))					26.73	34.26
63 Wet	[47] x (0.7905 + [53] + (1 + [53]) x [60] / 100)					26.73	34.26
64 Dry Gas, Mol/100 kg Fuel	[43] + [62]					31.74	39.28
65 Wet Gas, Mol/100 kg Fuel	[44] + [63] + [13] / 18.015					34.61	42.14
		Dry	Wet				
66 O2, %	[60] x [47] x 0.2095 / [65]	[64]	[65]			3.49	6.61
67 CO2,%	([30c]/0.1201+[40]/0.4401)/[65]	[64]	[65]			14.34	11.77
68 SO2,ppm	(1-[23]) x [30D] / 0.32064 / [65]	[64]	[65]			396.5	325.6
FLUE GAS PRODUCTS, kg/100 kJ							
69 Dry Air	(1 + [60] / 100) x [48]					3.932	4.850
70 Wet Gas from Fuel	[49]					0.396	0.396
71 CO2 from Sorbent	[40] / ([1] / 100)					0.000	0.000
72 Moisture in Air	[7] x [69]					0.037	0.046
73 Water from Sorbent	[41] / ([1] / 100)					0.000	0.000
74 Additional Moisture	[14]					0.000	0.000
75 Total Wet Gas	[69] + [70] + [71] + [72] + [73] + [74]					4.366	5.292
76 H2O in Wet Gas	[34M] + [72] + [73] + [74]					0.255	0.263
77 Dry Gas	[75] - [76]					4.111	5.029
78 H2O in Wet Gas, % Mass	100 x [76] / [75]					5.83	4.98
79 Residue, kg/kg Total Refuse at each location						0.00	0.00
80 Residue, kg/100 kJ	([30J] + [2] + [24]) / ([1] / 100)					0.0243	0.0243
81 Residue in Wet Gas, kg/kg	[79] x [80] / [75] Wet Gas					0.000	0.000
82 Leakage, % Gas Entering	100 x ([75L] - [75E]) / [75E]						21.22
GAS TEMPERATURE CORRECTION FOR AH LEAKAGE							
83 Gas Temp Lvg (INCL LKG), °C	[15]					344.03	132.39
84 Average AH Air Leakage Temp, °C	([16B] x [18B] + [16A] x [18D]) / 100					25.59	312.41
85 H Air Lvg, kJ/kg	T=[83], H2O=[7]						109.17
86 H Air Ent, kJ/kg	T=[84], H2O=[7]					0.597	
87 Cpg, kJ/kg°C	T=[83], H2O=[78E], RES=[81E]						1.055
88 AH Gas Outlet Temperature Excluding Leakage, °C	[83] + ([82] / 100 x ([85] - [86]) / [87])						154.22
AIR, GAS, FUEL & RESIDUE MASS FLOW RATES, kg/hr							
90 Input from Fuel, MJ/hr	[5] / [6] x 100						1035951
91 Fuel Rate, kg/hr	1000 x [90] / [1]						43569
92 Residue Rate, kg/hr	[80] x [90] / 10						2520
93 Wet Flue Gas, kg/hr	[75] x [90] / 10					452290	548270
95 Excess Air Lvg Blr, %	[60]						50.11
96 Total Air to Blr, kg/hr	(1 + [95] / 100) x (1 + [7]) x [48] x [90] / 10						507220
PLANT NAME : NORGENER ASME PTC 4 MASTER FORM				UNIT NO.	2		
TEST NO :	4	DATE :	17-Dec-15	LOAD	80%		
TIME START :	9:30	TIME END :	11:30	CALC BY	R. Tim		
REMARKS :				DATE	11-Feb-16		
				SHEET 3 of 3			

Form RES Unburned Carbon and Residue Calculation

DATA REQUIRED FOR RESIDUE SPLIT											
1	Ash in Fuel, %	from Form CMBSTNb [30J]			5.59	2	HHV Fuel, kJ/kg 'as fired'			23777	
3	Fuel Mass Flow Rate, kg/hr	from Form CMBSTNa [4b]			43569	4b	from Form CMBSTNa [1]				
a)	Item [3] - Use measured or estimated value initially. (See CMBSTNa) Recalculate after boiler efficiency has been calculated until estimated value is within 1% of calculated value.										
b)	Residue splits estimated. Enter value in Col [8] and calculate Col [5]. Residue rate measured. Enter measured mass flow rates in Col [5]. When residue is not measured at all locations, estimate split and flow for measured locations. Reiterate until estimated total residue is within 2% of calculated.										
c)	Enter the % free carbon in Col [6] (total carbon corrector for CO2). Units with sorbent: Enter the % CO2 in Col [7].										
Location	5	Residue Mass Flow	6	C in Residue %	7	CO2 in Residue %	8	Residue Split %	9	10	
	Input kg/hr	Calculated kg/hr					Input	Calculated 100 x [5]/[5F]	C Wtd Ave % [6] x [8]/100	CO2 Wtd Ave % [7] x [8]/100	
A Bottom Ash	0.00	0.00	10.09	5.00	15.00	0.00		1.514	0.750		
B Fly Ash	0.00	0.00	2.15	2.00	85.00	0.00		1.828	1.700		
C Economizer	0.00	0.00	0.00	0.00	0.00	0.00		0.000	0.000		
D	0.00	0.00	0.00	0.00	0.00	0.00		0.000	0.000		
E	0.00	0.00	0.00	0.00	0.00	0.00		0.000	0.000		
F TOTAL	5	0.00	0.00		8	100.0	0.00	9	3.341	10	2.450
UNITS WITHOUT SORBENT											
11	Unburned Carbon, kg/ 100 kg Fuel				[1] x [9F] / (100 - [9F])					0.193	
20	Total Residue, kg/ 100kg Fuel				[1] + [11]					5.78	
UNITS WITH SORBENT											
d)	Enter average C and CO2 in residue, [9F] and [10F] above or SRBa (Items [4] and [5]) and complete Sorbent Calculation Forms.										
11	Unburned Carbon, kg/ 100 kg Fuel				from Form SRBb Item [49]					0.231	
20	Total Residue, kg/ 100 Fuel				from Form SRBb Item [50]					6.92	
TOTAL RESIDUE											
21	Total Residue, kg/hr				[20] x [3] /100					2520	
e)	When all residue collection locations are measured, the measured residue split is used for calculations. If a portion of the residue mass is estimated, repeat calculation above until Col [5F] and Item [21] agree within 2%.										
22	Total Residue, kg/100 J				100 x [20] / [2]					0.024	
23	SENSIBLE HEAT RESIDUE LOSS, %										
Location	24	Temp Residue (°C)	[8] %	x	[22] Residue kg/100 kJ	x	H Residue kJ/kg	/ 10,000	Loss %		
	A Furnace	1100	15.00	x	0.024	x	1205.2	/ 10,000	0.044		
B Fly Ash	120	85.00	x	0.024	x	76.7	/ 10,000	0.016			
C Economizer	0	0.00	x	0.024	x	-30.1	/ 10,000	0.000			
D	0							0.000			
E	0							0.000			
							Total	25	0.060		
H Residue = 0.16 x T + 1.09E-4 x T^2 - 2.843E-8 x T^3 - 12.95											
PLANT NAME : NORGENER ASME PTC 4 MASTER FORM					UNIT NO.			2			
TEST NO :	4	DATE:	17-Dec-15			LOAD	80%				
TIME START :	9:30	TIME END :	11:30			CALC BY	R. Tim				
REMARKS :						DATE	11-Feb-16				
						SHEET 1 of 1					

**Form EFFa Efficiency Calculations
Data**

TEMPERATURES, °C					
1	Reference Temperature, °C	25.0	1A	Enthalpy Water (0°C Ref), kJ/kg	104.57
2	Average Entering Air Temp, from CMBSTNa Item [84]: $([16B]x[18B]+[16A]x[18D])/100$	25.59	2A	Enthalpy Dry Air, kJ/kg	0.59
3	Average Exit Gas T (Excl Lkg) from CMBSTNa [88]	154.2	3A	Enthalpy Dry Gas, kJ/kg	129.25
4	Fuel Temperature	20.8	3B	Enthalpy Steam @ 1 psia, kJ/kg	2788.5
			3C	Enthalpy Water Vapor, kJ/kg	243.88
			4A	Enthalpy Fuel, kJ/kg	-5.70
HOT AIR QUALITY CONTROL EQUIPMENT					
5	Entering Gas Temperature	0.0	5A	Enthalpy Wet Gas	0.00
6	Leaving Gas Temperature	0.0	6A	Enthalpy of Wet Gas	0.00
			6B	Enthalpy of Wet Air	0.00
			6C	Enthalpy of Wet Air @ T = [3]	0.00
RESULTS FROM COMBUSTION CALCULATION FORM CMBSTN					
10	Dry Gas Weight, kg/100 kJ [77]	4.111	18	Unburned Carbon, % [2]	0.193
11	Dry Air Weight [69]	3.932	19	HHV kJ/kg 'as-fired' [1]	23777.0
12	Water from H ₂ Fuel [34E]	0.141	HOT AQC EQUIPMENT		
13	Water from H ₂ O Fuel [34F]	0.077	20	Wet Gas Entering [75E]	0.00
14	Water from H ₂ Ov Fuel [34G]	0.000	21	H ₂ O in Wet Gas, % [78E]	0.00
15	Moisture in Air kg/kg DA [7]	0.00951	22	Wet Gas Leaving [75L]	0.00
16	Moisture in Air kg/100 kJ [72]	0.037	23	Residue in Wet Gas, % [81E]	0.00
17	Fuel Rate Est. kg/hr [3]	43569	25	Excess Air, % [95]	50.11
MISCELLANEOUS					
30	Unit Output, MJ/hr	914476	31	Aux Equip Power, MJ/hr	3056
32	Loss Due to Surface Radiation and Convection, %				0.25
PLANT NAME :		ASME PTC 4 MASTER FORM	UNIT NO.	2	
TEST NO :		DATE :	LOAD	80%	
TIME START :		TIME END :	CALC BY	R. Tim	
REMARKS :			DATE	11-Feb-16	
			SHEET 1 of 3		

Form EFFb Efficiency Calculations

LOSSES, % Enter Calculated Result in % Column [B]			A	MKB	B	%
60 Dry Gas	[10] x [3A] x /100					5.314
61 Water from H2 Fuel	[12] x ([3B] - [1A]) / 100 x - 104.57) / 100					3.773
62 Water from H2O Fuel	[13] x ([3B] - [1A]) / 100 x - 104.57) / 100					2.059
63 Water from H2O Fuel	[14] x ([3C]) / 100 x / 100					0.000
64 Moisture in Air	[16] x [3C] / 100 x / 100					0.091
65 Unburned Carbon in Ref [18] x 33700 / [19] =	x 33700/					0.274
66 Sensible Heat of Refuse from Form RES						0.060
67 Hot AQC Equip ([20] x ([5A] - [6A]) - ([22] - [20]) x ([6C] - [6B])) / 100 (-) - (-) x (-)) / 100						0.000
68 Other Losses, % Basis from Form EFFc Item [110]						0.450
69 Summation of Losses, % Basis						12.020
LOSSES, MJ/hr Enter in MKB Column [A]						
75 Surface Radiation and Convection from Form EFFa Item [32]					0.000	
76 Sorbent Calcination / Dehydration from Form SRBc Item [77]					0.000	
77 Water from Sorbent from Form SRBc Item [65]					0.000	
80 Other Losses, MJ/hr Basis from Form EFFc Item [111]					0.000	
81 Summation of Losses, MJ/hr Basis					0.000	
CREDITS, % Enter Calculation Result in % Column [B]						
85 Entering Dry Air	[11] x [2A] /100 x /100					0.023
86 Moisture in Air	[16] x [2B] /100 x /100					0.000
87 Sensible Heat in Fuel	100 x [4A] / [19] 100 x /					-0.024
88 Sulfation from Form SRBc Item [80]						0.000
89 Other Credits, % Basis from Form EFFc Item [112]						0.000
90 Summation of Credits, % Basis						0.000
CREDITS, MJ/hr Enter Calculated Result in MKB Column [A]						
95 Auxiliary Equipment Power [31]					3056.4	
96 Sensible Heat from Sorbent from Form SRBc Item [85]					0.000	
97 Other Credits, MJ/hr Basis from Form EFFc Item [113B]					0.000	
98 Summation of Credits, MJ/hr Basis					3056.4	
100 Fuel Eff, % (100 - [69] + [90]) x [30] / ([30] + [81] - [98]) (100 - +) x / (+ -)						88.27
101 Input from Fuel, MJ/hr 100 x [30] / [100] = 100 x /					1035946	
102 Fuel Rate, kg/hr 1.000 x [101] / [19] = 1.000 x /						43569
PLANT NAME : NORGENER	ASME PTC 4 MASTER FORM	UNIT NO.	2			
TEST NO : 4	DATE : 17-Dec-15	LOAD	80%			
TIME START : 9:30	TIME END : 11:30	CALC BY	R. Tim			
REMARKS :		DATE	11-Feb-16			
		SHEET 2 of 3				

Form EFFc Efficiency Calculations
Other Losses and Credits

The losses and credits listed on this sheet are not universally applicable to all fossil fired steam generators and are usually minor. Losses/credits that have not been specifically identified by this Code but are applicable in accordance with the intent of the Code should also be recorded on this sheet.

Parties to the test may agree to estimate the losses or credits in lieu of testing. Enter a 'T' for tested or 'E' for estimate in the second column, and result in the appropriate column.

Enter the sum of each group on Form EFFb.

Refer to the text of PTC 4 for the calculation method.

Item	T or E	LOSSES, % Enter Calculated Result in % Column [B]	A	MKB	B	%
110A		CO in Flue Gas				0.000
110B		Formation of NOx				0.000
110C		Pulverizer Rejects				0.000
110D		Air Infiltration				0.000
110E		Unburned Hydrocarbons in Flue Gas				0.000
110F		Unburned Hydrogen in Refuse				0.000
110G	E	Unmeasured Loss, as per agreement				0.200
110H	E	Surface Radiation Loss, as per agreement				0.250
110		Summation of Other Losses, % Basis				0.450
<hr/>						
LOSSES, MJ/hr Enter in MKB Column [A]						
111A		Wet Ash Pit				0.000
111B		Sensible Heat in Recycle Streams, Solid				0.000
111C		Sensible Heat in Recycle Streams, Gas				0.000
111D		Additional Moisture				0.000
111E		Cooling Water				0.000
111F		Air Preheater Coil (supplied by Unit)				0.000
111G		Other				0.000
111		Summation of other Losses, MJ/hr Basis				0.000
<hr/>						
CREDITS, % Enter Calculation Result in % Column [B]						
112A		Other				0.000
112		Summation of Credits, % Basis				0.000
<hr/>						
CREDITS, MJ/hr Enter Result in MKB Column [A]						
113A		Heat in Additional Moisture (external to envelope)				0.000
113B		Other				0.000
113C		Heat by Auxiliary Equipment Power				3056.4
113		Summation of Credits, MJ/hr Basis				3056.4
<hr/> <hr/> <hr/> <hr/> <hr/> <hr/>						
PLANT NAME : NORGENER		ASME PTC 4 MASTER FORM	UNIT NO.		2	
TEST NO :	4	DATE : 17-Dec-15	LOAD		80%	
TIME START :	9:30	TIME END : 11:30	CALC BY		R. Tim	
REMARKS :			DATE		11-Feb-16	
					SHEET 3 of 3	

APPENDIX G5

Results ASME PTC 4 Heat Balance Method Test at 70% Load

Form CMBSTNa Combustion Calculations

DATA REQUIRED					
1	HHV - Higher Heating value of Fuel, kJ/kg as fired, from Input Data Sheet [1]				23542
2	UBC - Unburned Carbon, kg/ 100 kg fuel from RES [11] or SRBb FORM				0.088
3	Fuel Flow, kg/hr [4b]				38778
4	a. Measured Fuel Flow				34236.0
4	b. Calculated Fuel Flow $100,000 \times [5] / [6] / [1]$				38777.5
5	Output, MJ/hr from Output Item [37]				806393
6	Fuel Efficiency, % (estimate initially), from Input Data Sheet [6]				88.33
7	Moisture in air, kg/kg Dry Air				0.01030
8	Barometric Pressure, mbar, from Input Data Sheet [8]				1007.1
9	Dry Bulb Temperature, °C, from Input Data Sheet [9]				21.4
10	Wet Bulb Temperature, °C, from Input Data Sheet [10]				16.9
11	Relative Humidity, %, from Input Data Sheet [11]				64.5
	Additional Moisture (Measured)	kg/hr			
	Atomizing Steam	from Output Item [14]	kg/hr		0.0
	Sootblowing Steam	from Output Item [11]	kg/hr		0.0
	Other		kg/hr		0.0
12	Summation Addition Moisture				0.0
13	Additional Moisture.kg/ 100 kg Fuel $100 \times [12] / [3]$				0.0
14	Additional Moisture, kg/100 kJ $[13] / ([1] / 100)$				0.0
	If Air Heater (Excl Stm/ Wtr Coil) Enter following				
15	Gas Temp Lvg AH, °C, from Input Data Sheet [15]	Primairy / Secundairy or Main			15A 131.3
16	Air Temp Ent AH, °C, from Input Data Sheet [16]	Primairy / Secundairy or Main	16B	26.8	16A 27.5
17	O2 in FG Ent Air Heater, %, from Input Data Sheet [17]	Primairy / Secundairy or Main			17A 4.39
18	O2 in FG Lvg Air Heater, %, from Input Data Sheet [18]	Primairy / Secundairy or Main			18A 7.50
18a	Mass Flow Fraction, %, from Input Data Sheet [18a]	Primairy / Secundairy or Main	18C	67.82	18D 32.18
19	Mass Ash, kg/100 kJ $100 \times [30j] / [1]$				0.024
	If mass of ash (item [19]) exceeds 0.065 kg/100 kJ or Sorbent utilized, Enter Mass Fraction of Refuse in Col [79] for each location				
	SORBENT DATA (Enter 0 if Sorbent not Used)				0
20	Sorbent Rate, kg/hr				0.000
21	CO2 from Sorbent, kg/ 100 kg Sorbent	from SRBa item [25I]			0.000
22	H2O from Sorbent, kg/ 100 kg Sorbent	from SRBa item [26I]			0.000
23	Sulfur Capture, kg/kg Sulfer	from SRBb item [45]			0.000
24	Spent Sorbent, kg/ 100 kg fuel	from SRBb item [48]			0.000
25	Sorb/Fuel Ratio, kg Sorb / kg Fuel	[20]/[3]			0.000
	HOT AIR QUALITY CONTROL EQUIPMENT DATA				
26	O2 in FG Ent HAQC Flue Gas Temperatures				N/A
	See Form EFFa for HAQC Flue Gas Temperatures				
PLANT NAME : NORGNER ASME PTC 4 MASTER FORM			UNIT NO.	2	
TEST NO :	5	DATE :	17-Dec-15	LOAD	70%
TIME START :	13:00	TIME END :	15:00	CALC BY	R. Tim
REMARKS :				DATE	11-Feb-16
				SHEET 1 of 3	

Form CMBSTNb Combustion Calculations

COMBUSTION PRODUCTS											
30	from Input Data Sheet		31	Theo Air Flow kg/100kg Fuel [30] x K	32	Dry Prod Flow Mol/100 kg Fuel [30] / K	33	Wet Prod Flow Mol/100 kg Fuel [30] / K	34	H2O Fuel kg/100 kJ [30] x K / ([1]) / 100	
	Ultimate Analysis % Mass										
	A	C									
A	C	59.01									
B	UBC		0.088								
C	Cb	58.92		11.51	678.19	12.0110	4.906				
D	S	0.43			4.31	1.85	32.0640	0.013			
E	H ₂	3.70			34.29	126.87			2.0159		
F	H ₂ O	19.08							18.0153		
G	H ₂ Ov	0.00							18.0153		
H	N ₂	1.18				28.0134	0.042				
I	O ₂	11.04		-4.32	-47.69						
J	ASH	5.55									
K	VM	33.41									
L	FC	41.95									
M	TOTAL	99.99	31	759.23	32		4.961	33	2.895	34	0.222
35	Total Theo Air Fuel Check, kg/100 kJ	([31M] + [30B] x 11.51) / ([1] / 100)								3.229	
CORRECTIONS FOR SORBENT REACTIONS AND SULFUR CAPTURE											
40	CO ₂ from Sorb, kg/100 kg fuel	[21] x [25]								0.000	
41	H ₂ O from Sorb, kg/100 kg fuel	[22] x [25]								0.000	
42	SO ₂ Reduction, Mol/100 kg fuel	[32D] x [23]								0.000	
43	Dry Prod Comb, Mol/100 kg fuel	[32M] + [40] / 44.01 - [42]								4.961	
44	Wet Prod Comb, Mol/100 kg fuel	[33M] + [41] / 18.0153 + [43]								7.856	
46	Theo Air Corr, kg/100 kg fuel	[31M] + 2.16 x [30D] x [23]								759.23	
47	Theo Air Corr, Mol/100 kg fuel	[46] / 28.9625								26.214	
48	Theo Air Corr, kg/100 kJ	[46] / ([1] / 100)								3.225	
49	Wet Gas from Fuel, kg/100 kJ	(100 - [30J] - [30B] - [30D] x [23]) / ([1] / 100)								0.401	
LOCATION										AH In	AH Out
50	Flue Gas Temperature Entering Air heater °C									335.8	131.3
51	Air Temperature Leaving Air Heater, °C									27.00	306.3
52	Flue Gas Oxygen Content, %									4.390	7.500
FLUE GAS ANALYSIS, Mol/100 kg Fuel											
53	Moisture in Air	0		[7] x 1.608					0.00	0.00	
54	Dry/Wet Products Comb	[43]		[44]					4.961	4.961	
55	Additional Moisture	0		[13] / 18.0153					0.00	0.00	
56		[47] x (0.7905 + [53])								20.72	20.72
57	Summation	[54] + [55] + [56]								25.68	25.68
58		20.95 - [52] x (1 + [53])								16.56	13.45
60	Excess Air, %	100 x [52] x [57] / [47] / [58]								25.97	54.63
PLANT NAME : NORGENER ASME PTC 4 MASTER FORM											
TEST NO :	5	DATE :	17-Dec-15		UNIT NO.		2				
TIME START :	13:00	TIME END :	15:00		LOAD		70%				
REMARKS :					CALC BY		R. Tim				
					DATE		11-Feb-16				
					SHEET 2 of 3						

Form CMBSTNc Combustion Calculations

LOCATION						AH In	AH Out
60 Excess Air, %						25.97	54.63
02, CO2, SO2, WHEN EXCESS AIR KNOWN							
61							
62 Dry	[47] x (0.7905 + ([60] / 100))					27.53	35.04
63 Wet	[47] x (0.7905 + [53] + (1 + [53]) x [60] / 100)					27.53	35.04
64 Dry Gas, Mol/100 kg Fuel	[43] + [62]					32.49	40.01
65 Wet Gas, Mol/100 kg Fuel	[44] + [63] + [13] / 18.015					35.39	42.90
		Dry	Wet				
66 O2, %	[60] x [47] x 0.2095 / [65]	[64]	[65]			4.03	6.99
67 CO2,%	([30c]/0.1201+[40]/0.4401)/[65]	[64]	[65]			13.86	11.44
68 SO2,ppm	(1-[23]) x [30D] / 0.32064 / [65]	[64]	[65]			379.0	312.6
FLUE GAS PRODUCTS, kg/100 kJ							
69 Dry Air	(1 + [60] / 100) x [48]					4.063	4.987
70 Wet Gas from Fuel	[49]					0.401	0.401
71 CO2 from Sorbent	[40] / ([1] / 100)					0.000	0.000
72 Moisture in Air	[7] x [69]					0.042	0.051
73 Water from Sorbent	[41] / ([1] / 100)					0.000	0.000
74 Additional Moisture	[14]					0.000	0.000
75 Total Wet Gas	[69] + [70] + [71] + [72] + [73] + [74]					4.505	5.439
76 H2O in Wet Gas	[34M] + [72] + [73] + [74]					0.263	0.273
77 Dry Gas	[75] - [76]					4.242	5.166
78 H2O in Wet Gas, % Mass	100 x [76] / [75]					5.85	5.02
79 Residue, kg/kg Total Refuse at each location						0.00	0.00
80 Residue, kg/100 kJ	([30J] + [2] + [24]) / ([1] / 100)					0.0239	0.0239
81 Residue in Wet Gas, kg/kg	[79] x [80] / [75] Wet Gas					0.000	0.000
82 Leakage, % Gas Entering	100 x ([75L] - [75E]) / [75E]						20.73
GAS TEMPERATURE CORRECTION FOR AH LEAKAGE							
83 Gas Temp Lvg (INCL LKG), °C	[15]					335.78	131.26
84 Average AH Air Leakage Temp, °C	([16B] x [18B] + [16A] x [18D]) / 100					27.00	306.32
85 H Air Lvg, kJ/kg	T=[83], H2O=[7]						108.09
86 H Air Ent, kJ/kg	T=[84], H2O=[7]					2.029	
87 Cpg, kJ/kg°C	T=[83], H2O=[78E], RES=[81E]						1.056
88 AH Gas Outlet Temperature Excluding Leakage, °C	[83] + ([82] / 100 x ([85] - [86]) / [87])						152.09
AIR, GAS, FUEL & RESIDUE MASS FLOW RATES, kg/hr							
90 Input from Fuel, MJ/hr	[5] / [6] x 100						912901
91 Fuel Rate, kg/hr	1000 x [90] / [1]						38778
92 Residue Rate, kg/hr	[80] x [90] / 10						2186
93 Wet Flue Gas, kg/hr	[75] x [90] / 10					411287	496535
95 Excess Air Lvg Blr, %	[60]						54.63
96 Total Air to Blr, kg/hr	(1 + [95] / 100) x (1 + [7]) x [48] x [90] / 10						459944
PLANT NAME : NORGENER ASME PTC 4 MASTER FORM				UNIT NO.	2		
TEST NO :	5	DATE :	17-Dec-15	LOAD	70%		
TIME START :	13:00	TIME END :	15:00	CALC BY	R. Tim		
REMARKS :				DATE	11-Feb-16		
				SHEET 3 of 3			

Form RES Unburned Carbon and Residue Calculation

DATA REQUIRED FOR RESIDUE SPLIT										
1	Ash in Fuel, %	from Form CMBSTNb [30J]			5.55	2	HHV Fuel, kJ/kg 'as fired'			23542
3	Fuel Mass Flow Rate, kg/hr	from Form CMBSTNa [4b]			38778	4b	from Form CMBSTNa [1]			
a)	Item [3] - Use measured or estimated value initially. (See CMBSTNa) Recalculate after boiler efficiency has been calculated until estimated value is within 1% of calculated value.									
b)	Residue splits estimated. Enter value in Col [8] and calculate Col [5]. Residue rate measured. Enter measured mass flow rates in Col [5]. When residue is not measured at all locations, estimate split and flow for measured locations. Reiterate until estimated total residue is within 2% of calculated.									
c)	Enter the % free carbon in Col [6] (total carbon corrector for CO2). Units with sorbent: Enter the % CO2 in Col [7].									
Location	5	Residue Mass Flow	6	C in Residue %	7	CO2 in Residue %	8	Residue Split %	9	10
	Input kg/hr	Calculated kg/hr					Input	Calculated 100 x [5]/[5F]	C Wtd Ave % [6] x [8]/100	CO2 Wtd Ave % [7] x [8]/100
A Bottom Ash	0.00	0.00	7.29	5.00		15.00	0.00	1.094		0.750
B Fly Ash	0.00	0.00	0.55	2.00		85.00	0.00	0.468		1.700
C Economizer	0.00	0.00	0.00	0.00		0.00	0.00	0.000		0.000
D	0.00	0.00	0.00	0.00		0.00	0.00	0.000		0.000
E	0.00	0.00	0.00	0.00		0.00	0.00	0.000		0.000
F TOTAL	5	0.00	0.00			8	100.0	0.00	9 1.561	10 2.450
UNITS WITHOUT SORBENT										
11	Unburned Carbon, kg/ 100 kg Fuel				[1] x [9F] / (100 - [9F])				0.088	
20	Total Residue, kg/ 100kg Fuel				[1] + [11]				5.64	
UNITS WITH SORBENT										
d)	Enter average C and CO2 in residue, [9F] and [10F] above or SRBa (Items [4] and [5]) and complete Sorbent Calculation Forms.									
11	Unburned Carbon, kg/ 100 kg Fuel				from Form SRBb Item [49]				0.105	
20	Total Residue, kg/ 100 Fuel				from Form SRBb Item [50]				6.73	
TOTAL RESIDUE										
21	Total Residue, kg/hr				[20] x [3] /100				2186	
e)	When all residue collection locations are measured, the measured residue split is used for calculations. If a portion of the residue mass is estimated, repeat calculation above until Col [5F] and Item [21] agree within 2%.									
22	Total Residue, kg/100 J				100 x [20] / [2]				0.024	
23	SENSIBLE HEAT RESIDUE LOSS, %									
Location	24	Temp Residue (°C)	[8]	x	[22]	Residue kg/100 kJ	x	H Residue kJ/kg	/ 10,000	Loss %
			%							
A Furnace	1100		15.00	x	0.024	x	1205.2	/ 10,000		0.043
B Fly Ash	120		85.00	x	0.024	x	76.7	/ 10,000		0.016
C Economizer	0		0.00	x	0.024	x	-30.1	/ 10,000		0.000
D	0									0.000
E	0									0.000
								Total	25	0.059
H Residue = 0.16 x T + 1.09E-4 x T^2 - 2.843E-8 x T^3 - 12.95										
PLANT NAME : NORGENER ASME PTC 4 MASTER FORM					UNIT NO.			2		
TEST NO :	5	DATE:	17-Dec-15			LOAD	70%			
TIME START :	13:00	TIME END :	15:00			CALC BY	R. Tim			
REMARKS :						DATE	11-Feb-16			
						SHEET 1 of 1				

**Form EFFa Efficiency Calculations
Data**

TEMPERATURES, °C					
1	Reference Temperature, °C	25.0	1A	Enthalpy Water (0°C Ref), kJ/kg	104.57
2	Average Entering Air Temp, from CMBSTNa Item [84]: ([16B]x[18B]+[16A]x[18D])/100	27.00	2A	Enthalpy Dry Air, kJ/kg	2.01
3	Average Exit Gas T (Excl Lkg) from CMBSTNa [88]	152.1	3A	Enthalpy Dry Gas, kJ/kg	127.08
			3B	Enthalpy Steam @ 1 psia, kJ/kg	2784.4
			3C	Enthalpy Water Vapor, kJ/kg	239.79
4	Fuel Temperature	21.4	4A	Enthalpy Fuel, kJ/kg	-4.97
HOT AIR QUALITY CONTROL EQUIPMENT					
5	Entering Gas Temperature	0.0	5A	Enthalpy Wet Gas	0.00
6	Leaving Gas Temperature	0.0	6A	Enthalpy of Wet Gas	0.00
			6B	Enthalpy of Wet Air	0.00
			6C	Enthalpy of Wet Air @ T = [3]	0.00
RESULTS FROM COMBUSTION CALCULATION FORM CMBSTN					
10	Dry Gas Weight, kg/100 kJ	[77]	4.242	18	Unburned Carbon, %
11	Dry Air Weight	[69]	4.063	19	HHV kJ/kg 'as-fired'
12	Water from H ₂ Fuel	[34E]	0.140	HOT AQC EQUIPMENT	
13	Water from H ₂ O Fuel	[34F]	0.081	20	Wet Gas Entering
14	Water from H ₂ Ov Fuel	[34G]	0.000	21	H ₂ O in Wet Gas, %
15	Moisture in Air kg/kg DA	[7]	0.01030	22	Wet Gas Leaving
16	Moisture in Air kg/100 kJ	[72]	0.042	23	Residue in Wet Gas, %
17	Fuel Rate Est. kg/hr	[3]	38778	25	Excess Air, %
				[95]	54.63
MISCELLANEOUS					
30	Unit Output, MJ/hr	806393	31	Aux Equip Power, MJ/hr	3038
32	Loss Due to Surface Radiation and Convection, %				0.25

PLANT NAME :	ASME PTC 4 MASTER FORM	UNIT NO.	2
TEST NO. :	DATE :	LOAD	70%
TIME START :	TIME END :	CALC BY	R. Tim
REMARKS :		DATE	11-Feb-16
		SHEET 1 of 3	

Form EFFb Efficiency Calculations

LOSSES, % Enter Calculated Result in % Column [B]			A	MKB	B	%
60 Dry Gas	[10] x [3A] x	/100 /100				5.391
61 Water from H2 Fuel	[12] x ([3B] - [1A]) / 100 x - 104.57) / 100					3.764
62 Water from H2O Fuel	[13] x ([3B] - [1A]) / 100 x - 104.57) / 100					2.172
63 Water from H2O Fuel	[14] x ([3C]) / 100 x / 100					0.000
64 Moisture in Air	[16] x [3C] x	/ 100 / 100				0.100
65 Unburned Carbon in Ref [18] x 33700 / [19] =	x 33700/					0.126
66 Sensible Heat of Refuse from Form RES						0.059
67 Hot AQC Equip ((20) x ([5A] - [6A]) - ([22] - [20]) x ([6C] - [6B])) / 100 (-) - (-) x (-)) / 100						0.000
68 Other Losses, % Basis from Form EFFc Item [110]						0.450
69 Summation of Losses, % Basis						12.062
LOSSES, MJ/hr Enter in MKB Column [A]						
75 Surface Radiation and Convection from Form EFFa Item [32]					0.000	
76 Sorbent Calcination / Dehydration from Form SRBc Item [77]					0.000	
77 Water from Sorbent from Form SRBc Item [65]					0.000	
80 Other Losses, MJ/hr Basis from Form EFFc Item [111]					0.000	
81 Summation of Losses, MJ/hr Basis					0.000	
CREDITS, % Enter Calculation Result in % Column [B]						
85 Entering Dry Air	[11] x [2A] x	/100 /100				0.082
86 Moisture in Air	[16] x [2B] x	/100 /100				0.002
87 Sensible Heat in Fuel	100 x [4A] 100 x	/ [19] /				-0.021
88 Sulfation from Form SRBc Item [80]						0.000
89 Other Credits, % Basis from Form EFFc Item [112]						0.000
90 Summation of Credits, % Basis						0.062
CREDITS, MJ/hr Enter Calculated Result in MKB Column [A]						
95 Auxiliary Equipment Power [31]					3038.4	
96 Sensible Heat from Sorbent from Form SRBc Item [85]					0.000	
97 Other Credits, MJ/hr Basis from Form EFFc Item [113B]					0.000	
98 Summation of Credits, MJ/hr Basis					3038.4	
100 Fuel Eff, % (100 - [69] + [90]) x [30] / ([30] + [81] - [98]) (100 - +) x / (+ -)						88.33
101 Input from Fuel, MJ/hr 100 x [30] / [100] = 100 x /					912904	
102 Fuel Rate, kg/hr 1.000 x [101] / [19] = 1.000 x /						38778
PLANT NAME : NORGENER	ASME PTC 4 MASTER FORM	UNIT NO.	2			
TEST NO : 5	DATE : 17-Dec-15	LOAD	70%			
TIME START : 13:00	TIME END : 15:00	CALC BY	R. Tim			
REMARKS :		DATE	11-Feb-16			
		SHEET 2 of 3				

Form EFFc Efficiency Calculations

The losses and credits listed on this sheet are not universally applicable to all fossil fired steam generators and are usually minor. Losses/credits that have not been specifically identified by this Code but are applicable in accordance with the intent of the Code should also be recorded on this sheet.

Parties to the test may agree to estimate the losses or credits in lieu of testing. Enter a 'T' for tested or 'E' for estimate in the second column, and result in the appropriate column.

Enter the sum of each group on Form EFFb.

Refer to the text of PTC 4 for the calculation method.

Item	T or E	LOSSES, % Enter Calculated Result in % Column[B]	A	MKB	B	%
110A		CO in Flue Gas				0.000
110B		Formation of NOx				0.000
110C		Pulverizer Rejects				0.000
110D		Air Infiltration				0.000
110E		Unburned Hydrocarbons in Flue Gas				0.000
110F		Unburned Hydrogen in Refuse				0.000
110G	E	Unmeasured Loss, as per agreement				0.200
110H	E	Surface Radiation Loss, as per agreement				0.250
110		Summation of Other Losses, % Basis				0.450

LOSSES, MJ/hr Enter in MKB Column [A]		
111A	Wet Ash Pit	0.000
111B	Sensible Heat in Recycle Streams, Solid	0.000
111C	Sensible Heat in Recycle Streams, Gas	0.000
111D	Additional Moisture	0.000
111E	Cooling Water	0.000
111F	Air Preheater Coil (supplied by Unit)	0.000
111G	Other	0.000
111	Summation of other Losses, MJ/hr Basis	0.000

CREDITS, % Enter Calculation Result in % Column [B]	
112A	Other
112	Summation of Credits, % Basis

CREDITS, MJ/hr Enter Result in MKB Column [A]		
113A	Heat in Additional Moisture (external to envelope)	0.000
113B	Other	0.000
113C	Heat by Auxiliary Equipment Power	3038.4
113	Summation of Credits, MJ/hr Basis	3038.4

PLANT NAME : NORGENER	ASME PTC 4 MASTER FORM	UNIT NO.	2
TEST NO : 5	DATE : 17-Dec-15	LOAD	70%
TIME START : 13:00	TIME END : 15:00	CALC BY	R. Tim
REMARKS :		DATE	11-Feb-16

APPENDIX G6

Results ASME PTC 4 Heat Balance Method Test at 47% Load

Form CMBSTNa Combustion Calculations

DATA REQUIRED					
1	HHV - Higher Heating value of Fuel, kJ/kg as fired, from Input Data Sheet [1]				23505
2	UBC - Unburned Carbon, kg/ 100 kg fuel from RES [11] or SRBb FORM				0.111
3	Fuel Flow, kg/hr [4b]				28005
4	a. Measured Fuel Flow				24696.0
4	b. Calculated Fuel Flow 100,000 x [5] / [6] / [1]				28004.8
5	Output, MJ/hr from Output Item [37]				579546
6	Fuel Efficiency, % (estimate initially), from Input Data Sheet [6]				88.04
7	Moisture in air, kg/kg Dry Air				0.01149
8	Barometric Pressure, mbar, from Input Data Sheet [8]				1005.1
9	Dry Bulb Temperature, °C, from Input Data Sheet [9]				20.7
10	Wet Bulb Temperature, °C, from Input Data Sheet [10]				17.6
11	Relative Humidity, %, from Input Data Sheet [11]				74.8
	Additional Moisture (Measured)	kg/hr			
	Atomizing Steam	from Output Item [14]	kg/hr		0.0
	Sootblowing Steam	from Output Item [11]	kg/hr		0.0
	Other		kg/hr		0.0
12	Summation Addition Moisture				0.0
13	Additional Moisture.kg/ 100 kg Fuel 100 x [12] / [3]				0.0
14	Additional Moisture, kg/100 kJ [13] / ([1] / 100)				0.0
	If Air Heater (Excl Stm/ Wtr Coil) Enter following				
15	Gas Temp Lvg AH, °C, from Input Data Sheet [15]	Primairy / Secundairy or Main		15A	127.2
16	Air Temp Ent AH, °C, from Input Data Sheet [16]	Primairy / Secundairy or Main	16B	26.3	16A 27.0
17	O2 in FG Ent Air Heater, %, from Input Data Sheet [17]	Primairy / Secundairy or Main		17A	5.78
18	O2 in FG Lvg Air Heater, %, from Input Data Sheet [18]	Primairy / Secundairy or Main		18A	8.90
18a	Mass Flow Fraction, %, from Input Data Sheet [18a]	Primairy / Secundairy or Main	18C	61.47	18D 38.53
19	Mass Ash, kg/100 kJ 100 x [30j] / [1]				0.024
	If mass of ash (item [19]) exceeds 0.065 kg/100 kJ or Sorbent utilized, Enter Mass Fraction of Refuse in Col [79] for each location				
	SORBENT DATA (Enter 0 if Sorbent not Used)				0
20	Sorbent Rate, kg/hr				0.000
21	CO2 from Sorbent, kg/ 100 kg Sorbent	from SRBa item [25I]			0.000
22	H2O from Sorbent, kg/ 100 kg Sorbent	from SRBa item [26I]			0.000
23	Sulfur Capture, kg/kg Sulfer	from SRBb item [45]			0.000
24	Spent Sorbent, kg/ 100 kg fuel	from SRBb item [48]			0.000
25	Sorb/Fuel Ratio, kg Sorb / kg Fuel	[20]/[3]			0.000
	HOT AIR QUALITY CONTROL EQUIPMENT DATA				
26	O2 in FG Ent HAQC Flue Gas Temperatures				N/A
	See Form EFFa for HAQC Flue Gas Temperatures				
PLANT NAME : NORGNER ASME PTC 4 MASTER FORM			UNIT NO.	2	
TEST NO :	6	DATE :	17-Dec-15	LOAD	47%
TIME START :	17:00	TIME END :	19:00	CALC BY	R. Tim
REMARKS :				DATE	11-Feb-16
				SHEET 1 of 3	

Form CMBSTNb Combustion Calculations

COMBUSTION PRODUCTS											
30	from Input Data Sheet		31	Theo Air Flow kg/100kg Fuel [30] x K	32	Dry Prod Flow Mol/100 kg Fuel [30] / K	33	Wet Prod Flow Mol/100 kg Fuel [30] / K	34	H2O Fuel kg/100 kJ [30] x K / ([1]) / 100	
	Ultimate Analysis % Mass										
A	C	59.11									
B	UBC		0.111								
C	Cb	59.00		11.51	679.08	12.0110	4.912				
D	S	0.43			4.31	1.85	32.0640	0.013			
E	H ₂	3.67			34.29	125.84			2.0159	1.821	
F	H ₂ O	18.99							18.0153	1.054	
G	H ₂ Ov	0.00							18.0153	0.000	
H	N ₂	1.18				28.0134	0.042				
I	O ₂	10.98			-4.32	-47.43					
J	ASH	5.62									
K	VM	33.50									
L	FC	41.88									
M	TOTAL	99.98		31	759.35	32	4.968	33	2.875	34	0.220
35	Total Theo Air Fuel Check, kg/100 kJ	([31M] + [30B] x 11.51) / ([1] / 100)								3.236	
CORRECTIONS FOR SORBENT REACTIONS AND SULFUR CAPTURE											
40	CO ₂ from Sorb, kg/100 kg fuel	[21] x [25]								0.000	
41	H ₂ O from Sorb, kg/100 kg fuel	[22] x [25]								0.000	
42	SO ₂ Reduction, Mol/100 kg fuel	[32D] x [23]								0.000	
43	Dry Prod Comb, Mol/100 kg fuel	[32M] + [40] / 44.01 - [42]								4.968	
44	Wet Prod Comb, Mol/100 kg fuel	[33M] + [41] / 18.0153 + [43]								7.842	
46	Theo Air Corr, kg/100 kg fuel	[31M] + 2.16 x [30D] x [23]								759.35	
47	Theo Air Corr, Mol/100 kg fuel	[46] / 28.9625								26.218	
48	Theo Air Corr, kg/100 kJ	[46] / ([1] / 100)								3.231	
49	Wet Gas from Fuel, kg/100 kJ	(100 - [30J] - [30B] - [30D] x [23]) / ([1] / 100)								0.401	
LOCATION										AH In	AH Out
50	Flue Gas Temperature Entering Air heater °C									308.5	127.2
51	Air Temperature Leaving Air Heater, °C									26.54	285.3
52	Flue Gas Oxygen Content, %									5.780	8.900
FLUE GAS ANALYSIS, Mol/100 kg Fuel											
53	Moisture in Air	0		[7] x 1.608				0.00		0.00	
54	Dry/Wet Products Comb	[43]		[44]				4.968		4.968	
55	Additional Moisture	0		[13] / 18.0153				0.00		0.00	
56	[47] x (0.7905 + [53])									20.73	20.73
57	Summation	[54] + [55] + [56]								25.69	25.69
58	20.95 - [52] x (1 + [53])									15.17	12.05
60	Excess Air, %	100 x [52] x [57] / [47] / [58]								37.34	72.38
PLANT NAME : NORGENER ASME PTC 4 MASTER FORM											
TEST NO :	6	DATE :	17-Dec-15		UNIT NO.		2		LOAD	47%	
TIME START :	17:00	TIME END :	19:00		CALC BY		R. Tim		DATE	11-Feb-16	
REMARKS :									SHEET 2 of 3		

Form CMBSTNc Combustion Calculations

LOCATION						AH In	AH Out
60 Excess Air, %						37.34	72.38
02, CO2, SO2, WHEN EXCESS AIR KNOWN							
61							
62 Dry	[47] x (0.7905 + ([60] / 100))					30.52	39.70
63 Wet	[47] x (0.7905 + [53] + (1 + [53]) x [60] / 100)					30.52	39.70
64 Dry Gas, Mol/100 kg Fuel	[43] + [62]					35.48	44.67
65 Wet Gas, Mol/100 kg Fuel	[44] + [63] + [13] / 18.015					38.36	47.54
		Dry	Wet				
66 O2, %	[60] x [47] x 0.2095 / [65]	[64]	[65]			5.35	8.36
67 CO2,%	([30c]/0.1201+[40]/0.4401)/[65]	[64]	[65]			12.81	10.33
68 SO2,ppm	(1-[23]) x [30D] / 0.32064 / [65]	[64]	[65]			349.6	282.1
FLUE GAS PRODUCTS, kg/100 kJ							
69 Dry Air	(1 + [60] / 100) x [48]					4.437	5.569
70 Wet Gas from Fuel	[49]					0.401	0.401
71 CO2 from Sorbent	[40] / ([1] / 100)					0.000	0.000
72 Moisture in Air	[7] x [69]					0.051	0.064
73 Water from Sorbent	[41] / ([1] / 100)					0.000	0.000
74 Additional Moisture	[14]					0.000	0.000
75 Total Wet Gas	[69] + [70] + [71] + [72] + [73] + [74]					4.889	6.034
76 H2O in Wet Gas	[34M] + [72] + [73] + [74]					0.271	0.284
77 Dry Gas	[75] - [76]					4.618	5.750
78 H2O in Wet Gas, % Mass	100 x [76] / [75]					5.55	4.71
79 Residue, kg/kg Total Refuse at each location						0.00	0.00
80 Residue, kg/100 kJ	([30J] + [2] + [24]) / ([1] / 100)					0.0244	0.0244
81 Residue in Wet Gas, kg/kg	[79] x [80] / [75] Wet Gas					0.000	0.000
82 Leakage, % Gas Entering	100 x ([75L] - [75E]) / [75E]						23.42
GAS TEMPERATURE CORRECTION FOR AH LEAKAGE							
83 Gas Temp Lvg (INCL LKG), °C	[15]					308.49	127.16
84 Average AH Air Leakage Temp, °C	([16B] x [18B] + [16A] x [18D]) / 100					26.54	285.31
85 H Air Lvg, kJ/kg	T=[83], H2O=[7]						104.01
86 H Air Ent, kJ/kg	T=[84], H2O=[7]					1.567	
87 Cpg, kJ/kg°C	T=[83], H2O=[78E], RES=[81E]						1.052
88 AH Gas Outlet Temperature Excluding Leakage, °C	[83] + ([82] / 100 x ([85] - [86]) / [87])						149.97
AIR, GAS, FUEL & RESIDUE MASS FLOW RATES, kg/hr							
90 Input from Fuel, MJ/hr	[5] / [6] x 100						658253
91 Fuel Rate, kg/hr	1000 x [90] / [1]						28005
92 Residue Rate, kg/hr	[80] x [90] / 10						1605
93 Wet Flue Gas, kg/hr	[75] x [90] / 10					321811	397184
95 Excess Air Lvg Blr, %	[60]						72.38
96 Total Air to Blr, kg/hr	(1 + [95] / 100) x (1 + [7]) x [48] x [90] / 10						370784
PLANT NAME : NORGENER ASME PTC 4 MASTER FORM				UNIT NO.	2		
TEST NO :	6	DATE :	17-Dec-15	LOAD	47%		
TIME START :	17:00	TIME END :	19:00	CALC BY	R. Tim		
REMARKS :				DATE	11-Feb-16		
				SHEET 3 of 3			

Form RES Unburned Carbon and Residue Calculation

DATA REQUIRED FOR RESIDUE SPLIT											
1	Ash in Fuel, %	from Form CMBSTNb [30J]			5.62	2	HHV Fuel, kJ/kg 'as fired'			23505	
3	Fuel Mass Flow Rate, kg/hr	from Form CMBSTNa [4b]			28005	4b	from Form CMBSTNa [1]				
a)	Item [3] - Use measured or estimated value initially. (See CMBSTNa) Recalculate after boiler efficiency has been calculated until estimated value is within 1% of calculated value.										
b)	Residue splits estimated. Enter value in Col [8] and calculate Col [5]. Residue rate measured. Enter measured mass flow rates in Col [5]. When residue is not measured at all locations, estimate split and flow for measured locations. Reiterate until estimated total residue is within 2% of calculated.										
c)	Enter the % free carbon in Col [6] (total carbon corrector for CO2). Units with sorbent: Enter the % CO2 in Col [7].										
Location	5	Residue Mass Flow	6	C in Residue %	7	CO2 in Residue %	8	Residue Split %	9	10	
	Input kg/hr	Calculated kg/hr					Input	Calculated 100 x [5]/[5F]	C Wtd Ave % [6] x [8]/100	CO2 Wtd Ave % [7] x [8]/100	
A Bottom Ash	0.00	0.00	10.26	5.00	15.00	0.00		1.539	0.750		
B Fly Ash	0.00	0.00	0.46	2.00	85.00	0.00		0.391	1.700		
C Economizer	0.00	0.00	0.00	0.00	0.00	0.00		0.000	0.000		
D	0.00	0.00	0.00	0.00	0.00	0.00		0.000	0.000		
E	0.00	0.00	0.00	0.00	0.00	0.00		0.000	0.000		
F TOTAL	5	0.00	0.00		8	100.0	0.00	9	1.930	10	2.450
UNITS WITHOUT SORBENT											
11	Unburned Carbon, kg/ 100 kg Fuel				[1] x [9F] / (100 - [9F])				0.111		
20	Total Residue, kg/ 100kg Fuel				[1] + [11]				5.73		
UNITS WITH SORBENT											
d)	Enter average C and CO2 in residue, [9F] and [10F] above or SRBa (Items [4] and [5]) and complete Sorbent Calculation Forms.										
11	Unburned Carbon, kg/ 100 kg Fuel				from Form SRBb Item [49]				0.132		
20	Total Residue, kg/ 100 Fuel				from Form SRBb Item [50]				6.83		
TOTAL RESIDUE											
21	Total Residue, kg/hr				[20] x [3] /100				1605		
e)	When all residue collection locations are measured, the measured residue split is used for calculations. If a portion of the residue mass is estimated, repeat calculation above until Col [5F] and Item [21] agree within 2%.										
22	Total Residue, kg/100 J				100 x [20] / [2]				0.024		
23	SENSIBLE HEAT RESIDUE LOSS, %										
Location	24	Temp Residue (°C)	[8] %	x	[22] Residue kg/100 kJ	x	H Residue kJ/kg	/ 10,000	Loss %		
A Furnace		1100	15.00	x	0.024	x	1205.2	/ 10,000	0.044		
B Fly Ash		120	85.00	x	0.024	x	76.7	/ 10,000	0.016		
C Economizer		0	0.00	x	0.024	x	-30.1	/ 10,000	0.000		
D		0							0.000		
E		0							0.000		
								Total	25	0.060	
H Residue = 0.16 x T + 1.09E-4 x T^2 - 2.843E-8 x T^3 - 12.95											
PLANT NAME : NORGENER ASME PTC 4 MASTER FORM					UNIT NO.			2			
TEST NO :	6	DATE:	17-Dec-15			LOAD	47%				
TIME START :	17:00	TIME END :	19:00			CALC BY	R. Tim				
REMARKS :						DATE	11-Feb-16				
						SHEET 1 of 1					

**Form EFFa Efficiency Calculations
Data**

TEMPERATURES, °C																									
1	Reference Temperature, °C	25.0	1A	Enthalpy Water (0°C Ref), kJ/kg	104.57																				
2	Average Entering Air Temp, from CMBSTNa Item [84]: ([16B]x[18B]+[16A]x[18D])/100	26.54	2A	Enthalpy Dry Air, kJ/kg	1.55																				
3	Average Exit Gas T (Excl Lkg) from CMBSTNa [88]	150.0	3A	Enthalpy Dry Gas, kJ/kg	124.93																				
4	Fuel Temperature	20.7	3B	Enthalpy Steam @ 1 psia, kJ/kg	2780.4																				
			3C	Enthalpy Water Vapor, kJ/kg	235.74																				
			4A	Enthalpy Fuel, kJ/kg	-5.97																				
HOT AIR QUALITY CONTROL EQUIPMENT																									
5	Entering Gas Temperature	0.0	5A	Enthalpy Wet Gas	0.00																				
6	Leaving Gas Temperature	0.0	6A	Enthalpy of Wet Gas	0.00																				
			6B	Enthalpy of Wet Air	0.00																				
			6C	Enthalpy of Wet Air @ T = [3]	0.00																				
RESULTS FROM COMBUSTION CALCULATION FORM CMBSTN																									
10	Dry Gas Weight, kg/100 kJ [77]	4.618	18	Unburned Carbon, % [2]	0.111																				
11	Dry Air Weight [69]	4.437	19	HHV kJ/kg 'as-fired' [1]	23505.0																				
12	Water from H ₂ Fuel [34E]	0.140	HOT AQC EQUIPMENT																						
13	Water from H ₂ O Fuel [34F]	0.081	20	Wet Gas Entering [75E]	0.00																				
14	Water from H ₂ Ov Fuel [34G]	0.000	21	H ₂ O in Wet Gas, % [78E]	0.00																				
15	Moisture in Air kg/kg DA [7]	0.01149	22	Wet Gas Leaving [75L]	0.00																				
16	Moisture in Air kg/100 kJ [72]	0.051	23	Residue in Wet Gas, % [81E]	0.00																				
17	Fuel Rate Est. kg/hr [3]	28005	25	Excess Air, % [95]	72.38																				
MISCELLANEOUS																									
30	Unit Output, MJ/hr	579546	31	Aux Equip Power, MJ/hr	3006																				
32	Loss Due to Surface Radiation and Convection, %				0.25																				
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>PLANT NAME :</td> <td>ASME PTC 4 MASTER FORM</td> <td>UNIT NO.</td> <td>2</td> </tr> <tr> <td>TEST NO :</td> <td>DATE :</td> <td>LOAD</td> <td>47%</td> </tr> <tr> <td>TIME START :</td> <td>TIME END :</td> <td>CALC BY</td> <td>R. Tim</td> </tr> <tr> <td>REMARKS :</td> <td></td> <td>DATE</td> <td>11-Feb-16</td> </tr> <tr> <td></td> <td></td> <td colspan="2">SHEET 1 of 3</td> </tr> </table>						PLANT NAME :	ASME PTC 4 MASTER FORM	UNIT NO.	2	TEST NO :	DATE :	LOAD	47%	TIME START :	TIME END :	CALC BY	R. Tim	REMARKS :		DATE	11-Feb-16			SHEET 1 of 3	
PLANT NAME :	ASME PTC 4 MASTER FORM	UNIT NO.	2																						
TEST NO :	DATE :	LOAD	47%																						
TIME START :	TIME END :	CALC BY	R. Tim																						
REMARKS :		DATE	11-Feb-16																						
		SHEET 1 of 3																							

Form EFFb Efficiency Calculations

LOSSES, % Enter Calculated Result in % Column [B]			A	MKB	B	%
60 Dry Gas	[10] x [3A] x /100					5.769
61 Water from H2 Fuel	[12] x ([3B] - [1A]) / 100 x - 104.57) / 100					3.734
62 Water from H2O Fuel	[13] x ([3B] - [1A]) / 100 x - 104.57) / 100					2.162
63 Water from H2O Fuel	[14] x ([3C]) / 100 x / 100					0.000
64 Moisture in Air	[16] x [3C] / 100 x / 100					0.120
65 Unburned Carbon in Ref [18] x 33700 / [19] =	x 33700/					0.159
66 Sensible Heat of Refuse from Form RES						0.060
67 Hot AQC Equip	([20] x ([5A] - [6A]) - ([22] - [20]) x ([6C] - [6B])) / 100 (-) - (-) x (-)) / 100					0.000
68 Other Losses, % Basis from Form EFFc Item [110]						0.456
69 Summation of Losses, % Basis						12.459
LOSSES, MJ/hr Enter in MKB Column [A]						
75 Surface Radiation and Convection from Form EFFa Item [32]					0.000	
76 Sorbent Calcination / Dehydration from Form SRBc Item [77]					0.000	
77 Water from Sorbent from Form SRBc Item [65]					0.000	
80 Other Losses, MJ/hr Basis from Form EFFc Item [111]					0.000	
81 Summation of Losses, MJ/hr Basis					0.000	
CREDITS, % Enter Calculation Result in % Column [B]						
85 Entering Dry Air	[11] x [2A] /100 x /100					0.069
86 Moisture in Air	[16] x [2B] /100 x /100					0.001
87 Sensible Heat in Fuel	100 x [4A] / [19] 100 x /					-0.025
88 Sulfation from Form SRBc Item [80]						0.000
89 Other Credits, % Basis from Form EFFc Item [112]						0.000
90 Summation of Credits, % Basis						0.045
CREDITS, MJ/hr Enter Calculated Result in MKB Column [A]						
95 Auxiliary Equipment Power [31]					3006.0	
96 Sensible Heat from Sorbent from Form SRBc Item [85]					0.000	
97 Other Credits, MJ/hr Basis from Form EFFc Item [113B]					0.000	
98 Summation of Credits, MJ/hr Basis					3006.0	
100 Fuel Eff, % (100 - [69] + [90]) x [30] / ([30] + [81] - [98]) (100 - +) x / (+ -)						88.04
101 Input from Fuel, MJ/hr 100 x [30] / [100] = 100 x /					658257	
102 Fuel Rate, kg/hr 1.000 x [101] / [19] = 1.000 x /						28005
PLANT NAME : NORGENER	ASME PTC 4 MASTER FORM	UNIT NO.	2			
TEST NO : 6	DATE : 17-Dec-15	LOAD	47%			
TIME START : 17:00	TIME END : 19:00	CALC BY	R. Tim			
REMARKS :		DATE	11-Feb-16			
		SHEET 2 of 3				

Form EFFc Efficiency Calculations

The losses and credits listed on this sheet are not universally applicable to all fossil fired steam generators and are usually minor. Losses/credits that have not been specifically identified by this Code but are applicable in accordance with the intent of the Code should also be recorded on this sheet.

Parties to the test may agree to estimate the losses or credits in lieu of testing. Enter a 'T' for tested or 'E' for estimate in the second column, and result in the appropriate column

Enter the sum of each group on Form EFFb

Refer to the text of PTC 4 for the calculation method.

Item	T or E	LOSSES, % Enter Calculated Result in % Column[B]	A	MKB	B	%
110A		CO in Flue Gas				0.006
110B		Formation of NOx				0.000
110C		Pulverizer Rejects				0.000
110D		Air Infiltration				0.000
110E		Unburned Hydrocarbons in Flue Gas				0.000
110F		Unburned Hydrogen in Refuse				0.000
110G	E	Unmeasured Loss, as per agreement				0.200
110H	E	Surface Radiation Loss, as per agreement				0.250
110		Summation of Other Losses, % Basis				0.456

LOSSES, MJ/hr Enter in MKB Column [A]		
111A	Wet Ash Pit	0.000
111B	Sensible Heat in Recycle Streams, Solid	0.000
111C	Sensible Heat in Recycle Streams, Gas	0.000
111D	Additional Moisture	0.000
111E	Cooling Water	0.000
111F	Air Preheater Coil (supplied by Unit)	0.000
111G	Other	0.000
111	Summation of other Losses, MJ/hr Basis	0.000

CREDITS, % Enter Calculation Result in % Column [B]	
112A	Other
112	Summation of Credits, % Basis

CREDITS, MJ/hr Enter Result in MKB Column [A]		
113A	Heat in Additional Moisture (external to envelope)	0.000
113B	Other	0.000
113C	Heat by Auxiliary Equipment Power	3006.0
113	Summation of Credits, MJ/hr Basis	3006.0

PLANT NAME : NORGENER	ASME PTC 4 MASTER FORM	UNIT NO.	2
TEST NO : 6	DATE : 17-Dec-15	LOAD	47%
TIME START : 17:00	TIME END : 19:00	CALC BY	R. Tim
REMARKS :		DATE	11-Feb-16

APPENDIX H

Results Uncertainty Calculation

UNCERTAINTY CALCULATION NET HEAT RATE NORGENER Unit #2				(as per ASME PTC 19.1)			
VARIABLE	UNITS	B _i	2S _i	U _{ri}	Q	U _i ²	Ur
@0080 P Barometer	bar(a)	0.0010	0.0008	0.0013	10.99	0.0002	
@0081 T Ambient Temp.	°C	0.2000	0.4691	0.5100	1.194	0.3706	
@0082 X Rel.Humidity	%	2.5000	1.9770	3.1873	-0.171	0.2979	
@0102 T HP FW after FW Pumps	°C	0.5000	0.1996	0.5384	-0.023	0.0001	
@0105 dP HP Spray 1 W.Boiler	mbar	0.0000	0.8233	0.8233	9.899	66.416	
@0106 P HP Spray 1 W.Boiler	bar(a)	0.1687	0.5577	0.5826	0.000	0.0000	
@0110 dP RH Spray W.Boiler	mbar	0.1561	5.8164	5.8185	1.384	64.876	
@0111 P RH Spray W.Boiler	bar(a)	0.0739	1.0224	1.0251	0.003	0.0000	
@0112 T RH Spray 1 at FW Pump	°C	0.5000	0.1734	0.5292	-0.224	0.0141	
@0114 T RH Spray 3 at FW Pump	°C	0.5000	0.1821	0.5321	-0.224	0.0143	
@0115 dP HP Spray 2 W.Boiler	mbar	0.0000	0.7017	0.7017	0.000	0.0000	
@0116 P HP Spray 2 W.Boiler	bar(a)	0.1687	0.5568	0.5818	0.000	0.0000	
@0120 P Extraction HPH#2	bar(a)	0.0392	0.1563	0.1611	-0.134	0.0005	
@0121 T Extraction HPH#2	°C	0.5000	1.4295	1.5144	0.142	0.0465	
@0123 T FW Inlet HPH#2	°C	0.5000	0.2072	0.5412	3.596	3.7888	
@0124 P FW Outlet HPH#2	bar(a)	0.1847	0.6016	0.6293	0.020	0.0002	
@0125 T FW Outlet HPH#2	°C	0.5000	0.2388	0.5541	-3.769	4.361	
@0126 T Drain HPH#2	°C	0.5000	0.2080	0.5415	-0.264	0.0205	
@0130 P HP Steam Outl.Boiler	bar(a)	0.1656	0.5556	0.5797	-4.227	6.0050	
@0131 T HP Steam Outl.Boiler	°C	1.2000	2.0897	2.4098	10.61	653.96	
@0133 P Cold RH Inl.Boiler	bar(a)	0.0391	0.1580	0.1627	7.859	1.6357	
@0134 T Cold RH Inl.Boiler	°C	0.5000	1.4205	1.5059	-8.446	161.76	
@0135 P Hot RH Outl.Boiler	bar(a)	0.0359	0.1523	0.1565	-3.319	0.2697	
@0136 T Hot RH Outl.Boiler	°C	1.2000	1.4844	1.9088	7.927	228.92	
@0140 P FW Inlet Boiler	bar(a)	0.1823	0.5780	0.6061	-0.018	0.0001	
@0141 T FW Inlet Boiler	°C	0.5000	0.2770	0.5716	-17.94	105.20	
@0150 T CW Inlet Cond.(a)	°C	0.1000	0.5520	0.5610	-3.939	4.8840	
@0151 T CW Inlet Cond.(b)	°C	0.1000	0.5520	0.5610	-3.939	4.8840	
@0280 C Content Coal (Ultim.)	%	0.5908	0.1477	0.6090	7.952	23.452	
@0281 H Content Coal (Ultim.)	%	0.0041	0.0010	0.0042	4.084	0.0003	
@0282 S Content Coal (Ultim.)	%	0.0370	0.0093	0.0381	149.11	32.341	
@0283 N Content Coal (Ultim.)	%	0.1862	0.0466	0.1919	11.209	4.6287	
@0284 O Content Coal (Ultim.)	%	0.0094	0.0024	0.0097	0.177	0.0000	
@0285 W H ₂ O in Coal (Proxim.)	%	0.1148	0.0287	0.1183	-2.138	0.0640	
@0286 A Ash in Coal (Proxim.)	%	0.0577	0.0144	0.0595	11.70	0.4841	
@0287 V Volatile Coal(Proxim.)	%	0.3296	0.0824	0.3397	0.021	0.0001	
@0288 C Fixed Carbon (Proxim.)	%	0.4264	0.1066	0.4395	0.009	0.0000	
@0290 Ub Unburn.Bottom Ash	%	0.1018	0.0254	0.1049	1.120	0.0138	
@0291 Ub Unburn.Fly-Ash	%	0.0625	0.0156	0.0644	23.10	2.2154	
@0295 HHV Value of Coal	kJ/kg	353.70	88.425	364.59	-0.056	410.98	
@0520 Ym Fuel Eff.Boiler Meas.	%	0.2549	0.0637	0.2628	-118.2	963.91	
@0550 Pe Gross Power Gen.	kW	477.20	750.50	889.4	0.0001	0.0042	
@0553 Phi Power Factor	-	0.0035	0.0009	0.004	-4170	225.86	
@0560 Pe Net Power Unit (kWh)	kW	439.18	0.0000	439.18	-0.083	1330.4	
@1756 M FW Boiler Cond.Method	kg/s	2.200	0.8350	2.353	88.88	43742	
@0910 T Cold Prim.Air Aver.	°C	1.5000	0.6612	1.6393	-1.365	5.0105	
@0911 T Cold Sec.Air Aver.	°C	1.5000	0.6455	1.6330	0.000	0.0000	
@0912 T Hot Prim.Air Aver.	°C	2.5000	1.8432	3.1060	0.000	0.0000	
@0913 T Hot Sec.Air Aver.	°C	2.5000	1.7628	3.0590	0.000	0.0000	
@0914 T Exh.Inl.Air Heat.Aver.	°C	2.5000	8.9264	9.2699	0.000	0.0000	
@0915 T Exh.Outl.Air Heat.Aver	°C	2.5000	15.883	16.0789	5.447	7671.2	
@0919 O2 Oxig.Inl.Air Heat.Aver	vol%,dry	0.1520	0.1796	0.2353	-0.486	0.0131	
@0920 O2 Oxig.Outl.Air H.Aver.	vol%,dry	0.3275	1.1401	1.1862	21.62	657.67	
@0921 CO Outl.Air Heat.Aver.	ppm	0.0000	0.4601	0.460	0.016	0.000	
@1760 M HP Spray 1 Boiler (methodology)	kg/s	0.0031	0.0000	0.0031	12.70	0.0015	
@1770 M HP Spray 2 Boiler (methodology)	kg/s	0.0031	0.0000	0.0031	12.70	0.0015	
@1800 M RH Spray Boiler (methodology)	kg/s	0.0467	0.0000	0.0467	92.28	18.536	
Summation						56397	
Abs. Unc. Net Heat Rate	kJ/kWh						237.5
Rel. Unc. Net Heat Rate	%						2.3



ABOUT DNV GL

Driven by our purpose of safeguarding life, property and the environment, DNV GL enables organizations to advance the safety and sustainability of their business. We provide classification and technical assurance along with software and independent expert advisory services to the maritime, oil and gas, and energy industries. We also provide certification services to customers across a wide range of industries. Operating in more than 100 countries, our 16,000 professionals are dedicated to helping our customers make the world safer, smarter and greener.